

HENNEPIN COUNTY—PUBLIC SWIMMING POOL DAILY LOG SHEET

Pool Name _____ Month _____ Year _____ Size of Pool (gallons) _____ Flow Rate Required (GPM) _____

Date	DAILY TESTS					OTHER TESTS			CHEMICALS ADDED			MAINTENANCE			
	Free Cl ₂ 0.5–5.0ppm	Total Cl ₂	Comb. Cl ₂ <0.5 ppm	pH 7.2–8.0	Temp Max 104°F	Flow Meter GPM	Main Drain Close pool if loose, missing, or broken. Initial	Alk. > 50 ppm	CYA <100 ppm	Type	Amt.	Other	Back Wash	Press. PSI	Other i.e. H ₂ O added
1															
2															
3															
4															
5															
6															
7															
8															
9															
10															
11															
12															
13															
14															
15															
16															
17															
18															
19															
20															
21															
22															
23															
24															
25															
26															
27															
28															
29															
30															
31															