



POWER-FIN MAINTENANCE INSPECTION REPORT



DATE	Check vent and air piping	Check relief valve	Check condensate drain system	Inspect gas/ water pipes for leaks	Test low water cutoff and reset button	Inspect interior and clean	Inspect condensate system and flush	Examine venting system	Check igniter	Inspect and clean burner	Inspect and clean HEX
Recommended Inspection Intervals	Monthly	Monthly	Monthly	Every Six Months	Every Six Months	Annually	Annually	Annually	Annually	Annually	Annually

MODEL # _____ SERIAL# _____

FOR TECHNICAL QUESTIONS WWW.LOCHINVAR.COM OR CALL TECHNICAL SUPPORT AT 1-800-722-2101

FOR DETAILED INSTRUCTIONS SEE I & O MANUAL