



TYPICAL NOTES:

- 1)-ALL EXPOSED PIPING AND FITTINGS TO BE GALVANIZED
WITH EXCEPTION OF STORZ CONNECTION
- 2)-40' MAX. FROM FDC TO APPARATUS ACCESS LOCATION
- 3)-FOR NFPA 13R SYSTEMS (2 1/2" RISER AND SMALLER) SINGLE.
FDC W/ RALEIGH THREADS (3.340 X 6 SHARPE V FORM)
- 4)-WHEN BUILDING HT. IS GREATER THAN 200' USE RAL. SIAMESE

CITY OF RALEIGH FIRE DEPARTMENT
FIRE PROTECTION DIVISION
310 WEST MARTIN ST. RALEIGH, NC 27602

DESCRIPTION:
FLUSH FDC DETAIL REQUIRMENTS

REVISIONS:
5-1-06
W Warren

DATE:
S B

DRAWING NO.
FP-14