

## SECTION 084113 - ALUMINUM-FRAMED ENTRANCES AND STOREFRONTS

This suggested guide specification has been developed using the current edition of the Construction Specifications Institute (CSI) "Manual of Practice", including the recommendations for the CSI 3 Part Section Format and the CSI Page Format. Additionally, the development concept and organizational arrangement of the American Institute of Architects (AIA) MASTERSPEC Program has been recognized in the preparation of this guide specification. Neither CSI nor AIA endorse specific manufacturers and products. The preparation of the guide specification assumes the use of standard contract documents and forms, including the "Conditions of the Contract", published by the AIA.

### PART 1 - GENERAL

#### 1.1 Related Documents

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 Summary

- A. Section Includes: Kawneer Architectural Aluminum Storefront Systems, including perimeter trims, stools, accessories, shims and anchors, and perimeter sealing of storefront units.

*EDITOR NOTE: CHOOSE NON-THERMAL OR THERMAL SYSTEM.*

1. Types of Kawneer Aluminum Storefront Systems include:
  - a. Trifab™ VG 451 Framing System – 2" x 4-1/2" (50.8 mm x 114.3 mm) nominal dimension; Non-Thermal; Front, Center, Back, Multi-Plane, Structural Silicone or Weatherseal Glazed (Type B); Screw Spline, Shear Block, Stick or Punched Opening Fabrication.
  - b. Trifab™ VG 451 Framing System – Impact Glazing and Blast Mitigation.
  - c. Trifab™ VG 451T Framing System – 2" x 4-1/2" (50.8 mm x 114.3 mm) nominal dimension; Thermal; Front, Center, Back, Multi-Plane, Structural Silicone or Weatherseal Glazed (Type B); Screw Spline, Shear Block, Stick or Punched Opening Fabrication.
  - d. Trifab™ VG 451T Framing System – Impact Glazing and Blast Mitigation.

*EDITOR NOTE: BELOW RELATED SECTIONS ARE SPECIFIED ELSEWHERE HOWEVER KAWNEER RECOMMENDS SINGLE SOURCE RESPONSIBILITY FOR ALL OF THESE SECTIONS AS INDICATED IN PART 1.6 QUALITY ASSURANCE.*

- B. Related Sections:
1. 072700 "Air Barriers"
  2. 079200 "Joint Sealants"
  3. 083213 "Sliding Aluminum-Framed Glass Doors"
  4. 084113 "Aluminum-Framed Entrances and Storefronts"
  5. 084329 "Sliding Storefronts"
  6. 084413 "Glazed Aluminum Curtain Walls"
  7. 084433 "Sloped Glazing Assemblies"
  8. 085113 "Aluminum Windows"
  9. 086300 "Metal-Framed Skylights"
  10. 088000 "Glazing"
  11. 107113 "Exterior Sun Control Devices"
  12. 122600 "Interior Daylighting Devices"

#### 1.3 Definitions

- A. Definitions: For fenestration industry standard terminology and definitions refer to American Architectural Manufacturers Association (AAMA) – AAMA Glossary (AAMA AG).

#### 1.4 Performance Requirements

- A. Storefront System Performance Requirements:

*EDITOR NOTE: AIR AND WATER PERFORMANCE RESULTS ARE BASED UPON ASTM AND AAMA STANDARDS FOR STOREFRONT FRAMING SYSTEMS. CONSULT YOUR LOCAL KAWNEER REPRESENTATIVE CONCERNING SPECIFIC PROJECT PERFORMANCE REQUIREMENTS.*

*EDITOR NOTE: PROVIDE WIND LOAD DESIGN PRESSURES IN PSF AND INCLUDE APPLICABLE BUILDING CODE AND YEAR EDITION*

1. Wind loads: Provide storefront system; include anchorage, capable of withstanding wind load design pressures of (\_\_\_\_) lbs./sq. ft. inward and (\_\_\_\_) lbs./sq. ft. outward. The design pressures are based on the (\_\_\_\_) Building Code; (\_\_\_\_) Edition.
2. Air Infiltration: The test specimen shall be tested in accordance with ASTM E 283. Air infiltration rate shall not exceed 0.06 cfm/ft<sup>2</sup> (0.3 l/s · m<sup>2</sup>) at a static air pressure differential of 6.24 psf (300 Pa).

3. Water Resistance: The test specimen shall be tested in accordance with ASTM E 331. There shall be no leakage at a minimum static air pressure differential of 8 psf (383 Pa) as defined in AAMA 501.
4. Uniform Load: A static air design load of 35 psf (1680 Pa) shall be applied in the positive and negative direction in accordance with ASTM E 330. There shall be no deflection in excess of L/175 of the span of any framing member. At a structural test load equal to 1.5 times the specified design load, no glass breakage or permanent set in the framing members in excess of 0.2% of their clear spans shall occur.

**EDITOR NOTE: THERMAL TRANSMITTANCE AND CONDENSATION RESISTANCE PERFORMANCE RESULTS ARE BASED UPON 1" CLEAR INSULATING GLASS (1/4" CLEAR WITH  $\epsilon = 0.035$  LOW E COATING ON #2 SURFACE, 1/2" AS WITH WARM EDGE SPACER AND 90% ARGON GAS FILL, 1/4" CLEAR).**

5. Thermal Transmittance (U-factor): When tested to AAMA Specification 1503, the thermal transmittance (U-factor) shall not be more than:
  - a. Glass to Exterior – 0.47 (low-e) or 0.61 (clear) or Project Specific ( ) BTU/hr/ft<sup>2</sup>/°F.
  - b. Glass to Center – 0.44 (low-e) or 0.61 (clear) or Project Specific ( ) BTU/hr/ft<sup>2</sup>/°F.
  - c. Glass to Interior – 0.41 (low-e) or 0.56 (clear) or Project Specific ( ) BTU/hr/ft<sup>2</sup>/°F.
6. Condensation Resistance (CRF): When tested to AAMA Specification 1503, the condensation resistance factor shall not be less than:
  - a. Glass to Exterior – 70<sub>frame</sub> and 69<sub>glass</sub> (low-e) or 69<sub>frame</sub> and 58<sub>glass</sub> (clear).
  - b. Glass to Center – 62<sub>frame</sub> and 68<sub>glass</sub> (low-e) or 63<sub>frame</sub> and 56<sub>glass</sub> (clear).
  - c. Glass to Interior – 56<sub>frame</sub> and 67<sub>glass</sub> (low-e) or 54<sub>frame</sub> and 58<sub>glass</sub> (clear).

**EDITOR NOTE: SOUND TRANSMISSION CLASS (STC) AND OUTDOOR-INDOOR TRANSMISSION CLASS (OITC) TEST RESULTS ARE BASED UPON 1" CLEAR DOUBLE LAMINATED INSULATING GLASS WITH PVB INTERLAYER (1/8", .030", 1/8", 1/2" AS, 1/8", .030", 1/8").**

7. Sound Transmission Class (STC) and Outdoor-Indoor Transmission Class (OITC): When tested to AAMA Specification 1801 and in accordance with ASTM E1425 and ASTM E90, the STC and OITC Rating shall not be less than:
  - a. Glass to Exterior – 38 (STC) and 31 (OITC).
  - b. Glass to Center – 37 (STC) and 30 (OITC).
  - c. Glass to Interior – 38 (STC) and 30 (OITC).

**EDITOR NOTE: CHOOSE IMPACT RESISTANCE PERFORMANCE IF REQUIRED TO MEET PROJECT REQUIREMENTS.**

8. Windborne-Debris-Impact Resistance Performance: Shall be tested in accordance with ASTM E 1886, information in ASTM E 1996 and TAS 201/203.
  - a. Large-Missile Impact: For aluminum-framed systems located within 30 feet (9.1 m) of grade.
  - b. Small-Missile Impact: For aluminum-framed systems located above 30 feet (9.1 m) of grade.

**EDITOR NOTE: CHOOSE BLAST MITIGATION PERFORMANCE IF REQUIRED TO MEET PROJECT REQUIREMENTS.**

9. Blast Mitigation Performance: Shall be tested or proven through analysis to meet ASTM F1642, GSA-TS01, and UFC 04-010.01 performance criteria.

To meet UFC 04-010.01, B-3.1 Standard 10 for Windows and Skylights, the following options are available:

- a. Section B-3.1.1 Dynamic analysis.
- b. Section B-3.1.2 Testing.
- c. Section B-3.1.3 ASTM F2248 Design Approach.

## 1.5 Submittals

- A. Product Data: Include construction details, material descriptions, dimensions of individual components and profiles, hardware, finishes, and installation instructions for each type of aluminum-framed storefront system indicated.
- B. Shop Drawings: Include plans, elevations, sections, details, hardware, and attachments to other work, operational clearances and installation details.
- C. Samples for Initial Selection: For units with factory-applied color finishes including samples of hardware and accessories involving color selection.
- D. Samples for Verification: For aluminum-framed storefront system and components required.
- E. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency for each type of aluminum-framed storefront.
- F. Fabrication Sample: Of each vertical-to-horizontal intersection of aluminum-framed systems, made from 12" (304.8 mm) lengths of full-size components and showing details of the following:
  1. Joinery.
  2. Anchorage.
  3. Expansion provisions.
  4. Glazing.
  5. Flashing and drainage.
- G. Other Action Submittals:
  1. Entrance Door Hardware Schedule: Prepared by or under the supervision of supplier, detailing fabrication and assembly of entrance door hardware, as well as procedures and diagrams. Coordinate final entrance door hardware schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of entrance door hardware.

Laws and building and safety codes governing the design and use of glazed entrance, window, and curtain wall products vary widely. Kawneer does not control the selection of product configurations, operating hardware, or glazing materials, and assumes no responsibility therefor.

Kawneer reserves the right to change configuration without prior notice when deemed necessary for product improvement.  
© Kawneer Company, Inc., 2010

## 1.6 Quality Assurance

- A. Installer Qualifications: An installer which has had successful experience with installation of the same or similar units required for the project and other projects of similar size and scope.
- B. Manufacturer Qualifications: A manufacturer capable of providing aluminum-framed storefront system that meet or exceed performance requirements indicated and of documenting this performance by inclusion of test reports, and calculations.
- C. Source Limitations: Obtain aluminum-framed storefront system through one source from a single manufacturer.
- D. Product Options: Drawings indicate size, profiles, and dimensional requirements of aluminum-framed storefront system and are based on the specific system indicated. Refer to Division 01 Section "Product Requirements". Do not modify size and dimensional requirements.
  - 1. Do not modify intended aesthetic effects, as judged solely by Architect, except with Architect's approval. If modifications are proposed, submit comprehensive explanatory data to Architect for review.
- E. Mockups: Build mockups to verify selections made under sample submittals and to demonstrate aesthetic effects and set quality standards for materials and execution.
  - 1. Build mockup for type(s) of storefront elevation(s) indicated, in location(s) shown on Drawings.
- F. Pre-installation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination".
- G. Structural-Sealant Glazing: Comply with ASTM C 1401, "Guide for Structural Sealant Glazing" for design and installation of structural-sealant-glazed systems.
- H. Structural-Sealant Joints: Design reviewed and approved by structural-sealant manufacturer.

## 1.7 Project Conditions

- A. Field Measurements: Verify actual dimensions of aluminum-framed storefront openings by field measurements before fabrication and indicate field measurements on Shop Drawings.

## 1.8 Warranty

- A. Manufacturer's Warranty: Submit, for Owner's acceptance, manufacturer's standard warranty.
  - 1. Warranty Period: Two (2) years from Date of Substantial Completion of the project provided however that the Limited Warranty shall begin in no event later than six months from date of shipment by manufacturer.

## PART 2 - PRODUCTS

### 2.1 Manufacturers

*EDITOR NOTE: CHOOSE NON-THERMAL OR THERMAL SYSTEM AND GLASS ORIENTATION CENTER, EXTERIOR (FRONT), INTERIOR (BACK).*

- A. Basis-of-Design Product:
  - 1. Kawneer Company Inc.
  - 2. Trifab™ VG 451 (Non-Thermal) or Trifab™ 451T (Thermal) Framing System
  - 3. Trifab™ VG 451 (Non-Thermal) or Trifab™ 451T (Thermal) Framing System (Impact Glazing and Blast Mitigation)
  - 4. System Dimensions: 2" x 4-1/2" (50.8 mm x 114.3 mm)
  - 5. Glass: Center, Exterior or Interior

*EDITOR NOTE: PROVIDE INFORMATION BELOW INDICATING APPROVED ALTERNATIVES TO THE BASIS-OF-DESIGN PRODUCT*

- B. Subject to compliance with requirements, provide a comparable product by the following:
  - 1. Manufacturer: (\_\_\_\_\_)
  - 2. Series: (\_\_\_\_\_)
  - 3. Profile dimension: (\_\_\_\_\_)
- C. Substitutions: Refer to Substitutions Section for procedures and submission requirements
  - 1. Pre-Contract (Bidding Period) Substitutions: Submit written requests ten (10) days prior to bid date.
  - 2. Post-Contract (Construction Period) Substitutions: Submit written request in order to avoid storefront installation and construction delays.
  - 3. Product Literature and Drawings: Submit product literature and drawings modified to suit specific project requirements and job conditions.
  - 4. Certificates: Submit certificate(s) certifying substitute manufacturer (1) attesting to adherence to specification requirements for storefront system performance criteria, and (2) has been engaged in the design, manufacturer and fabrication of aluminum storefronts for a period of not less than ten (10) years. (Company Name)
  - 5. Test Reports: Submit test reports verifying compliance with each test requirement required by the project.
  - 6. Samples: Provide samples of typical product sections and finish samples in manufacturer's standard sizes.
- D. Substitution Acceptance: Acceptance will be in written form, either as an addendum or modification, and documented by a formal change order signed by the Owner and Contractor.

**2.2 Materials**

- A. Aluminum Extrusions: Alloy and temper recommended by aluminum storefront manufacturer for strength, corrosion resistance, and application of required finish and not less than 0.070" (1.8 mm) wall thickness at any location for the main frame and complying with ASTM B 221: 6063-T6 alloy and temper.
- B. Fasteners: Aluminum, nonmagnetic stainless steel or other materials to be non-corrosive and compatible with aluminum framing members, trim hardware, anchors, and other components.
- C. Anchors, Clips, and Accessories: Aluminum, nonmagnetic stainless steel, or zinc-coated steel or iron complying with ASTM B 633 for SC 3 severe service conditions or other suitable zinc coating; provide sufficient strength to withstand design pressure indicated.
- D. Reinforcing Members: Aluminum, nonmagnetic stainless steel, or nickel/chrome-plated steel complying with ASTM B 456 for Type SC 3 severe service conditions, or zinc-coated steel or iron complying with ASTM B 633 for SC 3 severe service conditions or other suitable zinc coating; provide sufficient strength to withstand design pressure indicated.
- E. Sealant: For sealants required within fabricated storefront system, provide permanently elastic, non-shrinking, and non-migrating type recommended by sealant manufacturer for joint size and movement.
- F. Tolerances: Reference to tolerances for wall thickness and other cross-sectional dimensions of storefront members are nominal and in compliance with AA Aluminum Standards and Data.

**2.3 Storefront Framing System**

- A. Thermal Barrier (Trifab™ VG 451T):
  - 1. Kawneer IsoLock™ Thermal Break with a 1/4" (6.4 mm) separation consisting of a two-part chemically curing, high-density polyurethane, which is mechanically and adhesively joined to aluminum storefront sections.
    - a. Thermal Break shall be designed in accordance with AAMA TIR-A8 and tested in accordance with AAMA 505.
- B. Versoleil™ SunShade: An aluminum sunshade (consisting of outriggers, louvers, and fascia which may be selected from standard configurations), that is anchored directly to the vertical mullions. Outriggers shall be painted (Select from Kawneer's standard paints and colors. Custom colors are available upon request). Louvers and fascia shall be painted or anodized (Select from Kawneer's standard paints and colors, custom colors are available upon request or Kawneer's anodized finishes).
- C. InLighten™ Light Shelf: aluminum light shelf system consisting of anchor channels, support beams, fascia trims and Aluminum Composite Material (ACM) panels that is anchored directly to the intermediate horizontal members.
  - 1. Light Shelf: Interior mounted shelf to reflect daylight deeper into interior space.
  - 2. Light Shelf System to consist of:
    - a. Aluminum Composite Material (ACM) panel, 4mm thick.
    - b. Translucent polycarbonate panel, 4mm/16mm thick.
    - c. ACM finish on upper and lower surface shall be selected from Kawneer standard finishes.
    - d. Extruded aluminum outriggers and fascia.
    - e. Extruded aluminum anchor designed to secure to compatible verticals of framing system. Anchor shall be designed to engage shelf so as to allow the shelf to rotate down and hang on its own safely for cleaning.
    - f. Extruded aluminum shear blocks designed to hinge on the anchors to allow rotating individual shelves for cleaning.
    - g. Panel /Shelf projection shall not exceed 30" (762mm).
    - h. Mullion spacing of framing system shall not exceed 6' (1.83 m) on center.
    - i. Panel /Shelf deflection shall not exceed L/120 of horizontal span length.
  - 3. Framing System to Support Light Shelf shall be: (select appropriate framing system)
    - a. Curtain Wall framing system.
    - b. Storefront framing system.
  - 4. Submittals.
    - a. Manufacturer's Installation Instructions.
    - b. Samples for Verification.
      - 1) Factory applied finish as selected by architect.
      - 2) Functioning Light Shelf sample demonstrating operation.
    - c. Shop Drawings including:
      - 1) Plans, elevations, sections, fabrication and installation details.
      - 2) Validation from manufacturer of single-source for light shelf and framing system and compatibility between the system.
- D. Brackets and Reinforcements: Manufacturer's standard high-strength aluminum with nonstaining, nonferrous shims for aligning system components.
- E. Fasteners and Accessories: Manufacturer's standard corrosion-resistant, nonstaining, nonbleeding fasteners and accessories compatible with adjacent materials. Where exposes shall be stainless steel.
- F. Perimeter Anchors: When steel anchors are used, provide insulation between steel material and aluminum material to prevent galvanic action
- G. Packing, Shipping, Handling and Unloading: Deliver materials in manufacturer's original, unopened, undamaged containers with identification labels intact.

Laws and building and safety codes governing the design and use of glazed entrance, window, and curtain wall products vary widely. Kawneer does not control the selection of product configurations, operating hardware, or glazing materials, and assumes no responsibility therefor.

Kawneer reserves the right to change configuration without prior notice when deemed necessary for product improvement.  
© Kawneer Company, Inc., 2010

- H. Storage and Protection: Store materials protected from exposure to harmful weather conditions. Handle storefront material and components to avoid damage. Protect storefront material against damage from elements, construction activities, and other hazards before, during and after storefront installation.

## 2.4 Glazing Systems

- A. Glazing: As specified in Division 08 Section "Glazing".
- B. Glazing Gaskets: Manufacturer's standard compression types; replaceable, extruded EPDM rubber.
- C. Spacers and Setting Blocks: Manufacturer's standard elastomeric type.
- D. Bond-Breaker Tape: Manufacturer's standard TFE-fluorocarbon or polyethylene material to which sealants will not develop adhesion.
- E. Glazing Sealants: For structural-sealant-glazed systems, as recommended by manufacturer for joint type, and as follows:
  - 1. Structural Sealant: ASTM C 1184, single-component neutral-curing silicone formulation that is compatible with system components with which it comes in contact, specifically formulated and tested for use as structural sealant and approved by a structural-sealant manufacturer for use in aluminum-framed systems indicated.
    - a. Color: Black
  - 2. Weatherseal Sealant: ASTM C 920 for Type S, Grade NS, Class 25, Uses NT, G, A, and O; single-component neutral-curing formulation that is compatible with structural sealant and other system components with which it comes in contact; recommended by structural-sealant, weatherseal-sealant, and aluminum-framed-system manufacturers for this use.
    - a. Color: Matching structural sealant.

## 2.5 Entrance Door Systems

- A. Entrance Doors: As specified in Division 084113 Section "Aluminum-Framed Entrances and Storefronts".
- B. Entrance Door Hardware: As specified in Division 084113 Section "Door Hardware".

## 2.6 Accessory Materials

- A. Joint Sealants: For installation at perimeter of aluminum-framed systems, as specified in Division 07 Section "Joint Sealants".
- B. Bituminous Paint: Cold-applied, asphalt-mastic paint complying with SSPC-Paint 12 requirements except containing no asbestos; formulated for 30 mil (0.762 mm) thickness per coat.

## 2.7 Fabrication

- A. Framing Members, General: Fabricate components that, when assembled, have the following characteristics:
  - 1. Profiles that are sharp, straight, and free of defects or deformations.
  - 2. Accurately fit joints; make joints flush, hairline and weatherproof.
  - 3. Means to drain water passing joints, condensation within framing members, and moisture migrating within the system to exterior.
  - 4. Physical and thermal isolation of glazing from framing members.
  - 5. Accommodations for thermal and mechanical movements of glazing and framing to maintain required glazing edge clearances.
  - 6. Provisions for field replacement of glazing.
  - 7. Fasteners, anchors, and connection devices that are concealed from view to greatest extent possible.
- B. Mechanically Glazed Framing Members: Fabricate for flush glazing without projecting stops.
- C. Structural-Sealant-Glazed Framing Members: Include accommodations for using temporary support device to retain glazing in place while structural sealant cures.
- D. Storefront Framing: Fabricate components for assembly using manufacturer's standard installation instructions.
- E. After fabrication, clearly mark components to identify their locations in Project according to Shop Drawings.

## 2.8 Aluminum Finishes

- A. Finish designations prefixed by AA comply with the system established by the Aluminum Association for designating aluminum finishes.
- B. Factory Finishing:
  - 1. Kawneer Permanodic™ AA-M10C21A44 / AA-M45C22A44, AAMA 611, Architectural Class I Color Anodic Coating (Color \_\_\_\_\_).
  - 2. Kawneer Permanodic™ AA-M10C21A41 / AA-M45C22A41, AAMA 611, Architectural Class I Clear Anodic Coating (Color #14 Clear) (Optional).
  - 3. Kawneer Permanodic™ AA-M10C21A31, AAMA 611, Architectural Class II Clear Anodic Coating (Color #17 Clear) (Standard).
  - 4. Kawneer Permafluor™ (70% PVDF), AAMA 2605, Fluoropolymer Coating (Color \_\_\_\_\_).
  - 5. Kawneer Permادize™ (50% PVDF), AAMA 2604, Fluoropolymer Coating (Color \_\_\_\_\_).
  - 6. Kawneer Permacoat™ AAMA 2604, Powder Coating (Color \_\_\_\_\_)
  - 7. Other: Manufacturer \_\_\_\_\_ Type \_\_\_\_\_ Color \_\_\_\_\_.

Laws and building and safety codes governing the design and use of glazed entrance, window, and curtain wall products vary widely. Kawneer does not control the selection of product configurations, operating hardware, or glazing materials, and assumes no responsibility therefor.

Kawneer reserves the right to change configuration without prior notice when deemed necessary for product improvement.  
© Kawneer Company, Inc., 2010

**PART 3 - EXECUTION****3.1 Examination**

- A. Examine openings, substrates, structural support, anchorage, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of work. Verify rough opening dimensions, levelness of sill plate and operational clearances. Examine wall flashings, vapor retarders, water and weather barriers, and other built-in components to ensure a coordinated, weather tight framed aluminum storefront system installation.
1. Masonry Surfaces: Visibly dry and free of excess mortar, sand, and other construction debris.
  2. Wood Frame Walls: Dry, clean, sound, well nailed, free of voids, and without offsets at joints. Ensure that nail heads are driven flush with surfaces in opening and within 3 inches (76 mm) of opening.
  3. Metal Surfaces: Dry; clean; free of grease, oil, dirt, rust, corrosion, and welding slag; without sharp edges or offsets at joints.
  4. Proceed with installation only after unsatisfactory conditions have been corrected.

**3.2 Installation**

- A. Comply with Drawings, Shop Drawings, and manufacturer's written instructions for installing aluminum-framed storefront system, accessories, and other components.
- B. Install aluminum-framed storefront system level, plumb, square, true to line, without distortion or impeding thermal movement, anchored securely in place to structural support, and in proper relation to wall flashing and other adjacent construction.
- C. Set sill members in bed of sealant or with gaskets, as indicated, for weather tight construction.
- D. Install aluminum-framed storefront system and components to drain condensation, water penetrating joints, and moisture migrating within aluminum-framed storefront to the exterior.
- E. Separate aluminum and other corrodible surfaces from sources of corrosion or electrolytic action at points of contact with other materials.

**3.3 Field Quality Control**

- A. Field Tests: Architect shall select storefront units to be tested as soon as a representative portion of the project has been installed, glazed, perimeter caulked and cured. Conduct tests for air infiltration and water penetration with manufacturer's representative present. Tests not meeting specified performance requirements and units having deficiencies shall be corrected as part of the contract amount.
1. Testing: Testing shall be performed by a qualified independent testing agency. Refer to Testing Section for payment of testing and testing requirements. Testing Standard per AAMA 503, including reference to ASTM E 783 for Air Infiltration Test and ASTM E 1105 Water Infiltration Test.
    - a. Air Infiltration Tests: Conduct tests in accordance with ASTM E 783. Allowable air infiltration shall not exceed 1.5 times the amount indicated in the performance requirements or 0.09 cfm/ft<sup>2</sup>, whichever is greater.
    - b. Water Infiltration Tests: Conduct tests in accordance with ASTM E 1105. No uncontrolled water leakage is permitted when tested at a static test pressure of two-thirds the specified water penetration pressure but not less than 6.24 psf (300 Pa).
- B. Manufacturer's Field Services: Upon Owner's written request, provide periodic site visit by manufacturer's field service representative.

**3.4 Adjusting, Cleaning, and Protection**

- A. Clean aluminum surfaces immediately after installing aluminum-framed storefronts. Avoid damaging protective coatings and finishes. Remove excess sealants, glazing materials, dirt, and other substances.
- B. Clean glass immediately after installation. Comply with glass manufacturer's written recommendations for final cleaning and maintenance. Remove nonpermanent labels, and clean surfaces.
- C. Remove and replace glass that has been broken, chipped, cracked, abraded, or damaged during construction period.

**DISCLAIMER STATEMENT**

This guide specification is intended to be used by a qualified construction specifier. The guide specification is not intended to be verbatim as project specification without appropriate modifications for the specific use intended. The guide specification must be used and coordinated with the procedures of each design firm, and the particular requirements of a specific construction project.

**END OF SECTION 084113**

Laws and building and safety codes governing the design and use of glazed entrance, window, and curtain wall products vary widely. Kawneer does not control the selection of product configurations, operating hardware, or glazing materials, and assumes no responsibility therefor.

Kawneer reserves the right to change configuration without prior notice when deemed necessary for product improvement.  
© Kawneer Company, Inc., 2010