



# Arkansas Department of Health

## STATEMENT OF ACA FINDINGS AND PLAN OF CORRECTION

NAME OF FACILITY		STREET ADDRESS, CITY, STATE, ZIP CODE		DATE SURVEY COMPLETED		
Mansfield Juvenile Treatment Center - Boys		Post Office Box 478 Mansfield, AR 72944		3/29/2011		
CITED STANDARD	SUMMARY STATEMENT OF FINDINGS	CITED STANDARD	FACILITY'S PLAN OF CORRECTION	Date of Completion	CITED STANDARD	RESULT OF FOLLOW-UP
<b>Arkansas State Plumbing Codes</b>  <b>1002.4 Trap Seals</b> Each fixture trap shall have a liquid seal of not less than 2 inches and not more than 4 inches, or deeper for special designs relating to accessible fixtures. Where a trap seal is subject to loss by evaporation, a trap seal primer valve shall be	<b>Arkansas State Plumbing Code 1002.4</b>  Based on the State Plumbing inspection completed on 3/29/2011, the facility shall properly maintain all floor drains.		<b>1002.4:</b> The existing construction that has housed the facility since 1994 was constructed in the 1960's. New construction is slated to be completed in July and all residents will be relocated to those buildings. Shift supervisors and other designees periodically pour water or cooking oil down the drains of showers that are not currently in use to avoid sewer gas issues. This has taken place as needed for many years.	03/29/11		Follow-up conducted on 5/24/11. This deficiency was cleared.



# Arkansas Department of Health

## STATEMENT OF ACA FINDINGS AND PLAN OF CORRECTION

installed.						
<p><b>Environmental Health Services</b></p> <p><b>Rules and Regulations Pertaining to General Sanitation</b></p> <p><b>Section VIII. (A) A Public toilet facilities must be provided and maintained in accordance with Arkansas Plumbing Code, kept clean, adequately lighted properly ventilated and in good repair.</b></p>	<p><b>Environmental Health Services Section VIII A.</b></p> <p>Based on the 3/29/2011, 10:30 AM – 10:45 AM tour of the boys dorms shower stalls, five of six had a dark brownish build up around the lower sides of the walls.</p>		<p><b>Sec. VIII A: All showers in the dorm living areas for boys are to be cleaned after showers on second shift and again in the morning on first shift every day. These chores are assigned to clients as part of their daily dorm “details.” A supervisor meeting was held on 3/29 to reinforce that Team Assistants are to inspect all dorm details upon completion and the Shift Supervisor will complete a thorough inspection to ensure that the details are completed in a satisfactory manner.</b></p>	<p><b>3/29 and daily after.</b></p>		<p><b>Follow up completed 5/24/11. This deficiency was cleared.</b></p>