

Clarifications No. 1, November 14, 2011 – San Diego I-805 HOV/BRT Design-Build Project Contract No. 11-2T2004

RFC No.	Category	Document	Section	Clarification	Response
1	3	Book 2	2.4.2.3.4, p.2-20	RFP states that Caice File format is to be used for design submittals. Please clarify that the Department's intent is that only final drawings are required to be submitted in MicroStation and Caice format. Work may be completed on other systems and intermediate design deliverables can be in PDF format.	Final drawings and survey data are to be submitted to the Department in Microstation and CAiCE format, respectively. Work may be done on other systems as long as they can be converted to these required formats. Intermediate design-deliverables can be in PDF format unless expressly required in another format in the RFP.
2	3	Book 2	8.1 P. 8-1	Please provide preliminary geotechnical explorations as stated in this section. This section indicates that there have been subsurface explorations performed. However, there are not documents included in the RIDs or Contract Documents.	The boring information was originally provided in the RID. Selected soil boring information for the project has now been provided as Exhibit 8-A, "Log of Test Borings" per Addendum No. 2.
3	2	Book 2	13.5.3.2	There is a reference to Exhibit 13-B, which we cannot locate.	Exhibit 13-B was provided with Addendum No. 2.
4	4	Book 2	15.2.1 P. 15-1	Please provide the Aesthetic Guidelines for Bridge Design document.	A revised Exhibit 15-A was provided with Addendum No. 2.
5	4	Book 2	16.2.5 P. 16-4	Please clarify the version of CAiCE and Microstation to use.	Correct versions are Microstation V8 and CAICE V10SP8. The RFP has been updated to reflect these versions in Addendum No. 2.
6	3	Book 2	18 General	Who will pay the costs of COZEEP on the project?	The Department will pay the costs of COZEEP on the project.
7	1	RID	CAD Files	Please provide access information to the "Hidden" website for the Microstation files. We have not received the 2 nd letter, discussed at the one-on-one meeting, containing access information.	Only one letter has been sent and contained both the "hidden link" and the RFP link. The Department has resent the link to all Proposers.
8	3	RID	General	Please make available the electronic design files (CAD files) used in the preparation of the Conceptual Plans. Specifically, the proposed horizontal design (edges of pavements and shoulders, guardrails, etc.), vertical alignments, superelevation design, drainage design, and etc. are requested. This request includes electronic files of the adjacent projects and the ultimate design concept.	These electronic files used to prepare Conceptual Plans were provided in the original release of the RFP on the hidden link. Master files of adjacent projects were also provided at the same location. The ultimate design concept file has now been posted as "Alt5.dgn" on the hidden link.

Clarifications No. 1, November 14, 2011 – San Diego I-805 HOV/BRT Design-Build Project Contract No. 11-2T2004

RFC No.	Category	Document	Section	Clarification	Response
9	3	RID	General	<p>The following RIDs are missing:</p> <p>57_0760RL_Rose_Cyn_Bridge.zip 57_0787_Carroll Canyon_Bridge.zip 57_DAR2 Carroll Canyon DAR.zip 57_0759 Governor Drive Bridge.zip</p>	These are bridge site submittals and can be accessed through the hidden link.
10	3	RID	General	<p>The following RIDs are missing:</p> <p>CDFG 1602 Agreement RWQCB Section 401 Certification Corps Section 404 permit Permit from the PUC.</p>	<p>CDFG 1602 Agreement was provided with Addendum No. 2.</p> <p>The 401 Certification and 404 Permit are pending and will be provided when received by the Department.</p> <p>The Permit from the PUC is dependent on the Final Design. The Design-Builder will be responsible for providing all deliverables required for the permit and the Department will obtain the permit..</p>
11	3	RID	General	<p>The following RIDs are missing:</p> <p>Project - 11-045894 – 805 at Carroll Canyon Bridge and Mira Mesa. We have bridge plans but not the rest of the plans which should include the drainage system.</p>	The roadway plans for these projects have now been posted to the RID.
12	2	RID	Governor Drive UC57-0759RL PFR / Page 2	<p>"In the RID's, on page 2 of the document "Governor Drive UC57-0759RL PFR" under the heading "Fault and Seismic Data" reference is made to the "Preliminary Seismic Design Recommendations (PSDR)(dated July 28, 2011 by Asef Wardak of the Office of Geotechnical Design South 2." Please provide this documentation to the bidders.</p>	Preliminary Seismic Design Recommendations for all structure locations have now been posted to the RID.
13	2	RID	Missing Information / Files	<p>Please provide the following missing information:</p> <p>Microstation master files containing linework of Roadway, Utilities, striping, signing, drainage, fiber optics, signals, and electrical.</p>	The Microstation master file b2T200aa1.dgn only contains linework of roadway, existing features such as utilities, striping, signing and drainage. Other information is currently not available or only available through as-builts. This file has been updated and reposted to the hidden link to show the ESA areas.

Clarifications No. 1, November 14, 2011 – San Diego I-805 HOV/BRT Design-Build Project Contract No. 11-2T2004

RFC No.	Category	Document	Section	Clarification	Response
14	2	RID	Missing Information / Files	Please provide the following missing information: Microstation cut sheet files of the pdf files provided.	The files were already posted and can be accessed through the hidden link.
15	2	RID	Missing Information / Files	Please provide the following missing information: Microstation "Alt5.dgn" is referenced to topographical base maps but not provided.	"Alt5.dgn" has now been uploaded to the hidden link.
16	2	RID	Missing Information / Files	Please provide the following missing information: CAiCE DTM files of the project concepts	These files have been posted to the RID.
17	2	RID	Missing Information / Files	Please provide the following missing information: CAiCE DTM files of the projects under construction: La Jolla Village Dr/Miramar Rd. Interchange(Contract 11-089754) and Carroll Canyon Rd/Mira Mesa Blvd Interchange (Contract 11-2T0404)	This information is not currently available. Information on these projects can be extracted from contract plans that have been provided.
18	2	RID	Missing Information / Files	Please provide the following missing information: Section 8.1, paragraph 3 says that there was pre-contract limited subsurface exploration performed for the project to reduce unknowns and it goes on to say that it was included in the RIDs, however we have not been able to find this information.	Soil boring information for the project was provided in Addendum No.2, Exhibit 8-A, "Log of Test Borings."
19	2	RID	Missing Information / Files	Please provide the following missing information: Preliminary Foundation Reports that were provided in the RIDs, it indicated that a Seismic Hazard Report was prepared. This report however was not included in the RIDs; we would like to request a copy of the Report.	Preliminary Seismic Design Reports for all structure locations have been posted to the RID.