ATTACHMENT I

GENERATOR MAINTENANCE CHECKLIST

Vendor information		Owner information		
Name:		Name:		
Address:		Address:		
Phone:		Site:		
Generator		Transfer Switch		
Model Number:		Model Number:		
Serial Number:		Serial Number:		
Size:	KW	Capacity:	AMP	
MONTHLY CHECKLI	ST		DATE	
 Clean and check batt Check for proper bel Check hoses and clan Check fluid levels Check proper block h Check battery charge Check no load voltag Check automatic tranunder a simulated po Check generator exen Clean automatic tran Generate a test and in 	t alignment and apps neater operation of the control of the contro	tensions more ation proper operation inet		
<u>GENERAT</u>	OK MAIN	TENANCE CHEC	KLIST	
Vendor information		Owner inf	formation	
Name:		Name:		

Address: Phone: Generator Model Number:		Address:Site: Transfer Switch Model Number:					
						Serial Number:	
				Serial Number:			
				Size:	KW	Capacity:	AMP
		-					
Clean and check battCheck for proper belCheck and lubricate	t alignment and						
Check for leaks of oil	O						
 Check hoses and clan 	nps						
□ Change oil and filter							
□ Change air filter							
Clean spark arresterClean spark plugs							
□ Check coolant fluid le	evel						
□ Check proper block l		n					
□ Check battery charge	-						
□ Check no load voltag		-					
Clean automatic tran							
□ Check automatic trai		proper operation					
under a simulated po							
□ Check Generator exe		4					
 Generate a test and in 	nspection repoi	rt					

2.1 Vendor information	Owner		
infor	rmation		
Name:	Name:		
Address:	Address:		
Phone:	Site: Transfer Switch Model Number:		
Generator			
Model Number:			
Serial Number:	Serial Number:		
Size:KW	Capacity:AMP		
YEARLY CHECKLIST	DATE		
 □ Governor – Check oil level □ Change engine oil □ Change oil filter □ Clean or replace air cleaner element □ Check charge and level of battery □ Clean battery cables □ Check and adjust alternator, fan and □ Lubricate throttle, governor and cho □ Change coolant hoses □ Check and refill cooling system 	d governor belts		
 Check and adjust idle speed Check and adjust idle mixture 			
 Check and adjust idle speed Check and adjust idle mixture Inspect spark plugs, replace if necess Clean and check distributor points, on the check and adjust ignition timing 			

Replace PVC valve	
Check all hardware, fittings, clamps, fasteners etc	
Check starter for proper cranking RPM and starter	
disconnect	
□ Inspect safety shutdown devices, simulating faults	
On low oil pressure, high water temp and overspend	
Inspect governor brush holders and brushes,	
commutator and slip rings, rotating diodes, exciter	
and end bell-bearing	
Inspect transfer switch and mainline circuit breaker	
Run generator set (under load) and check voltage,	
frequency, and instrument systems. Adjust carburator	
governor, and voltage regulator if necessary	
□ Generate test and inspection report	