



City of Bristol
BRISTOL, CONNECTICUT 06010

Invitation to Bid 2C15-057
Replacement of Fire Alarm Systems at South Side Elementary School
Addendum 01
January 20, 2015

The due date for bids is hereby extended to **January 26, 2015 at 2:00 pm**.

Q1 Will the fire alarm device count be revised? If so when will we receive them?

A1 The base bid shall assume the number of devices shown in Attachment 01. In the event of discrepancy between counts shown and actual required devices required, bidders are requested to provide unit costs per device, which will be used to adjust to either greater or lesser quantity installed.

A revised bid page 004200-3 is included with this addendum, for the purpose of providing such unit prices.

Q2 The battery cabinet now located in the basement area should be relocated next to the panel. Please let ESC know if this will be added to the scope of work.

A2 Relocation of the battery cabinet is not required as part of this scope of work, unless determined to be necessary for compliance with building code.

Q3 Please verify that the existing height of the Horn strobe units will remain as currently installed.

A3 The awarded contractor shall replace devices in-kind to avoid rewiring or having to extend wiring. Devices shall remain at height currently installed.

Q4 Please consider approval of Edwards EST 3X fire alarm system as equal to the FCI 7100 and E3 fire alarm system.

A4 The Edwards system identified above is considered an approved equal.

All other terms and conditions remain unchanged.

Roger D. Rousseau
Purchasing Agent
Tel (860) 584-6195
Fax (860) 584-6171

Attachments: Revised Bid Page 004200-3 (1 page)
Acknowledgement form (1 page)

**BID PROPOSAL
2C15-057**

In accordance with the attached specifications entitled "**Contract 2C15-057 Replacement of Fire Alarm Systems at South Side Elementary School**"; the undersigned agrees to perform construction as follows costs:

Replacement of Fire Alarm System and Devices at South Side School,
in accordance with the specifications set forth herein,
At the lump sum price of \$_____

The **TOTAL AMOUNT** of this Bid, based upon the estimated quantities listed above for as computed by the Bidder is:

_____ DOLLARS and

_____ CENTS. \$_____

Alternate Unit pricing

Alt 1	Manual alarm box	Ea	_____
Alt 2	Smoke detector	Ea	_____
Alt 3	Heat detector	Ea	_____
Alt 4	Duct detector	Ea	_____
Alt 5	Horn/audible signal	Ea	_____
Alt 6	Strobe/visual signal	Ea	_____

RETURN THIS FORM IMMEDIATELY!

City of Bristol, Connecticut
Acknowledgment: Receipt of Bid Documents

Bid Number: **2C15-057**

Title: **Fire Alarm System at South Side School
Addendum 01**

Please take a moment to acknowledge receipt of the attached documents. Your compliance with this request will help us to maintain proper follow-up procedures while ensuring that all recipients have the opportunity to submit proposals.

Date Addendum 01 was issued January 20, 2015

Date Addendum 01 was received ____/____/____

Do you plan to submit a proposal? Yes ____ No ____

Print or type the following information:

Company name: _____

Address: _____

City or Town: _____

Phone: _____

Fax: _____

Email: _____

Received by: _____

Note: Faxed acknowledgments are requested!

FAX (860)584-6171

A cover sheet is NOT necessary.

IMPORTANT: DO NOT FAX PROPOSALS.

PROPOSALS MUST BE SUBMITTED IN SEALED PACKAGES