



RENTAL HOUSING INSPECTION PROGRAM **General Inspection Checklist**

(916) 808-7368

CASE #: _____

PROPERTY ADDRESS:	PROPERTY NAME (IF APPLICABLE)	DATE	NO. OF UNITS
-------------------	-------------------------------	------	--------------

Check the box next to each item or area that is inspected and found to be in compliance:

UNIT	☐ 1. Premises – no abandoned or inoperable vehicles, overgrown vegetation, infestation of insects or vermin, discarded household items, trash, debris or any graffiti.	☐ 8. Common Areas - in a safe and sanitary condition.	☐ 15. Water heaters – water heaters are installed in an approved location, and have seismic strapping, operable temperature relief valve & drain line, venting, and a minimum 120 degrees water temperature.
	☐ 2. Exterior walls – in good condition, no peeling paint, holes, missing sections or deterioration.	☐ 9. Entry doors – all doors and door jambs have strike plates that are secure, not loose; entry doors have a standard deadbolt with thumb latch at interior, a viewer, and are weather sealed.	☐ 16. Bathroom ventilation – bathrooms have operable window or exhaust fan.
	☐ 3. Vent screens - no missing or damaged crawl space, attic or foundation vent screens.	☐ 10. Windows and window locks – windows can be opened and closed easily, and have no missing or broken glazing. Bedroom egress windows are not blocked by furniture or air conditioners, and any security bars can be released from the interior.	☐ 17. Smoke detectors – smoke detectors are working, and are located in hallways leading to rooms used for sleeping purposes or are installed and maintained in compliance with the Code in effect at the time of their original installation.
	☐ 4. Stairway/landing/treads/risers/guardrails/handrails – in good condition, well secured, not loose or deteriorated.	☐ 11. Heaters – are permanently installed and properly functioning.	☐ 18. Electrical -general outlets, lights, switches and cover plates are installed properly and in good condition, no exposed wiring.
	☐ 5. Roof and ceilings – in good condition without any leaks.	☐ 12. Kitchen counters and sink surfaces – surfaces are in good condition, no significant cracked, chipped or missing pieces.	☐ 19. GFCI required locations – GFCI properly function and have been installed where outlets have been replaced in the bathrooms, on kitchen counters, on the exterior and in garages.
	☐ 6. Exterior lighting – all lights function and have proper covers, no exposed wiring.	☐ 13. Floor coverings - coverings do not create tripping hazards or unsanitary conditions.	☐ 20. Carbon Monoxide detectors –located outside each sleeping area & on each level of a dwelling (including basements). Installation must be per manufacturer's instructions and per California Building Code.
	☐ 7. Electrical panel – all electrical panels are identified, all breakers/fuses are labeled and there is no exposed wiring.	☐ 14. Plumbing fixtures/piping – properly installed and in good condition without any leaks or clogs, no missing handles or spouts.	

No change in any portion of a building, structure, common area or any other work regulated by Code shall be required when such work was installed and is maintained in accordance with the Code in effect at the time of installation. A completed Rental Housing Inspection Checklist does not certify that any work done to the building or structure was in compliance with any permit or approval requirements.

I certify that I have inspected the aforementioned unit and that the information above is true and correct to the best of my knowledge.

Name of Inspector: _____ Date: _____

Please correct the following violation/s prior to next 30-day progress inspection scheduled for: _____

Between the hours of 12:30pm to 3:00pm

☐ Building Permit(s) Required if Checked* Permit Valuation \$ _____

☐ _____ ☐ I have received a Self-Certification Packet (if applicable):
 (Signature of Owner or Local Contract Representative) Date

I, the undersigned, have lawful access or control of the rental housing unit described above. I freely and voluntarily give my consent to have the inspectors of the City of Sacramento's Rental Housing Inspection Program enter and inspect the unit.

Name: _____ Telephone: _____
 Signature: _____ Date: _____ ☐ Inspection conducted in the absence of occupant, with written consent.

*If a building permit is required, please visit the Public Counter at 300 Richards Blvd., 3rd Floor between 9am & 4pm. Bring a copy of your checklist.

White- Office
 Yellow- Owner or Local Contact
 Pink- Tenant