## **Architect's Supplemental Instructions**

**ASI NUMBER:** 

025




4119 & 4123 12th Avenue

Seattle, WA

PROJECT NUMBER:

1343



Owner

Field

Architect

Consultant Contractor

OWNER: Chris Johnson

> **CA Student Living** 161 N. Clark, Suite 4900 Chicago, Illinois 60601

TO CONTRACTOR:

Robert Beeler

Pavilion Construction

6720 SW Macadam Ave., Suite #310

Portland, OR 97219

FROM

**NK Architects** 

THE ARCHITECTS:

310 First Avenue S, Suite 4S

Seattle, WA 98104

The Work shall be carried out in accordance with the following supplemental instructions in accordance with the Contract Documents without change in Contract Sum or Contract Time. Proceeding with the Work in accordance with these instructions indicates your acknowledgement that there will be no change in the Contract Sum of Contract time.

## **DESCRIPTION:**

Provide Pacific Polymers 5000TC system traffic coating at Trash Room (over transformer room and access well) as follows:

- (3) Base coats 25 mil ElastoDeck 5001
- (I) Top coat 15 mil Elastodeck 6001 AL

With Aluminum Oxide aggregate and with primer and crack sealer per manufacturer.

Apply the coating up the wall 4'-0" or more if necessary to protect wall from the dumpsters.

ATTACHMENTS:	
ISSUED BY THE ARCHITECTS:	ACCEPTED BY CONTRACTOR:
(Signature & Date) Fill in Name	(Signature & Date) Fill in Name