

Recommendation: Adopt NFPA 70E as a Best Practice

Background:

When discussing NFPA 70E with personnel at industrial facilities, one of the first questions organizations ask is: **"Does OSHA require compliance to this standard?"** In answering this question, one must first consider some background information associated with existing OSHA standards and this particular standard.

Following the Occupational Health and Safety Act of 1970, OSHA adopted the 1968, and then the 1971, edition of NFPA 70, National Electric Code, under Section 6(a) of the Act. Later changes or additions to the OSHA requirements would require performing the process outlined in Section 6(b) of the Act, which requires a public notice, or an opportunity for public comment and public hearings. This is an expensive and lengthy process at best. Unfortunately, OSHA found that the NEC was lacking in many aspects of electrical safety. The NEC primarily deals with the design and construction of electrical installations. However, OSHA's responsibilities include the employers and employees in the workplace, and the NEC does not address the requirements for electrical safety-related work practices associated with the operation and maintenance of electrical systems. Realizing this disconnect, the National Fire Protection Association (NFPA) offered its assistance in preparing a document "to assist OSHA in preparing electrical safety standards that would serve OSHA's needs and that could be expeditiously promulgated through the provisions of Section 6(b) of the Occupational Safety and Health Act." The resulting Standard for Electrical Safety Requirements for Employee Workplaces, NFPA 70E, was first issued in 1979 with the specific purpose of being a companion document to the NEC.

Subsequent to the initial versions of NFPA 70E, the OSHA standard 29CFR1910.269, commonly referred to as Subpart R - Electrical Power Generation, Transmission, and Distribution was issued. In general, this OSHA standard addresses the electrical shock hazard and electrical arc flash hazards. This standard delineates requirements for qualified persons, which include being familiar with the standard, as well as being trained and familiar with the work being performed. Unfortunately, it does not specifically define what the "appropriate" electrical protective equipment is for an arc flash hazard. However, this requirement does imply that the magnitude of the electrical hazard should be known and that the protective equipment should be selected, accordingly.

In an effort to further define the requirements for electrical safety, the fifth edition of NFPA 70E was published in 1995. This standard introduced both the concept of "limits of approach" and the establishment of a "flash protection boundary". In the sixth edition,



published in 2000, further focus on flash protection and the use of personal protective equipment (PPE) was expanded with charts being added to assist the user in applying PPE for common tasks. The seventh edition, published in 2004, was rearranged to be consistent with the *NEC* and was renamed *Standard for Electrical Safety in the Workplace*. The eighth edition was published in 2012. The majority of changes have occurred in Chapter 1. With the exception of the major revisions in Article 320, *Safety Requirements Related to Batteries and Battery Rooms,* the revisions in Chapters 2 and 3 are primarily for clarification and editorial purposes. Annexes D, F, H, J, and O have substantive revisions. Annex P aligns *NFPA 70E* with occupational health and safety management standards.

Another Industry standard, ANSI/IEEE C2 - National Electric Safety Code (NESC), further amplifies these requirements in its 2007 edition. It states that: "Effective as of January 1, 2009, the employer shall ensure that an assessment is performed to determine potential exposure to an electric arc for employees who work on or near energized parts or equipment. If the assessment determines a potential employee exposure greater than 2cal/cm² exists (see Neal, Bingham, and Doughty [B59]), the employer shall require employees to wear clothing or a clothing system that has an effective arc rating not less than the anticipated level of arc energy."

What should be derived from the above discussion is that NFPA 70E is considered an industrial consensus standard and is intended for use by employers, employees, and OSHA. OSHA has not "adopted" NFPA 70E simply because adoption would require the lengthy and expensive process outlined in Section 6(b) of the Act. OSHA has instead referenced compliance to NFPA 70E using Section 5(a)(1) of the Occupational Safety and Health Act of 1970, commonly referred to as the "general duty clause," as their basis for implementation. The general duty clause states that employers "shall furnish to each of its employees employment and a place of employment which are free from recognized hazards that are causing or likely to cause death or serious physical harm to his employees."

This methodology for "implementing" potentially new requirements through the use of industrial consensus standards, like NFPA 70E, is a common practice by OSHA. In a recent standard interpretation letter dated 7/25/03, OSHA's Russell Swanson stated: "Industry consensus standards, such as NFPA 70E, can be used by employers as guides to making the assessments and equipment selections required by the standard. Similarly, in OSHA enforcement actions, they can be used as evidence of whether the employer acted reasonably."

It is clear from the above evidence that OSHA is using NFPA 70E as an industrial consensus standard. Further, OSHA expects employers and employees to comply with the provisions of NFPA 70E regardless of whether or not it has been "adopted" as an OSHA requirement.



"How will NFPA 70E compliance affect an organization?"

NFPA 70E - 2004 and the *NESC* - 2007 require and/or recommend that facilities provide:

- A safety program with defined responsibilities.
- Electrical hazards analyses.
- Personal protective equipment (PPE) for workers.
- Training for workers.
- Tools for safe work.

NFPA 70E further requires that, when working on or near exposed energized circuits, "safety-related work practices shall be used to safeguard employees from injury while they are working on or near exposed electric conductors or circuit parts that are or can become energized. The specific safety-related work practice shall be consistent with the nature and extent of the associated electric hazards." These work practices shall include wearing protective clothing and other personal protective equipment (PPE) when working with the flash protection boundary.

With regard to arc flash hazards, a "flash hazard analysis shall be done in order to protect personnel from the possibility of being injured by an arc flash. The flash hazard analysis shall determine the Flash Protection Boundary and the personal protective equipment that people within the Flash Protection Boundary shall use." This standard also provides some descriptions associated with working distances, or boundaries, with respect to being a qualified versus unqualified person. These boundaries are as follows:

• Flash Protection Boundary - The distance at which the incident energy from the live part is equal to 1.2 cal/cm², which is the limit for a second-degree burn on bare skin. Persons must not cross this boundary unless they are wearing appropriate personal protective clothing and are under close the supervision of a qualified person.

• **Limited Approach** - The distance at which barriers should be placed to protect unqualified personnel from an electrical hazard. Only qualified persons and escorted unqualified persons are allowed to enter a limited space.

• **Restricted Approach** - The distance at which only qualified personnel are allowed with appropriate protective clothing and personal protective equipment for the associated hazard. No unauthorized conductive material and no unqualified persons are permitted to cross a restricted boundary. Further, a documented and approved plan is required to enter a restricted space.

To : ALL STANDARDS BOARD MEMBERS

From : Occupational Safety and Health Standards Board

Conrad E. Tolson, Senior Engineer - Standards

Subject : High-Voltage Electrical Safety Orders

The following information is provided in regard to the proposed revisions to the California Code of Regulations, Title 8, Division 1, Chapter 4, Subchapter 5, Electrical Safety Orders, Group 2, High-Voltage Electrical Safety Orders.

INFORMATIVE DIGEST OF PROPOSED ACTION/POLICY STATEMENT OVERVIEW

The Occupational Safety and Health Standards Board (Board) intends to adopt the proposed rulemaking action pursuant to Labor Code Section 142.3, which mandates the Board to adopt standards at least as effective as federal standards addressing occupational safety and health issues.

On February 14, 2007, the U.S. Department of Labor, Occupational Safety and Health Administration (Federal OSHA) promulgated standards revising the general industry electrical installation standards found in Subpart S of 29 Code of Federal Regulations (CFR) Part 1910. The Board is relying on the explanation of the provisions of the federal standards in Federal Register, Volume 72, No. 30, pages 7136-7221, February 14, 2007, as the justification for the Board's proposed rulemaking action. The Board proposes to adopt standards which are the same as the federal standards except for minor editorial and format differences, or where existing state standards provide a higher level of safety. Furthermore, obsolete cross-references to California Code of Regulations, Title 24 are also proposed for deletion under provisions of the California Code of Regulations, Title 1, Section 100. Prior to September 30, 2002, the Standards Board was mandated by Health and Safety Code Section 18943(b) to submit Title 8 building standards to the California Building Standards Commission for their approval and adoption into Title 24, the California Building Code.

Assembly Bill 3000 (Stats. 2002, c. 1124), which was signed by the Governor and filed with the Secretary of State on September 30, 2002, formally exempted the Standards Board from the building standard requirements contained in the Health and Safety Code as well as those contained in Labor Code Sections 142.3 and 142.6. Consequently, all previous references to Title 24 have been deleted.

In the final rule, Federal OSHA has revised its existing general industry electrical installation standards contained in Sections 1910.302-1910.308 along with relevant definitions found in Section 1910.399. Federal OSHA's existing electrical standards are based on the 1979 edition of NFPA 70E, Standard for Electrical Safety Requirements for Employee Workplaces. The final

Board Memorandum High-Voltage Electrical Safety Orders Public Hearing December 18, 2008 Page 2 of 4

> federal rule is based primarily on Part I of the 2000 edition of NFPA 70E which, in turn, is based on the 1999 National Electrical Code (NEC). Thus the proposal will reflect more current practice and technology as well as respond to requests from stakeholders that Subpart S reflect the most recent editions of NFPA 70E which the industry is already voluntarily complying with in its present form. Federal OSHA is of the opinion that the revised standard will facilitate compliance by stakeholders, including small businesses, while also improving safety for employees.

Subjects addressed by the proposal include, but are not limited to, the following:

- Definitions of terms used in the HVESO
- Approval of installations and equipment
- Examination, installation and use of equipment
- Marking and identification
- Overcurrent protection
- Grounding
- Wiring methods
- Temporary wiring
- Enclosures for electrical installations
- Interrupting and isolating devices
- Transformers
- Control of motors and generators
- Workspace and guarding
- Communications systems
- Induction and dielectric heating equipment
- Integrated electrical systems

The proposed standards are substantially the same as the final rule promulgated by federal OSHA. Labor Code Section 142.3(a)(3) exempts the Board from the provisions of Article 5 (commencing with Section 11346) and Article 6 (commencing with Section 11349) of Chapter 3.5, Part 1, Division 3 of Title 2 of the Government Code when adopting standards substantially the same as federal standards. However, the Board is still providing a comment period and will convene a public hearing. The primary purpose of the written and oral comments at the public hearing is to:

- (1) Identify any issues unique to California related to this proposal which should be addressed in a subsequent rulemaking; and
- (2) Solicit comments on the proposed effective date.

The responses to comments will be available in the rulemaking file on this matter and will be limited to the above areas.

The effective date is proposed to be upon filing with the Secretary of State as provided by Labor Code Section 142.3(a)(3). The standards may be adopted without further notice even though modifications may be made to the original proposal in response to public comments or at the Board's discretion.

DOCUMENTS RELIED UPON

Federal Register, Vol. 72, No. 30, pp. 7136-7221 (February 14, 2007)

This document is available online at the federal OSHA website, <u>www.osha.gov</u> and is also available for review Monday through Friday from 8:00 a.m. to 4:30 p.m. at the Standards Board Office located at 2520 Venture Oaks Way, Suite 350, Sacramento, California.

DOCUMENTS INCORPORATED BY REFERENCE

29 CFR 1910.7, Definition and requirements for a nationally recognized testing laboratory.

This document is available for review Monday through Friday from 8:00 a.m. to 4:30 p.m. at the Standards Board Office located at 2520 Venture Oaks Way, Suite 350, Sacramento, California.

STRIKEOUT/UNDERLINE DRAFT PROPOSAL

See Attachment No. 1.

SIDE-BY-SIDE CODE COMPARISON WITH FEDERAL STANDARD

See Attachment No. 2.

COST ESTIMATES OF PROPOSED ACTION

OSHA's estimation of compliance costs found in Federal Register, Vol. 72, No. 30, February 14, 2007, Preamble Section VI, Final Economic and Regulatory Screening Analysis, subsection D, Estimation of Compliance Costs, notes that there is already within the industry widespread use of the 1999 (or later) edition of the National Electrical Code (NEC) upon which the federal promulgation was based. Since this rulemaking proposal merely incorporates the federal standards where necessary to make California's High-Voltage Electrical Safety Orders at least as effective, Board staff therefore relies on OSHA's estimate of compliance costs in making a determination that this rulemaking of High-Voltage Electrical Safety Orders will have no appreciable cost impact on the regulated public.

DETERMINATION OF MANDATE

The Occupational Safety and Health Standards Board has determined that the proposed standards not impose a local mandate. Therefore, reimbursement by the state is not required pursuant to Part 7 (commencing with Section 17500) of Division 4 of the Government Code because the proposed amendments will not require local agencies or school districts to incur additional costs in complying with the proposal. Furthermore, these standards do not constitute a "new program or higher level of service of an existing program within the meaning of Section 6 of Article XIII B of the California Constitution."

Board Memorandum High-Voltage Electrical Safety Orders Public Hearing December 18, 2008 Page 4 of 4

The California Supreme Court has established that a "program" within the meaning of Section 6 of Article XIII B of the California Constitution is one which carries out the governmental function of providing services to the public, or which, to implement a state policy, imposes unique requirements on local governments and does not apply generally to all residents and entities in the state. (County of Los Angeles v. State of California (1987) 43 Cal.3d 46.)

These proposed standards do not require local agencies to carry out the governmental function of providing services to the public. Rather, the standards require local agencies to take certain steps to ensure the safety and health of their own employees only. Moreover, these proposed standards do not in any way require local agencies to administer the California Occupational Safety and Health program. (See <u>City of Anaheim v. State of California</u> (1987) 189 Cal.App.3d 1478.)

These proposed standards do not impose unique requirements on local governments. All state, local and private employers will be required to comply with the prescribed standards.

EFFECT ON SMALL BUSINESSES

The Board has determined that the proposed amendments may affect small businesses. However, no significant economic impact is anticipated.

ASSESSMENT

The adoption of the proposed amendments to these standards will neither create nor eliminate jobs in the State of California nor result in the elimination of existing businesses or create or expand businesses in the State of California.

OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD 2520 Venture Oaks Way, Suite 350 Sacramento, CA 95833 (916) 274-5721 FAX (916) 274-5743 www.dir.ca.gov/oshsb

Attachment No. 3

INITIAL STATEMENT OF REASONS

CALIFORNIA CODE OF REGULATIONS

TITLE 8, Division 1, Chapter 4, Subchapter 5, Group 1, Low-Voltage Electrical Safety Orders. Articles and Sections as follows:

Article	Section	
2. Administration.	2305.2	Application.
4. Requirements for Electrical	2340.12	Mechanical Execution of Work
Installations.		
	2340.16	Work Space About Electric Equipment.
6. Branch Circuits.	2360.3	Ground-Fault Circuit Interrupter
		Protection for Personnel – General
		Industry.
13. Temporary Wiring.	2405.4	Ground-Fault Circuit Protection-
		Construction Site.
45. Cabinets, Boxes, and Fittings.	2473.1	Conductors Entering Boxes, Cabinets,
		or Fittings.
58. Capacitors.	2534.8	Disconnecting Means.

Low-Voltage Electrical Safety Orders - Addendum

SUMMARY

The Occupational Safety and Health Standards Board (Board), recently updated Title 8 Low-Voltage Electrical Safety Orders (LVESO) for equivalency with updates to 29 CFR Part 1910, Subpart S. That rulemaking action was pursuant to Labor Code Section 142.3, which mandates the Board to adopt standards at least as effective as federal standards addressing occupational safety and health issues. That rulemaking process followed the authority listed in Labor Code Section 142.3(a)(3), sometimes referred to as a "Horcher" rulemaking; thus it was limited only to changes covered by the counterpart federal standard. However, during the course of that rulemaking, other items, outside the scope of the "Horcher" process, were noted to be ambiguous, obsolete, overlapping, conflicting, and/or unnecessary. The purpose of this rulemaking proposal is to address those items.

SPECIFIC PURPOSE AND FACTUAL BASIS OF PROPOSED ACTION

Section 2305.2. Application.

Subsection (b), Extent of Application, specifies effective dates for different parts of the LVESO. Subsequent to the adoption of the LVESO update, Board staff became aware that the effective date for Section 2395.6, Portable and Vehicle-Mounted Generators, was unclear. Accordingly, Section 2305.2(b) is being amended to clearly indicate that, consistent with federal standards, amendments to Section 2395.6 became effective on May 5, 2008, the same time the general update became effective. The purpose and necessity for this amendment is to simplify compliance and enforcement by clearly establishing the effective date for changes made for portable and vehicle-mounted generators.

Section 2340.12. Mechanical Execution of Work.

Subsection 2340.12 requires that electric equipment be installed in a neat and workmanlike manner. Subsection (a) provides, in relevant part, that unused openings in boxes, raceways, auxiliary gutters, cabinets, equipment cases, or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment.

Similar requirements are found in Section 2473.1(b), which is proposed for deletion as being duplicative and overlapping with other sections of the Safety Orders, including Section 2340.12(a). One subject of the proposed deletion of subsection 2473.1(b), however, that is not covered elsewhere is the matter of unused openings in fittings. It is therefore proposed to add "fittings" to 2340.12(a) in order to maintain that requirement in the Electrical Safety Orders. The purpose and necessity for these revisions is to assure that unused openings in fittings are effectively closed to protect employees from hazardous electrical exposures.

Section 2340.16. Work Space About Electric Equipment.

Subsection (b), Work Space, prescribes the work space to be provided for examination, adjustment, servicing, or maintenance of energized equipment. Subsection (b)(2)(A) specifies that concrete, brick or tile walls shall be considered as grounded when determining width for clear work space requirements. A stakeholder requested clarification to the effect that any concrete, brick or tile surface be considered as grounded when determining any clear work space requirement (i.e., depth, width, height). This would be equivalent to National Fire Protection Association (NFPA) 70E-2004, Table 400.15(A)(1), Condition #2, and 2005 National Electrical Code (NEC) Table 110.26(A)(1), Condition #2. Thus it is proposed to relocate "concrete, brick, or tile" from subsection (b)(2) to Table 2340.16, Condition #2, so that it will apply to all clearances, and not just to width. The purpose and necessity for this proposed relocation is to conform Section 2340.16 of the LVESO to industry standard NFPA 70E-2004, and the 2005 Edition of the NEC.

<u>Section 2360.3.</u> Ground-Fault Circuit Interrupter Protection for Personnel - General Industry. Section 2360.3 prescribes when ground-fault circuit interrupter (GFCI) protection is required during maintenance, remodeling, or repair of buildings, structures, or equipment "or during similar *construction-like* activities" [italicized for emphasis]. Existing Section 2405.4, Ground-Fault Circuit Protection-Construction Site, which was outside the scope of the Horcher Low-Voltage Electrical Safety Orders – Addendum Initial Statement of Reasons Public Hearing November 19, 2009 Page 3 of 6

rulemaking, contains similar, but not identical, grounding requirements for construction sites. The ambiguity of the term "construction-like" in Section 2360.3 causes it to overlap with Section 2405.4, and because of different grounding requirements for general industry versus construction, it creates confusion as to application. It is therefore proposed that the term "construction-like" be deleted from Section 2360.3(b). The purpose and necessity for this change is to clarify application of electrical standards for general industry and construction.

Section 2405.4. Ground-Fault Circuit Protection – Construction Site. Subsection (a) General. An advisory opinion from Federal OSHA, Region 9, on the Low-Voltage Electrical Safety Orders update¹ noted that Subsection 2405.4(a) describes a construction site as "a place of employment where erection, demolition, *modification*, alteration or excavation is being performed on a building, structure or underground facility, other than mining (emphasis added)." Region 9 opines that inclusion of the term "modification" in this definition excludes GFCI protection from activities intended to be covered by general industry standards in 29 CFR 1910, Subpart S. Section 2405.4 is the state counterpart to federal 29 CFR 1926.404(b)(1) which contains ground fault protection requirements for construction. The ground fault protection requirements of 29 CFR 1926, Subpart K, do not require GFCI in all cases where they are required by 29 CFR 1910, Subpart S, because of difficulties in implementing GFCI in construction settings. Thus Region 9 was concerned that the provisions of Section 2405.4 might be applied in certain instances of remodeling and modification of existing buildings, and that these provisions would not be as effective as federal standards for general industry.

Board staff therefore proposes to delete the term "modification" from Section 2405.4(a). The purpose and necessity for this deletion is to clarify the distinction between grounding requirements for general industry (Section 2360.3) and construction (Section 2405.4).

<u>Section 2405.4.</u> Ground-Fault Circuit Protection – Construction Site. Subsection (b) Construction Sites, Exception.

This subsection requires that employees on construction sites be protected by either or both ground-fault circuit interrupters as specified in Subsection 2405.4(c) or by an assured equipment grounding conductor program as specified in Subsection 2405.4(d) or by both. An exception to this subsection exempts from these requirements individual cord sets, supplied from any receptacle on a 15- or 20- ampere branch circuit which is part of the permanent wiring of building or structure. This exception is not supported by 29 CFR 1926.404(b)(1) or the NEC, and is less protective than the counterpart federal standard. The exception is therefore proposed for deletion. The purpose and necessity for this deletion is to provide safety at least as effective as the counterpart federal standard and the NEC.

<u>Section 2405.4.</u> Ground-Fault Circuit Protection – Construction Site. Subsection (d) Assured Equipment Grounding Conductor Program.

This subsection requires the employer to establish and implement an assured equipment grounding conductor program on construction sites covering all 120-volt, AC, single-phase, cord sets, receptacles which are not a part of the permanent wiring of the building or structure and equipment connected by cord and plug, which are used by employees. Modifications are

¹ Letter to OSHSB from US Dept. of Labor, OSHA Region 9, dated July 14, 2008.

Low-Voltage Electrical Safety Orders – Addendum Initial Statement of Reasons Public Hearing November 19, 2009 Page 4 of 6

proposed to (1) delete "120-volt, AC, single-phase" and (2) amend "used by employees" to read "available for use or used by employees." The purpose and necessity for these modifications is to provide protection equivalent to 29 CFR 1926.404(b)(1)(iii).

Section 2405.4. Ground-Fault Circuit Protection – Construction Site. Note to Subsection (d) Assured Equipment Grounding Conductor Program.

A note below subsection (d)(4) provides that double-insulated tools or other similar equipment need not be grounded, and cross references to Section 2395.45(d)(5). This cross-reference is incorrect, and it is proposed to be corrected to Section 2395.45, Exception 2 which requires double-insulated equipment to be distinctively marked. The purpose and necessity for this amendment is to clarify the use of double-insulated tools and utilization equipment.

Section 2473.1. Conductors Entering Boxes, Cabinets, or Fittings.

This section prescribes protection and securing for conductors entering cutout boxes, cabinets, or fittings. Subsection (b) provides that unused openings in cabinets, boxes, and fittings shall be effectively closed. Subsection (b) is duplicative of Sections 2340.12(a) and 2473.2(a); therefore it is proposed for deletion. The purpose and necessity for this deletion is to clarify requirements by eliminating overlapping and duplication.

Section 2534.8. Disconnecting Means.

This section prescribes disconnecting means for capacitors. As presently worded, it does not require the disconnecting means to open all ungrounded conductors simultaneously. This is contrary to NFPA 70-2005 (NEC) Section 460.8(C)(1), thus it is proposed to amend this section to be consistent with the NEC. It is also proposed to reformat the remainder of the section to be consistent with the verbiage of NEC 460.8(C). The purpose and necessity of these modifications will be to conform capacitor disconnecting means to those prescribed by the 2005 edition of the NEC.

DOCUMENTS RELIED UPON

NFPA 70, National Electrical Code (NEC), 2005 Edition, published by National Fire Protection Association, Inc. (NFPA), One Batterymarch Park, Boston, MA 02169; Table 110.26(A)(1), Condition #2 and Section 460.8(C).

NFPA 70E, Standard for Electrical Safety in the Workplace, 2004 Edition, published by National Fire Protection Association, Inc. (NFPA), One Batterymarch Park, Boston, MA 02169; Table 400.15(A)(1), Condition #2.

Federal Register, Vol. 72, No. 30, Wednesday, February 14, 2007, U.S. Department of Labor, OSHA, 29 CFR Part 1910, Electrical Standard (Final Rule), pages 7136-7221.

Letter to OSHSB from US Dept. of Labor, OSHA Region 9, dated July 14, 2008.

Facsimile to OSHSB from U.S. Dept. of Labor, OSHA Phoenix Resource Center, dated April 2, 2009.

Low-Voltage Electrical Safety Orders – Addendum Initial Statement of Reasons Public Hearing November 19, 2009 Page 5 of 6

These documents are available for review Monday through Friday from 8:00 a.m. to 4:30 p.m. at the Standards Board Office located at 2520 Venture Oaks Way, Suite 350, Sacramento, California.

REASONABLE ALTERNATIVES THAT WOULD LESSEN ADVERSE ECONOMIC IMPACT ON SMALL BUSINESSES

No reasonable alternatives were identified by the Board and no reasonable alternatives identified by the Board or otherwise brought to its attention would lessen the impact on small businesses.

SPECIFIC TECHNOLOGY OR EQUIPMENT

This proposal will not mandate the use of specific technologies or equipment.

COST ESTIMATES OF PROPOSED ACTION

Costs or Savings to State Agencies

No costs or savings to state agencies will result as a consequence of the proposed action.

Impact on Housing Costs

The Board has made an initial determination that this proposal will not significantly affect housing costs.

Impact on Businesses

The Board has made a determination that this proposal will not result in a significant, statewide adverse economic impact directly affecting businesses, including the ability of California businesses to compete with businesses in other states.

Cost Impact on Private Persons or Businesses

The Board is not aware of any cost impacts that a representative private person or business would necessarily incur in reasonable compliance with the proposed action.

<u>Costs or Savings in Federal Funding to the State</u> The proposal will not result in costs or savings in federal funding to the state.

<u>Costs or Savings to Local Agencies or School Districts Required to be Reimbursed</u> No costs to local agencies or school districts are required to be reimbursed. See explanation under "Determination of Mandate."

<u>Other Nondiscretionary Costs or Savings Imposed on Local Agencies</u> This proposal does not impose nondiscretionary costs or savings on local agencies. Low-Voltage Electrical Safety Orders – Addendum Initial Statement of Reasons Public Hearing November 19, 2009 Page 6 of 6

DETERMINATION OF MANDATE

The Occupational Safety and Health Standards Board has determined that the proposed standards do not impose a local mandate. Therefore, reimbursement by the state is not required pursuant to Part 7 (commencing with Section 17500) of Division 4 of the Government Code because the proposed amendments will not require local agencies or school districts to incur additional costs in complying with the proposal. Furthermore, these standards do not constitute a "new program or higher level of service of an existing program within the meaning of Section 6 of Article XIII B of the California Constitution."

The California Supreme Court has established that a "program" within the meaning of Section 6 of Article XIII B of the California Constitution is one which carries out the governmental function of providing services to the public, or which, to implement a state policy, imposes unique requirements on local governments and does not apply generally to all residents and entities in the state. (County of Los Angeles v. State of California (1987) 43 Cal.3d 46.)

These proposed standards do not require local agencies to carry out the governmental function of providing services to the public. Rather, the standards require local agencies to take certain steps to ensure the safety and health of their own employees only. Moreover, these standards do not in any way require local agencies to administer the California Occupational Safety and Health program. (See <u>City of Anaheim v. State of California</u> (1987) 189 Cal.App.3d 1478.)

These proposed standards do not impose unique requirements on local governments. All state, local and private employers will be required to comply with the prescribed standards.

EFFECT ON SMALL BUSINESSES

The Board has determined that the proposed amendments may affect small businesses. However, no economic impact is anticipated.

ASSESSMENT

The adoption of the proposed amendments to these standards will neither create nor eliminate jobs in the State of California nor result in the elimination of existing businesses or create or expand businesses in the State of California.

ALTERNATIVES THAT WOULD AFFECT PRIVATE PERSONS

No reasonable alternatives have been identified by the Board or have otherwise been identified and brought to its attention that would be more effective in carrying out the purpose for which the action is proposed or would be as effective and less burdensome to affected private persons than the proposed action.

	NITED S	TATES	ABOR							SEARCH
							A to Z Ind	ex En español (Contact Us FAQs	About OSHA
OSHA			OSHA Quio	kTakes Ne	ewsletter	RSS Feeds	🖶 Print This Page	📕 🛨 Text Size		
Occupatio	nal Safe	y & Health	Administra	tion	We Car	n Help			What's New	Offices
Home	Workers	Regulations	Enforcement	Data & S	tatistics	Training	Publications	Newsroom	Small Business	O SHA
Standard Inte	erpretations - 1	able of Contents								
• Standard Nu	umber:		<u>1910.5; 1910.</u> <u>1910.333; 191</u> 1910.335(a)(1	5(c)(1); 191(0.333(a)(1); (iv); 1910.3	<u>D.5(f); 191(</u> <u>1910.333(</u> 35(a)(1)(v)	0.132; <u>1910.1</u> / b)(2); <u>1910.3(</u> ; <u>1910.335(a)</u>	45; <u>1910.303; 1</u> 35; <u>1910.335(b)</u> (2)(i); 1910.335	<u>910.303(e);</u> ; <u>1910.335(b)(1);</u> (<u>a)(2)(ii)</u>		
	This letter not be ap	r constitutes OS plicable to any	GHA's interpret situation not d	ation only o elineated w	of the requ vithin the	uirements dia original corre	scussed and m espondence.	ay		
November 14, 2	2006									
Ms. Joanne B. Li ORC Worldwide 1910 Sunderland Washington, DC	inhard d Place, NW 20036									
Dear Ms. Linhard	d:									
Thank you for yo for an interpreta <i>Electrical Safety</i>	our e-mail to ation regardin <i>in the Workp</i>	the Occupational g OSHA's require blace. Your questi	Safety and Heal ments and the N ons have been re	h Administra ational Fire F estated below	ation's (OSH Protection A v for clarity	HA's) Directora Issociation's (N . We apologize	ate of Enforceme NFPA) 70E-2004, e for the delay in	nt Programs (DEP) <i>Standard for</i> our response.		
Question 1: Wi does OSHA required by NFP	hen work mu uire the marki PA 70E-2004?	st be performed ng of the electric <u>1</u>	on energized elected equipment to w	tric equipme arn qualified	ent that is c persons of	apable of expo potential elec	osing employees tric arc-flash haz	to arc-flash hazarc ards — i.e., as	ls,	
Reply : OSHA ha included in the 1 descriptive mark information, alor themselves from	as no specific 1981 Subpart kings, includir ng with the t n arc-flash ha	requirement for S revision. Howe og the equipment aining requireme zards.	such marking. A ver, paragraph ('s voltage, currer nts for qualified	requirement e) of §1910.3 t, wattage, c persons, will	to mark eq 303 require or other rat provide em	uipment with s employers to ings as necess iployees the n	flash hazard war o mark electrical sary. OSHA belie ecessary informa	nings was not equipment with ves that this ttion to protect		
Additionally, in § . to warn and pr Although these arc-flash hazard about electrical	§1910.335(b) <i>rotect employ</i> Subpart S ele Is, §1910.335 hazards (e.g.	, OSHA requires e rees from hazards ctrical provisions (b)(1) requires th , electric-arc-flas	employers to use s which could cau do not specifical e use of safety s n hazards) which	alerting tech se injury due y require tha igns, safety s may endang	nniques (sat e to electric at electric e symbols, or ger them as	fety signs and c shock, burns equipment be r accident prev s required by §	tags, barricades or failure of electron marked to warn of vention tags to w §1910.145.	, and attendants) . ctric equipment par qualified persons o varn employees	ts. f	
Question 2: Is	s flame-resist	ant clothing requ	ired for employee	s working or	n electrical	installations co	overed by Subpa	rt S?		
Reply : OSHA's time include spe have included su comparable prov therefore, does	present requ ecific provision uch body proi visions specifi not include a	irements in Subp ns for flame-resis ection provisions cally related to th specific requirem	art S, <i>Safety-Rel</i> tant (FR) clothing , OSHA has not c ne use of FR cloth ent for the use o	ated Work Pr [protective onducted rul ning to prote f FR clothing	ractices, are equipment] lemaking pl ct against a	e based on NF]. Although m roceedings to arc-flash hazar	PA 70E-1983, wh ore recent versio update Subpart rds. OSHA's exist	nich did not at that ons of NFPA 70E S by adopting ing Subpart S,		
However, arc-fla arc-flash burn ha generally require equipment safe reduces the likel the equipment is	ash hazards a azard preven e deenergizat by completel lihood of arc- s shut down	re addressed in t tion, the general ion of live parts t y deenergizing it flash burn injury and when the qua	he OSHA electric provisions for the before an employ by means of lock by reducing emp alified employee	al safety-rela Selection and ee works on out and tagg loyee exposu verifies, by u	ated work p nd use of w or near the ging proced ure to elect se of a test	practices stand work practices em — i.e., em ures. This sing rical hazards - t instrument, a	ards. For examp contained in §19 ployees must firs gle safe work pra – i.e., exposure a deenergized sta	le, with respect to 10.333(a)(1) at render electric actice significantly is limited to when ate.		
When employee contact with exp likelihood of emp	es perform wo bosed energiz ployee injury	rk on energized o ed parts must be caused by an arc	circuits, as permit insulated in acco blast.	ted by §1910 ordance with	0.333(a)(1) §1910.335	, tools and ha 5(a)(2)(i). This	ndling equipmen work practice al	t that might make so reduces the		
Arc-flash hazard Equipment (PPE from flying object use of protective injuries while that \$1910.335(a)(2) blast, and arc-fla	Is are also ad for the eyes cts resulting f e shields, bar at employee)(ii) safeguard ash burn haz	dressed in §1910 s and face be wor rom an electrical riers, or insulating is working <i>wh</i> d selected — shie ards associated w	.335(a)(1)(v), Sa rn whenever ther explosion. In ac gequipment "to p here dangerous a ld, barrier, or inse rith the incident of	feguards for e is danger o dition, parag protect each <i>lectric heatir</i> , llating mater energy expos	personnel , of injury to graph (a)(2) employee f ag or arcing rial — must sure for the	protection, wh the eyes or fa)(ii) of §1910.3 rom shocks, b g might occur" fully protect e specific task t	ich requires that ce from electric a 335 requires, in j urns, or other el (emphasis adde employees from el to be performed.	personal protective arcs or flashes or pertinent part, the ectrically related d). The electric shock, the However, in	e	

situations where a fully protective safeguard could be used as an alternative, OSHA will, under its policy for *de minimis* violations, allow employers to use, instead, safeguards that are not fully protective, provided that the employer implement additional measures.² The supplemental measures, which could include the use of arc-rated FR clothing appropriate to the specific task, **must fully protect** the employee from all residual hazardous energy (e.g., the resultant thermal effects³ from the electric arc) that passes the initial safeguard.

Where there is no \$1910.335(a)(2)(ii) safeguard that would fully protect against the hazards, an employer is still obligated under the Occupational Safety and Health Act of 1970 to take reasonable steps that will protect the employee to the degree possible.⁴ As noted in the previous paragraph, the protection provided by a safeguard that is not fully effective can be augmented through use of other safety measures such as FR clothing and other appropriate PPE.

OSHA recommends that employers consult consensus standards such as NFPA 70E-2004 to identify safety measures that can be used to comply with or supplement the requirements of OSHA's standards for preventing or protecting against arc-flash hazards. For example, Section 130.3 of the NFPA standard establishes its own mandatory provisions for flash-hazard-analysis⁵, which sets forth the criteria to define a flash-protection boundary and the personal protective equipment for use by employees within the flash-protection boundary. The goal of this provision is to reduce the possibility of being injured by an arc-flash. The analysis is task specific and determines the worker's incident-energy exposure (in calories per square centimeter). Where it has been determined that work will be performed within the flash-protection boundary, NFPA 70E specifies that flame-resistant clothing and PPE use either be based on the pre-determined incident-energy exposure data or be in accordance with the *Hazard/Risk Category Classifications* and *Protective Clothing and Personal Protective equipment (PPE) Matrix* tables contained in Sections 130.7(C)(9) and (C)(10), respectively.

Other NFPA 70E, Article 130 provisions, such as the justification for work through the use of an energized electrical work authorization permit, and the completion of a job briefing with employees before they start each job, additionally decrease the likelihood that exposure to electrical hazards would occur.

Question 3: How is OSHA enforcing §1910.132 and Subpart S with regard to the latest edition of NFPA 70E requirements?

Reply: As noted above, OSHA has not conducted a rulemaking to adopt the requirements of the latest edition of NFPA 70E and, therefore, does not "enforce" those requirements. However, industry consensus standards, such as NFPA 70E, can be used by OSHA and employers as guides in making hazard analyses and selecting control measures.

With regards to enforcing §1910.132 and the Subpart S standards, the PPE requirements contained in Subpart S would prevail over the general requirements contained in §1910.132 where both standards would apply to the same condition, practice, control method, etc. See §1910.5(c)(1).

Question 4: Does OSHA issue Section 5(a)(1) General Duty Clause violations to companies who do not follow the new NFPA 70E requirements?

Reply: A violation of the General Duty Clause, Section 5(a)(1) of the Act, exists if an employer has failed to furnish a workplace that is free from recognized hazards causing or likely to cause death or serious physical injury. The General Duty Clause is not used to enforce the provisions of consensus standards, although such standards are sometimes used as evidence of hazard recognition and the availability of feasible means of abatement. In addition, the General Duty Clause usually should not be used if there is a standard that applies to the particular condition, practice, means, operation, or process involved. See §1910.5(f).

Thank you for your interest in occupational safety and health. We hope you find this information helpful. OSHA requirements are set by statute, standards, and regulations. Our interpretation letters explain these requirements and how they apply to particular circumstances, but they cannot create additional employer obligations. This letter constitutes OSHA's interpretation of the requirements discussed. Note that our enforcement guidance may be affected by changes to OSHA rules. In addition, from time to time we update our guidance in response to new information. To keep apprised of such developments, you can consult OSHA's website at http://www.osha.gov. If you have any further questions, please feel free to contact the Office of General Industry Enforcement at (202) 693-1850.

Sincerely,

Edwin G. Foulke, Jr.

¹ Section 400.11 of NFPA 70E-2004 states: Switchboards, panelboards, industrial control panels, and motor control centers that are in other than dwelling occupancies and are likely to require examination, adjustment, servicing, or maintenance while energized shall be field marked to warn qualified persons of potential electric arc flash hazards. The marking shall be located so as to be clearly visible to qualified persons before examination, adjustment, servicing, or maintenance of the equipment. [back to text]

² OSHA has not formally compared each provision of the NFPA 70E-2004 standard with the parallel provision in Subpart S but generally believes that the NFPA standard offers useful guidance for employers and employees attempting to control electrical hazards. The Agency notes, however, that the face and head protection requirements contained in the Section 130.7(c)(10) Table do not require face and head area protection for Hazard Risk Category 1, even when serious face and head injury from the thermal effects of the arc could result. Therefore, this particular NFPA provision may not provide equivalent or greater employee protection with respect to the corresponding OSHA standards on eye, face, and head protection — i.e., \$1910.335(a)(1)(v) and 1910.335(a)(1)(v). In addition, the Individual Qualified Employee Control Procedure conditionally permits certain work activities to be performed without the placement of lockout/tagout devices on the disconnecting means. See Section 130.7(D)(1). This work practice provides less employee protection than that afforded by compliance with the OSHA lockout and tagging requirements contained in \$1910.333(b)(2) and is, therefore, not acceptable. [back to text]

 3 When an employee is working within the flash-protection boundary, Section 130.7 of the NFPA 70E-2004 standard requires the employee to wear protective clothing wherever there is possible exposure to an electric arc flash above the threshold incident-energy level for a second-degree burn, 5 J/cm² (1.2) cal/cm². In other words, the protective clothing system is designed to protect the employee from receiving second- or third-degree burns to his or her body. The typical characteristics, degree of protection, and required

minimum arc ratings for typical protective clothing systems may be found in Table 130.7(c)(11). The NFPA standard requires the protective clothing selected for the corresponding hazard/risk category number to have an arc rating of at least the minimum value listed. [back to text]

⁴ To establish all of the elements of the affirmative defense of impossibility, an employer who can show that compliance with the terms of a standard is impossible under the circumstances must also show that it used alternative measures to protect employees, or that there were no such control measures. [back to text]

⁵ This flash hazard analysis information represents recognized good engineering practice and can be useful guidance for both OSHA personnel and employers applying the provisions contained in the electrical safety-related work practice standards contained in 29 CFR §§1910.331 through 1910.335. [back to text]

👍 Standard Interpretations - Table of Contents

Freedom of Information Act | Privacy & Security Statement | Disclaimers | Customer Survey | Important Web Ste Notices | International | Contact Us

U.S. Department of Labor | Occupational Safety & Health Administration | 200 Constitution Ave., NW, Washington, DC 20210 Telephone: 800-321-OSHA (6742) | TTY: 877-889-5627

www.OSHA.gov



Section 5(a)(1) of the Occupational Safety and Health Act requires an employer to furnish to its employees:

employment and a place of employment which are free from recognized hazards that are causing or are likely to cause death or serious physical harm to his employees

However, as stated in the multi-employer compliance directive,

only exposing employers can be cited for General Duty Clause violations.

Therefore, citations based on a failure to meet a General Duty Clause requirement can only be issued to an "exposing" employer - an employer whose own employees were exposed to the hazard. So, for example, an employer cannot be cited in its role as a "controlling employer" for exposure of subcontractor employees to a General Duty Clause violation.

Industry Consensus Standard NFPA 70E

With respect to the General Duty Clause, industry consensus standards may be evidence that a hazard is "recognized" and that there is a feasible means of correcting such a hazard. However, as explained above, NFPA 70E is not relevant to assessing a controlling employer's duties under OSHA's multi-employer policy, since controlling employers are not responsible for overseeing their subcontractors' compliance with General Duty Clause responsibilities.²

A controlling employer engaged in construction work does have obligations regarding 29 CFR part 1926 subpart K (Electrical) under the multi-employer policy.³

Question (2): I note that OSHA has not incorporated the personal protective equipment portions of NFPA 70E by reference in §1910.132 (personal protective equipment, general requirements) or §1910.335 (safeguards for personal protection). Does an employer have an obligation under the General Duty Clause to ensure that its own employees comply with personal protective equipment requirements in NFPA 70E?

Answer

[Please refer to November 14, 2006 letter to Ms. Joanne B. Linhard.]

This document was amended on 2/7/2011 to strike information that no longer reflects current OSHA policy.

These provisions are written in general terms, requiring, for example, that personal protective equipment be provided "where necessary by reason of hazards..." (§1910.132(a)), and requiring the employer to select equipment "that will protect the affected employee from the hazards..." (§1910.132(d)(1)). Also, §1910.132(c) requires the equipment to "be of safe design and construction for the work performed."-

Similarly, \$1910.335 contains requirements such as the provision and use of "electrical protective equipment that is appropriate for the specific parts of the body to be protected and the work to be performed (\$1910.335(a)(i)).

Industry consensus standards, such as NFPA 70E, can be used by employers as guides to making the assessments and equipment selections required by the standard. Similarly, in OSHA enforcement actions, they can be used as evidence of whether the employer acted reasonably.

Under §1910.135, the employer must ensure that affected employees wear a protective helmet that meets either the applicable ANSI Z89.1 standard or a helmet that the employer demonstrates "to be equally effective." If an employer demonstrated that NFPA 70E contains criteria for protective helmets regarding protection against falling objects and electrical shock that is equal to or more stringent than the applicable ANSI Z89.1 standard, and a helmet met the NFPA 70E criteria, the employer could use that to demonstrate that the helmet is "equally effective."

Question (3)(a): Can an employer be cited for violating an OSHA requirement for personal fall protection (PPE) where a properly trained employee decides not to wear the PPE?

Answer

Employee misconduct is an "affirmative defense" $\frac{4}{2}$ to a failure to meet the requirements of an OSHA requirement. To establish the defense, the employer must be able to show that: (a) the violative condition was unknown to the employer, (b) the employer had a method of detecting violations and an effective enforcement policy when violations are discovered, and (c) the employee's action was in violation of an adequate employer work rule which was effectively communicated and uniformly enforced.

Therefore, if the employer can show that it did not know (and reasonably could not have known) that the employee was not wearing the PPE, that it had an adequate work rule requiring the employee to wear the PPE, and that the work rule was effectively communicated and uniformly enforced, the employer would not be responsible under OSHA requirements for the violation.

Question (3)(b): Would the employer be liable in a private lawsuit in that situation?

Answer

It is not within the purview of this office to provide guidance regarding tort, workers' compensation or other private action legal liability.

Question (4): Are there OSHA standards that state that an owner of a work facility must identify and mark electrical hazards for contractors?

Answer

OSHA requirements apply to employers; generally they do not apply to owners with no employees. Owners that also are employers are subject to OSHA requirements depending on the activities performed.

There are no OSHA standards that specifically require owners to post notice of electrical hazards for contractors performing construction work at the owners' facilities.⁵ However it is worth noting that both OSHA general industry and construction standards require the durable and legible marking of disconnecting means and circuits.

Section 29 CFR 1910.303(f) requires that:

...Each service, feeder, and branch circuit, at its disconnecting means or overcurrent device, shall be legibly marked to indicate its purpose, unless located and arranged so the purpose is evident. These markings shall be of sufficient durability to withstand the environment involved.

Section 29 CFR 1926.403(h) contains an identical provision.

Question (5): How can I distinguish between electrical work that is considered "construction work" and electrical work that is considered "general industry work"?

Answer

29 CFR 1910.12 sets out the scope of OSHA construction standards. Section 1910.12(a) provides that:

The standards prescribed in part 1926 of this chapter ... shall apply ... to every employment and place of employment of every employee engaged in construction work.

Section 1920.12(b) defines construction work as follows:

Construction work means work for construction, alteration, and/or repair, including painting and decorating.

Section 1910.12(d) adds that:

'construction work' includes the erection of new electric transmission and distribution lines and equipment, and the alteration, conversion, and improvement of the existing transmission and distribution lines and equipment.

In our <u>February 1, 1999, letter to Mr. Randall A. Tindell</u>, we discussed in detail, and gave specific examples of, the distinction between general industry and construction work.

If the work falls within OSHA's jurisdiction and is considered construction work, then 29 CFR part 1926 subparts K (Electrical) or V (Power Transmission and Distribution) might apply. However, since you have not specified the type of "electrical work" involved, we cannot advise you on whether one of these standards would apply in your situation.

If you need any additional information, please contact us by fax at: U.S. Department of Labor, OSHA, Directorate of Construction, Office of Construction Standards and Guidance, fax # 202-693-1689. You can also contact us by mail at the above office, Room N3468, 200 Constitution Avenue, N.W., Washington, D.C. 20210, although there will be a delay in our receiving correspondence by mail.

Sincerely,

Russell B. Swanson, Director Directorate of Construction

¹ The policy can be viewed on OSHA's website at: <u>http://www.osha.gov/OshDoc/Directive_pdf/CPL_2-0_124.pdf</u>* . [Return to Text]

² However, if a controlling employer's own employees were exposed to a hazard, it would also be in the role of an exposing employer, and would have General Duty Clause obligations with respect to its own employees. [Return to Text]

³ Note that in §1926.402(a) there is the following statement:

If the electrical installation is made in accordance with the National Electrical Code ANSI/NFPA 70-1984 . . . it will be deemed to be in compliance with §§1926.403 through 1926.408, except for §§1926.404(b)(1) and 1926.405(a)(2)(ii)(E), (F), (G) and (J). [Return to Text]

⁴ An affirmative defense is a defense which, if established by the employer, will excuse the employer from a violation. [Return to Text]

⁵ Note, though, that §1926.21 (b)(2) requires the employer to "Instruct each employee in the recognition and avoidance of unsafe conditions" [Return to Text]

* File provided for download only.

Accessibility Assistance: Contact the OSHA Directorate of Enforcement Programs at (240) 364-6015 for assistance accessing PDF materials.

👍 <u>Standard Interpretations - Table of Contents</u>

Freedom of Information Act | Privacy & Security Statement | Disclaimers | Customer Survey | Important Web Site Notices | International | Contact Us

U.S. Department of Labor | Occupational Safety & Health Administration | 200 Constitution Ave., NW, Washington, DC 20210 Telephone: 800-321-OSHA (6742) | TTY: 877-889-5627

```
www.OSHA.gov
```



NFPA 72: National Fire Alarm Code, 2007 Edition

Item#: **7207** List: **\$85.50** Member: **\$76.95** Format: Book

Choose Format

YOU MIGHT ALSO LIKE



NFPA 70E: Standard for Electrical Safety in the Workplace and Handbook Set, 2012 Edition Item#: 70ESET12 List: \$192.00 Set: **\$158.75** Member: **\$142.88**

🖽 ADD



NFPA 70E: Safety Requirements for Electricians DVD -2009 Edition Item#: VC106DVD List: \$507.75 Member: \$456.98 Format: DVD

🖽 ADD

Home Contact Privacy Policy Terms of Use Help © National Fire Protection Association 2013 facebook 💱 🕬 🐻 Linked 🛅 . Ewitter flickr 🚳

										SEARCH
			ADOK				A to Z Inde	x En español	Contact Us FAQs	About OSHA ge-helpful?
OSHA			OSHA Quic	kTakes Newsletter	RSS Feeds	🔒 Pri	int This Page	🗖 🛨 Text Size		
Occupatio	nal Safet	y & Health	Administra	tion We C	an Help				What's New	Offices
Home	Workers	Regulations	Enforcement	Data & Statistics	Training	PL	ublications	Newsroom	Small Business	O SHA
<u>Standard Inte</u>	erpretations - 1	able of Contents								
• Standard Nu	ımber:		<u>1910.5; 1910.5</u> <u>1910.333; 191</u> 1910.335(a)(1)	5(c)(1); 1910.5(f); 1 0.333(a)(1); 1910.3 (iv); 1910.335(a)(1	1910.132; 1910. 33(b)(2); 1910.)(v); 1910.335(a	<u>145; 1</u> 335; 1 a)(2)(i)	<u>910.303;</u> <u>19</u> 910.335(b); ; <u>1910.335(</u> ;	110.303(e); 1910.335(b)(1); a)(2)(ii)		
	This letter not be ap	r constitutes OS plicable to any	GHA's interpreta situation not de	ation only of the r elineated within t	equirements c he original cor	liscuss respo	sed and ma ndence.	iy		
November 14, 2	2006									
Ms. Joanne B. Li ORC Worldwide 1910 Sunderland Washington, DC	inhard d Place, NW 20036									
Dear Ms. Linhar	d:									
Thank you for yo for an interpreta <i>Electrical Safety</i>	our e-mail to ation regardin <i>in the Workp</i>	the Occupational g OSHA's require blace. Your questi	I Safety and Healt ments and the Na ons have been re	h Administration's (ational Fire Protectic stated below for cla	OSHA's) Directo on Association's rity. We apologi	rate of (NFPA) ze for t	Enforcemen 70E-2004, the delay in	t Programs (DEP) <i>Standard for</i> our response.		
Question 1: Wi does OSHA required by NFP	hen work mu uire the marki A 70E-2004?	st be performed on ng of the electric 1	on energized elec equipment to wa	tric equipment that arn qualified persons	is capable of ex s of potential ele	posing ectric a	employees t rc-flash haza	o arc-flash hazaro ards — i.e., as	ds,	
Reply : OSHA has included in the descriptive mark information, alou themselves from	as no specific 1981 Subpart kings, includir ng with the ti n arc-flash ha	requirement for S revision. Howe g the equipment aining requireme zards.	such marking. A ever, paragraph (e 's voltage, curren ents for qualified p	requirement to marl e) of §1910.303 req t, wattage, or other persons, will provide	equipment with uires employers ratings as nece employees the	n flash to mar ssary. (necess	hazard warn k electrical e OSHA believ sary informat	nings was not equipment with es that this ion to protect		
Additionally, in § . to warn and p Although these arc-flash hazard about electrical	§1910.335(b) <i>rotect employ</i> Subpart S ele Is, §1910.335 hazards (e.g.	, OSHA requires e rees from hazards ctrical provisions (b)(1) requires th , electric-arc-flash	employers to use s which could cau do not specifical he use of safety s h hazards) which	alerting techniques se injury due to ele y require that electri gns, safety symbols may endanger then	(safety signs an <i>ctric shock, burr</i> ic equipment be a, or accident pro n as required by	d tags, <i>as or fa</i> marke eventio §1910	, barricades, <i>ailure of elec</i> a ed to warn q on tags to wa).145.	and attendants) . tric equipment par ualified persons o arn employees	rts. f	
Question 2: 1	s flame-resist	ant clothing requi	ired for employee	s working on electri	cal installations	covere	d by Subpar	t S?		
Reply : OSHA's time include spe have included su comparable prov therefore, does	present reque ecific provision uch body prot visions specifi not include a	irements in Subp ns for flame-resis ection provisions cally related to th specific requirem	art S, <i>Safety-Rela</i> tant (FR) clothing , OSHA has not c ne use of FR cloth tent for the use o	ated Work Practices, [protective equipm onducted rulemakin ing to protect agair f FR clothing.	are based on N ent]. Although g proceedings to ist arc-flash haz	IFPA 70 more r o upda ards. C	DE-1983, whi ecent version te Subpart S DSHA's existin	ich did not at that ns of NFPA 70E 6 by adopting ng Subpart S,		
However, arc-fla arc-flash burn h generally require equipment safe reduces the likel the equipment is	ash hazards a azard preven e deenergizat by completely lihood of arc- s shut down a	re addressed in t tion, the general ion of live parts t y deenergizing it l flash burn injury and when the qua	he OSHA electric provisions for the before an employ by means of lock by reducing emp alified employee	al safety-related wo Selection and use ee works on or neal but and tagging pro loyee exposure to e verifies, by use of a	rk practices stan of work practice. r them — i.e., er cedures. This sin lectrical hazards test instrument,	idards. s conta mploye ngle sa — i.e. a deer	For example ained in §191 es must first ife work prace , exposure is nergized stat	e, with respect to 0.333(a)(1) render electric stice significantly s limited to when re.		
When employee contact with exp likelihood of em	es perform wo posed energiz ployee injury	rk on energized o ed parts must be caused by an arc	circuits, as permit insulated in acco blast.	ted by §1910.333(a ordance with §1910.)(1), tools and h 335(a)(2)(i). Th	nandling is work	g equipment practice als	that might make o reduces the		
Arc-flash hazard Equipment (PPE from flying objective use of protective injuries while the \$1910.335(a)(2) blast, and arc-fl	Is are also ad for the eyes cts resulting f e shields, bar at employee ((ii) safeguard ash burn haz	dressed in §1910 s and face be wor rom an electrical riers, or insulating is working <i>wh</i> d selected — shiel ards associated w	.335(a)(1)(v), Sa rn whenever ther explosion. In ad g equipment "to p here dangerous e ld, barrier, or insu ith the incident e	feguards for persona e is danger of injury dition, paragraph (a protect each employ lectric heating or ar ilating material — m mergy exposure for	nel protection, w to the eyes or f a)(2)(ii) of §1910 ee from shocks, cing might occur nust fully protect the specific task	which re ace fro 0.335 re burns, " (emp emplo to be	equires that om electric a equires, in p or other ele bhasis added byees from el performed.	personal protectiv rcs or flashes or ertinent part, the ectrically related). The lectric shock, the However, in	e	

22

situations where a fully protective safeguard could be used as an alternative, OSHA will, under its policy for *de minimis* violations, allow employers to use, instead, safeguards that are not fully protective, provided that the employer implement additional measures.² The supplemental measures, which could include the use of arc-rated FR clothing appropriate to the specific task, **must fully protect** the employee from all residual hazardous energy (e.g., the resultant thermal effects³ from the electric arc) that passes the initial safeguard.

Where there is no \$1910.335(a)(2)(ii) safeguard that would fully protect against the hazards, an employer is still obligated under the Occupational Safety and Health Act of 1970 to take reasonable steps that will protect the employee to the degree possible.⁴ As noted in the previous paragraph, the protection provided by a safeguard that is not fully effective can be augmented through use of other safety measures such as FR clothing and other appropriate PPE.

OSHA recommends that employers consult consensus standards such as NFPA 70E-2004 to identify safety measures that can be used to comply with or supplement the requirements of OSHA's standards for preventing or protecting against arc-flash hazards. For example, Section 130.3 of the NFPA standard establishes its own mandatory provisions for flash-hazard-analysis⁵, which sets forth the criteria to define a flash-protection boundary and the personal protective equipment for use by employees within the flash-protection boundary. The goal of this provision is to reduce the possibility of being injured by an arc-flash. The analysis is task specific and determines the worker's incident-energy exposure (in calories per square centimeter). Where it has been determined that work will be performed within the flash-protection boundary, NFPA 70E specifies that flame-resistant clothing and PPE use either be based on the pre-determined incident-energy exposure data or be in accordance with the *Hazard/Risk Category Classifications* and *Protective Clothing and Personal Protective equipment (PPE) Matrix* tables contained in Sections 130.7(C)(9) and (C)(10), respectively.

Other NFPA 70E, Article 130 provisions, such as the justification for work through the use of an energized electrical work authorization permit, and the completion of a job briefing with employees before they start each job, additionally decrease the likelihood that exposure to electrical hazards would occur.

Question 3: How is OSHA enforcing §1910.132 and Subpart S with regard to the latest edition of NFPA 70E requirements?

Reply: As noted above, OSHA has not conducted a rulemaking to adopt the requirements of the latest edition of NFPA 70E and, therefore, does not "enforce" those requirements. However, industry consensus standards, such as NFPA 70E, can be used by OSHA and employers as guides in making hazard analyses and selecting control measures.

With regards to enforcing §1910.132 and the Subpart S standards, the PPE requirements contained in Subpart S would prevail over the general requirements contained in §1910.132 where both standards would apply to the same condition, practice, control method, etc. See §1910.5(c)(1).

Question 4: Does OSHA issue Section 5(a)(1) General Duty Clause violations to companies who do not follow the new NFPA 70E requirements?

Reply: A violation of the General Duty Clause, Section 5(a)(1) of the Act, exists if an employer has failed to furnish a workplace that is free from recognized hazards causing or likely to cause death or serious physical injury. The General Duty Clause is not used to enforce the provisions of consensus standards, although such standards are sometimes used as evidence of hazard recognition and the availability of feasible means of abatement. In addition, the General Duty Clause usually should not be used if there is a standard that applies to the particular condition, practice, means, operation, or process involved. See §1910.5(f).

Thank you for your interest in occupational safety and health. We hope you find this information helpful. OSHA requirements are set by statute, standards, and regulations. Our interpretation letters explain these requirements and how they apply to particular circumstances, but they cannot create additional employer obligations. This letter constitutes OSHA's interpretation of the requirements discussed. Note that our enforcement guidance may be affected by changes to OSHA rules. In addition, from time to time we update our guidance in response to new information. To keep apprised of such developments, you can consult OSHA's website at http://www.osha.gov. If you have any further questions, please feel free to contact the Office of General Industry Enforcement at (202) 693-1850.

Sincerely,

Edwin G. Foulke, Jr.

¹ Section 400.11 of NFPA 70E-2004 states: Switchboards, panelboards, industrial control panels, and motor control centers that are in other than dwelling occupancies and are likely to require examination, adjustment, servicing, or maintenance while energized shall be field marked to warn qualified persons of potential electric arc flash hazards. The marking shall be located so as to be clearly visible to qualified persons before examination, adjustment, servicing, or maintenance of the equipment. [back to text]

² OSHA has not formally compared each provision of the NFPA 70E-2004 standard with the parallel provision in Subpart S but generally believes that the NFPA standard offers useful guidance for employers and employees attempting to control electrical hazards. The Agency notes, however, that the face and head protection requirements contained in the Section 130.7(c)(10) Table do not require face and head area protection for Hazard Risk Category 1, even when serious face and head injury from the thermal effects of the arc could result. Therefore, this particular NFPA provision may not provide equivalent or greater employee protection with respect to the corresponding OSHA standards on eye, face, and head protection — i.e., \$1910.335(a)(1)(v) and 1910.335(a)(1)(v). In addition, the Individual Qualified Employee Control Procedure conditionally permits certain work activities to be performed without the placement of lockout/tagout devices on the disconnecting means. See Section 130.7(D)(1). This work practice provides less employee protection than that afforded by compliance with the OSHA lockout and tagging requirements contained in \$1910.333(b)(2) and is, therefore, not acceptable. [back to text]

 3 When an employee is working within the flash-protection boundary, Section 130.7 of the NFPA 70E-2004 standard requires the employee to wear protective clothing wherever there is possible exposure to an electric arc flash above the threshold incident-energy level for a second-degree burn, 5 J/cm² (1.2) cal/cm². In other words, the protective clothing system is designed to protect the employee from receiving second- or third-degree burns to his or her body. The typical characteristics, degree of protection, and required

minimum arc ratings for typical protective clothing systems may be found in Table 130.7(c)(11). The NFPA standard requires the protective clothing selected for the corresponding hazard/risk category number to have an arc rating of at least the minimum value listed. [back to text]

⁴ To establish all of the elements of the affirmative defense of impossibility, an employer who can show that compliance with the terms of a standard is impossible under the circumstances must also show that it used alternative measures to protect employees, or that there were no such control measures. [back to text]

⁵ This flash hazard analysis information represents recognized good engineering practice and can be useful guidance for both OSHA personnel and employers applying the provisions contained in the electrical safety-related work practice standards contained in 29 CFR §§1910.331 through 1910.335. [back to text]

👍 Standard Interpretations - Table of Contents

Freedom of Information Act | Privacy & Security Statement | Disclaimers | Customer Survey | Important Web Ste Notices | International | Contact Us

U.S. Department of Labor | Occupational Safety & Health Administration | 200 Constitution Ave., NW, Washington, DC 20210 Telephone: 800-321-OSHA (6742) | TTY: 877-889-5627

www.OSHA.gov



• **Prohibited Approach** - The distance at which qualified personnel should not introduce grounded equipment or material not insulated for the voltage rating due to the possibility of flashover. A documented and approved risk analysis plan is required to enter a prohibited space.

To accommodate the work practices stated above for many common tasks, NFPA 70E Table 130.7(C)(9)(a), has been provided for use. However, specific fault currents and fault clearing times were assumed in the preparation of those tables. The assumed short circuit current capacities and fault clearing times are listed in the notes of the table. If the fault currents or fault clearing times are different than those used in generating the recommendations in the table, the incident energy can be very different. These tables are suitable for their intended use, providing an immediate answer, but are not a substitute for performing a more detailed arc flash hazard analysis specific to the facility. Analyses that take into consideration the true operating conditions of a specific facility can be performed using the methods outlined in either NFPA 70E or IEEE Standard 1584-2002. The IEEE 1584-2002 guidelines have been derived as a result of extensive testing and, therefore, are typically considered to be more accurate. Use of either methodology should be considered acceptable.

With regard to determining appropriate work practices and PPE, the magnitude of the potential arc flash hazard is first determined based on the work being performed, the exposure to the employee, and the potential incident energy of an arc flash. The appropriate PPE is then selected with guidance provided in the PPE Matrix, NFPA 70E Table 130.7(C)(10). Further guidance on protective clothing characteristics is provided in NFPA 70E Table 130.7(C)(11).

With regard to what a utility should already be doing to minimize the exposure of employees to energized circuits, OSHA 1910.269 has provided requirements on working on energized lines and equipment, deenergizing lines and equipment, PPE, grounding, and guarding.

Summary:

OSHA expects employers and employees to comply with the provisions of NFPA 70E regardless of whether or not it has been "adopted" as an OSHA requirement. NFPA 70E compliance involves putting an electrical safety program in place, identifying and analyzing electrical hazards in the workplace, educating the workforce on those hazards, requiring the use of appropriate PPE, and using warning labels and guards to protect workers.