



**LAHORE ELECTRIC SUPPLY COMPANY  
ELECTRICITY DEMAND FORECAST  
BASED ON  
POWER MARKET SURVEY**

TWENTY FOURTH ISSUE

**PERIOD 2014 TO 2024**

**JOINTLY PREPARED BY LESCO  
UNDER THE SUPERVISION OF  
PLANNING POWER, NTDC  
MAY 2015**





## Executive Summary

### Executive Summary

Lahore Electric Supply Company (LESCO) is the largest electric power distribution company and is supplying power to civil districts of Lahore, Kasur, Okara, Nankana and Sheikhupura. This company came into existence in the year 2001 after unbundling of WAPDA system, earlier it was known as Lahore Area Electricity Board (AEB) and its distribution network comprised of sixty-eight 132 kV and fourteen 66 kV sub-stations and at present in the year 2013-14 there are one thirty four 132kV and seven 66kV sub-stations.

Peak demand of LESCO in the year 2013-14 was 2911 MW, energy sale was 15948 GWh and energy purchased was 18425 GWh. The shares of domestic sector and industrial sector were 42% and 43 % respectively with respect to total energy sale. The total number of consumers in 2013-14 was 3.71 million out of which 3.05 million were domestic, 0.52 million were commercial and 0.057 million were agricultural. In the year 2013-14 total sale of LESCO in terms of megawatts was 2522 MW, for the domestic sector it was 1211 MW, for medium & large industries it was 1425 MW and for small industries it was 108 MW.

This forecast has been computed on the basis of Power Market Survey (PMS) methodology by the LESCO (PMS) team under the supervision of planning power, (NTDCL). The year 2013-14 has been taken as base year and the forecast horizon is ten years up to 2023-24. The base year sale data (feeder wise consumer category-wise energy sale) and the expected spot loads data at the locations of different sub-stations have been collected by LESCO power market survey team. Data for the base year has also been adjusted for the estimates of un-served energy (load shedding) in order to have realistic figures.

Forecast results show that in the years 2018-19 and 2023-24 energy sale will be 24373 GWh and 30974 GWh, peak demand will be 6479 MW and 7788 MW, and energy purchased will be 34285 GWh and 416166 GWh respectively. For the period 2013-24 to 2023-24, annual average compound growth rate of energy sale, peak demand and energy purchased will be 6.86%, 5.43% and 5.70% respectively.

A realistic forecast, saves over investment as well as under investment, meaning thereby timely recovery of revenue and no constraints in the supply of power (load shedding) respectively. This kind of forecast can only be prepared by applying proper methodology with authentic data. The results of previous PMS forecasts were very close to the actual which proves the authenticity of methodology and data. This report highlights the salient features of load forecast of the company.

Planning Power, NTDCL firmly believes that the readers' comments/suggestions on this report will help in improving energy and demand forecast in future.



# Table of Contents

## Table of Contents

<b>1</b>	<b>Introduction .....</b>	<b>1</b>
<b>2</b>	<b>Historical Supply And Demand Analysis .....</b>	<b>3</b>
2.1	Category-wise Sale.....	3
2.2	Transmission and Distribution Losses.....	4
2.3	Recorded and Computed Peak Demand.....	5
2.4	Number of Consumers .....	5
<b>3</b>	<b>Power Market Survey Methodology .....</b>	<b>6</b>
3.1	Overview .....	6
3.2	Survey Base Data.....	6
3.3	Input Parameters .....	7
3.4	Growth Rates .....	7
3.5	Losses .....	8
3.6	Load Factors.....	8
3.7	Coincidence Factors .....	9
3.8	Forecast Calculations .....	9
3.9	Energy Calculations.....	9
3.10	Peak Demand Calculations.....	10
3.11	Accumulations.....	10
<b>4</b>	<b>PMS Forecast Results.....</b>	<b>11</b>
4.1	Recorded Forecast (Excluding Load Shedding) .....	11
4.2	Computed Forecast (Including Load Shedding) .....	11
4.3	Category-wise Forecasted Energy Sale (GWh).....	12
4.4	Category wise Forecasted Energy Sale (MW) .....	13
4.5	Peak Demand of Substations .....	13
4.6	Per Capita Consumption .....	13
4.7	Category-wise Substation-wise Energy and Demand Projections .....	14
4.8	Civil Administrative Area Forecast .....	14
4.9	Monthly Demand (MW) Projections.....	14
4.10	List of Overloaded Substations .....	14
4.11	List of Grids with their Codes and MVA Capacities.....	14
<b>Disclaimer .....</b>	<b>63</b>	



## List of Figures

### List of Figures

Figure 1- 1: Computed Demand Forecast .....	1
Figure 1- 2: <b>Historical Category-wise Sale</b> .....	3
Figure 1- 3: Historical Transmission and Distribution Losses.....	4
Figure 1- 4: Historical Recorded and Computed Peak Demand .....	5
Figure 1- 5: Number of Consumers .....	5
Figure 1- 6: Computed Peak Demand.....	11
Figure 1- 7: Energy Purchased VS Energy Sale .....	11
Figure 1- 8: Forecasted Category Wise Sale.....	12
Figure 1- 9: Per Capita Consumption .....	13
<b>Figure 1- 10:</b> Distribution Network Map .....	59
Figure 1- 11: Distribution Network Map (Lahore Ring) .....	61



## List of Tables

### List of Tables

Table 1-1: PMS Recorded Forecast (Excluding Load Shedding).....	15
Table 1-2: PMS Base Forecast.....	16
Table 1-3: Category Wise Sale – GWh (Excluding Load Shedding) .....	17
Table 1-4: Category-wise Sale – GWh (Base Forecast) .....	18
Table 1-5: Category-wise Demand – MW (Excluding Load Shedding).....	19
Table 1-6: Category-wise Demand – MW (Base Forecast).....	20
Table 1-7: District-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For District: Kasur.....	21
Table 1-8: District-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For District: Lahore .....	22
Table 1-9: District-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For District: Nankana .....	23
Table 1-10: District-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For District: Okara.....	24
Table 1-11: District-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For District: Sheikhupura .....	25
Table 1-12: Division-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For Division: Lahore. ....	26
Table 1-13: Monthly Peak Demand Forecast .....	27
Table 1-14: List of Overloaded Substations during Period 2012-13 to 2022-23      Overloading Criterion= 85% .....	28
Table 1-15: List of Overloaded Substations during Period 2012-13 to 2022-2      Overloading Criterion=100% .....	31
Table 1-16: List of Grids with their Codes and MVA Capacities.....	34




## 1 Introduction

The present report of Power Market Survey forecast is the 24<sup>th</sup> issue, jointly prepared by LESCO and Planning Power NTDCL. This report contains year wise detailed forecast of energy and demand for the whole company and each sub-station within the company. In addition to that civil administrative area forecast like divisions and districts within the company are also computed and depicted in different tables. The forecasted peak demand of LESCO has graphically presented in Figure 1-1.

Load forecasting is an important element of the power planning process involving prediction of energy and demand. The forecast serves as the basis for demand and supply-side planning. Load forecasts are typically prepared by utilities for different time frames depending upon the different planning applications and operations.

Long term planning requires a system level forecast of total generation requirement and peak demand. On the other hand transmission and distribution planning require more load level and geographic detail to assess location, timing and loading of individual lines, substation and transformation facilities.



**Figure 1- 1:** Computed Demand Forecast

Forecasting models fall into three general categories:

- Trend models
- Econometric based models
- End-use models

Trend forecasts graphically or mathematically extrapolate past electricity demand trends into the future. They may be inadequate for shorter time periods where demographic changes in the underlying causal factors of load growth are not anticipated. Econometric models represent a more complex 'top-down' approach to forecasting and rely on the observed or the implied relationship between past energy consumption and other variables defining past economic output, demographics and price or income variables. Such models employ a combination of econometric, regression and time series forecast techniques. End-use models relate energy use to the physical

appliance stock levels, to the use patterns or to the industrial process. These end use models represent a ‘bottom-up’ forecasting approach and normally incorporate disaggregate end use forecast and consumer survey techniques.

This report has been prepared on the basis of Power Market Survey Methodology and the model used is called Power Market Survey (PMS) model. This model is a form of end use model which provides energy and power projection for all distribution companies and all grid stations within the company.

The PMS model relies on an extensive data base of historical sales. The data base includes consumption by consumer type (i.e. domestic, industrial and commercial etc.) on a grid station and grid station feeder basis. Actual consumption data are adjusted for un-served demands attributed to load shedding.

Energy forecasts are computed for each consumption category at the sub area level on the basis of a trend analysis of recent per consumer sales plus new consumer connection applications. Industrial forecasts are based on interviews with existing consumers, trend projections and a review of the applications for request of new and increased service. These analyses are repeated for each sub area for each of the years to be forecast. The annual peak demand is determined from the resulting energy forecasts by using the load factors and diversity factors developed for each consumer category. Forecasts are then aggregated to system level.

Because the PMS forecast is based on a mix of end-use, trend projection and known consumer expansion plans, it cannot be used reliably to predict demand over the longer term. This model had not been created to predict impacts of changes in growth of different economic sectors or consumers categories over time, or changes in both the absolute and relative prices of electricity, and of changes in the relationships between income growth and electricity growth over time as a result of market saturation and technological change (in order to capture these changes NTDCL is using another model called regression model). Regression model is used for long term forecasting as the changes in growth are occurred due to change in technology, life style over a longer time period.

The Power Market Survey forecast model most closely approaches the requirements of power system planning. It provides the level of detail required for siting studies and transmission and substation planning, as well as the sectoral detail necessary to assess different sector growth rates and their impacts on load shapes, both for the system, DISCOs and grid stations. In addition, because it also makes specific provision for load shedding i.e. suppressed demand, it provides a reasonable approximation of unconstrained load growth.

## 2 Historical Supply And Demand Analysis

### 2.1 Category-wise Sale

The customers within the company can be segregated in different categories. The segregation is usually based upon the type of applications for which electricity is being used. Major categories include Domestic, Commercial, Small industries, Medium & Large industries and Agriculture.

The category-wise percentage sale for the years 2002-03, 2005-06, and 2013-14 are given in Figure 1-2.





Figure 1- 2: **Historical Category-wise Sale**

## 2.2 Transmission and Distribution Losses

In our system losses are divided into two types;

- Transmission Losses
- Distribution Losses

The losses on 132 kV and 11kV transmission lines are considered as Transmission Losses where as the losses on 11 kV and 440 Volts lines supplying the consumers are called Distribution Losses. In a system, generally the high losses are due to lack of proper maintenance and element of theft. Reduction in losses can be achieved, by installing proper size of conductor in 11kV feeders, and low tension lines and by installing capacitor banks, to reduce reactive power and thereby improving power factor. Energy sent out is shown in the form of its breakup as sale, distribution losses and transmission losses with their percentages in the figure 1-3 for the year 2010-11, 2011-12 and 2012-13.



**Figure 1- 3:** Historical Transmission and Distribution Losses

## 2.3 Recorded and Computed Peak Demand

Recorded demand is the highest electricity demand or maximum power supplied to the consumers during the base year. Computed peak demand is calculated by adding the element of unserved power into the figure of recorded peak demand. Figure 1-4 shows the recorded and computed peak demand (MW) from the year 2008-09 to 2012-13.




Figure 1- 4: Historical Recorded and Computed Peak Demand

## 2.4 Number of Consumers

Historical record of number of consumers within LESCO jurisdiction is given in Figure 1-5. These consumers are from all categories; i.e. Domestic, Commercial, Small industries, Medium & Large industries, Public Lighting, Bulk and Agriculture.




Figure 1- 5: Number of Consumers

### 3 Power Market Survey Methodology

#### 3.1 Overview

The Power Market Survey Model forms the basis of the medium term forecast. It produces energy and peak demand forecast over an eleven year period by consumption category and by grid station for the entire service area. The model has three inter-related components: the main database, the basic input parameters and the calculations themselves.

The energy consumption data base obtained through the power market survey is immense. It contains base year consumption data for existing consumers and eleven years' forecast data for new consumers for each consumer category within the company. In addition, there is separate information for peak demand in medium & large industries and traction categories. Because of its volume this data is not listed as part of this report.

In addition to the data base, a number of basic input parameters form an integral part of the forecast model which are separately prepared for each DISCO. These include:

- Growth rates: the annual increase in consumption per consumer by consumption category
- Loss rates: transmission and distribution losses expressed as a percentage of energy purchased and energy sold, respectively
- Load factors: relating the amount of energy consumed to the rate at which it is consumed (that is, the peak demand) for each consumption category
- Coincidence factors: describing the load diversity within the system.

The forecast calculations within the model combine the energy consumption data and the input parameters to compute the energy and peak demand requirements within each area for each year to be forecasted. The data is accumulated from the area basis, to grid stations, DISCOs and ultimately to produce a forecast for the entire system.

Each of the three model component is discussed in detail below.

#### 3.2 Survey Base Data

An extensive data base has been developed on gross consumption by consumer category household (domestic), commercial, small industrial, large industrial, tube wells (agriculture), public lighting, and traction (electric rail). Energy consumption comes from consumer service meter readings. Maximum demand readings and load factors for large industrial users and other demand-metered consumers are based on service meter readings. The consumption data is collected from Computer Centers of each DISCO (It is feeder-wise category-wise consumption data).

Actual consumption data are also adjusted for un-served demands attributed to load shedding and to voluntary restraint by consumers (e.g. an industrial consumer who agrees to close his plant or switch to auto-generation during peak hours).

The basic geographic unit represented within the data base is called an area, although many areas are divided into two or more subareas. This occurs when portions of the area are served by different feeders or where a single feeder services different administrative districts. Each area is assigned a series of codes which identify the technical boundaries associated with the area.

The technical boundaries, which are emphasized in this report, start at the grid station. Thus, all areas and subareas are assigned to one of the all the sub-stations in each DISCO. These are distribution grid stations supplying power at 11 kV after transformation from a 132kV or 66 kV source. Grid stations are combined to form DISCO.

There can be up to eleven records in the data base for each area or subarea, one record for each year of forecast. The first year is typically year zero and records the base year level of consumption for each consumption category as determined in the survey. The remaining records for the area list the incremental consumption associated with new consumers to be added to the area within the specified year.

This incremental consumption is based on applications for new or extended service which are filed at each revenue office and from discussions with the relevant industries and government agencies. Incremental industrial consumption is based on a combination of interviews, trend projections, and reviews of applications for new and/or increased service. Interviews are held with major industrial consumers to identify their current capacity utilization and any long-term plans they have for future expansion or changes in their electricity consumption. Auto-generation is also recorded. In addition, the various branches of the Ministry of Industries are interviewed to determine how many applications for new developments or plant expansions have been received, and what the anticipated electrical load associated with each is likely to be. These anticipated new demands are added to the basic forecast of industrial consumption.

Extension of electricity to new areas over the forecast period is dealt with separately. The number of new communities to be electrified is also obtained. Initial loads and load growth are calculated based on past experience in terms of market penetration and consumption per consumer in newly electrified communities. This analysis is conducted at DISCO level.

There are over 10,000 area/subarea/year records in the data base.

### **3.3 Input Parameters**

A number of input parameters are defined for use in the Power Market Survey model, these parameters are:

- Transmission and distribution loss rates
- The rates of growth in consumption per consumer
- Load factors for each consumption category
- Coincidence or diversity factors
- Load Shedding or Unserved Energy

The definition and basic derivation of each is discussed below.

### **3.4 Growth Rates**

The forecast calculations, as will be discussed below, use per consumer growth rates to update the previous year's consumption before adding the incremental consumption estimate for the current year. The Power Market Survey model requires per consumer growth rates to be specified by DISCO for each consumption category (domestic, commercial, etc). The rates selected for the forecast are based on average annual compound growth rates, calculated from the last six years data of each consumer category in each DISCO.

### 3.5 Losses

For every 100 units of electricity purchased from a power station only 75 to 85 units are actually sold to the ultimate end-user. The remainder is consumed by the power system itself in the transmission and distribution of the sold energy. These transmission and distribution losses must be added to the sales forecast in order to determine the total generation requirement for the system. An additional source of "loss" is the consumption in auxiliaries (also called station service) used by the power plants in the process of generating electricity. Auxiliary consumption cannot be avoided and is totally dependent on the type of generation system. For example, a thermal plant would have a higher station service than a hydro plant to account for the energy consumed by fuel and waste handling systems. Auxiliary losses are determined and incorporated in the forecast outside the model.

Within the Power Market Survey model, distribution losses are expressed as a percentage of sales and transmission losses as a percentage of the energy purchased from the generating stations. The model is capable of handling different loss rates of each year for each DISCO. The distribution and transmission losses used in the Power Market Survey Model are based on the review of current loss rates and an evaluation of existing loss reduction initiatives within PEPCO. The losses proposed, distribution losses at 11kV and transmission losses at 132 kV, are applied DISCO-wise. A separate excel sheet has been developed outside the model to calculate the loss rates needed for the model. The loss rates have been set to match observed performance.

### 3.6 Load Factors

Energy sale in each consumption category is converted to peak power demand through the use of a load factor. It expresses the ratio of the amount of energy actually consumed to the amount that would have been consumed had the peak rate been continued over the entire period. Load factors can be calculated over any time period but the most common are daily, weekly and annual.

The load factors utilized in the Power Market Survey Model relate annual energy sales to peak capacity for each consumer category (domestic, commercial, public lighting, small industries and private tube wells). Input load factors are not required for medium/large industry, public tube well and traction sales as consumption for these sectors is provided through the survey in both energy and power terms.

Maximum demand readings are available directly for large industrial and other demand metered consumers such as public tube wells. Load factors for non-demand metered consumers are determined on a sample basis. For example, peak demand is based on maximum demand readings from substation feeders which are identified as serving predominantly one sector.

Domestic and commercial load factors are differentiated by community size (village, town or city). Whereas a single load factor is used for small industrial, private tube wells, public lighting and traction because of the similar nature in the operation of these loads. While there is some variation in the load factors within the domestic and commercial sectors, there are no differences in any of the load factors by DISCO or year.

### 3.7 Coincidence Factors

The total energy demand of a number of individual consumers is determined as the simple sum of their individual energy consumption values. The total peak load, however, is calculated as the diversified sum of their individual peak load levels. The coincidence factor, as its name implies, is a general term which measures the coincidence between the peak loads of any number of individual consumers or consumer groups over a specified time period in order to compute a combined peak. Mathematically, it is the inverse of the diversity factor.

The daily coincidence factor is determined by comparing the daily load patterns of each consumer or group under consideration. In this case, the sum of the individual hourly (or 15-minute) peaks would determine the overall daily load pattern and the overall peak load. If, for example, one consumer (or group) consumes energy only in the morning and a second group consume only in the evening, the coincidence factor between these two consumers would be zero and the peak load of the combined group would be the peak of the larger consumer. Conversely, if both groups consumed all energy at the same hour, the coincidence factor would be one and the combined peak would be the sum of the two peaks. In practice, the coincidence factor is found between these two extremes.

Coincidence factors can be determined between any group and sub-group of consumers whether it is domestic versus commercial or Lahore versus Islamabad, provided that reasonable estimates of the appropriate load patterns are available. Typically, these patterns are not readily available and must be synthesized from incomplete or estimated data. In addition, all coincidence factors calculated from these load patterns are approximations of the corresponding instantaneous peak faced by the system. In fact, a common practice is to define this instantaneous peak as the bench mark and specify all coincidence factors in relation to this peak and time. The advantage of this approach is that all peak can be easily converted into their contribution to the overall system peak, the disadvantage is that the relationship between any two groups cannot be so clearly specified and will likely be incorrectly specified.

The Power Market Survey Model depends upon specified coincidence factors between consumption categories and between consumption areas in the aggregation of peak loads from consumers to the peaks at grid stations and at DISCO level and at the level of overall system peak. The coincidence factors estimated for the medium term model have been based on the limited available PEPCO records of the peak loads at various points in their respective systems.

### 3.8 Forecast Calculations

The forecast calculations involve three basic steps. Firstly, an energy forecast is determined at the area (or subarea) level using per consumer growth rates and incremental consumption estimates from the data base. This is then converted to a peak demand forecast, again at the area (or subarea) level using the input load and diversity factors. Then transmission and distribution losses are added and final step is to accumulate the areas into their corresponding grid stations, and grid stations into their DISCOs and finally all DISCOs to form the system.

### 3.9 Energy Calculations

The basic calculation unit is the area or subarea. The data base provides the base year energy consumption level for each of six consumption categories: domestic, commercial, public lighting, small industrial, private tube wells and medium and large industry. The database

also includes the peak demand associated with the medium and large industry category. The domestic energy forecast for year 1 (the base year is year 0) is calculated by multiplying the base year consumption by the domestic per consumer growth rate to account for growth in the intensity of use in the sector then adding the incremental consumption listed in the data base to account for new use in the sector. This process is repeated for the remaining five energy sectors (plus the medium and large industrial demand) for each of the remaining 10 years. The total energy consumed in the subarea within the year is then computed.

### **3.10 Peak Demand Calculations**

The annual energy values for each of the domestic, commercial, public lighting, small industry and private tube well categories are converted to peak demand using the load factors listed in the appropriate input parameter file and adjusted to account for coincidence within the category. The annual peak demand for the area or subarea is computed as the sum of the individual category peaks multiplied by coincidence factors within the subarea and for each subarea within an area.

### **3.11 Accumulations**

The total energy and peak demand at a given grid station is calculated as the sum of all the areas and subareas in that grid station's service area plus an allowance for distribution losses. Peak demand estimates are accumulated and different coincidence factors applied to city, town and village areas within the service area. The total energy and peak demand within a given DISCO is the sum of all grid stations in that DISCO plus traction and an allowance for transmission losses. Peak demands are again diversified in the accumulation, and the system totals are obtained from DISCO's total with some coincidence.


## 4 PMS Forecast Results

### 4.1 Recorded Forecast (Excluding Load Shedding)


The term ‘recorded’ means the sale used in forecast has not been adjusted for un-served energy (load shedding). Forecasted sale, transmission and distribution losses, generation requirements and peak demand without load shedding has been shown on Table 1-1.

### 4.2 Computed Forecast (Including Load Shedding)

The term ‘computed’ means the sale used in forecast has been adjusted for un-served energy (load shedding). Forecasted sale, transmission and distribution losses, generation requirement and peak demand with load shedding has been shown on Table 1-2. Peak demand of this table has been demonstrated graphically in Figure 1-6. Similarly energy sale and energy Purchased also have been shown in Figure 1-7, the difference shows all losses of the DISCO. This is also the base forecast. If there had not been the load shedding the recorded forecast would have been the actual forecast i.e. the base forecast.




**Figure 1- 6:** Computed Peak Demand



**Figure 1- 7:** Energy Purchased VS Energy Sale

### 4.3 Category-wise Forecasted Energy Sale (GWh)

Percentage share of each consumer category in total sale of year 2017-18 and year 2023-24 has been depicted in Figure 1-8.



**Figure 1- 8:** Forecasted Category Wise Sale

The category-wise forecasted sale with and without load shedding are shown in Table 1-3 and 1-4 respectively.

#### 4.4 Category wise Forecasted Energy Sale (MW)

The forecast of consumption (sale) in terms of Mega Watts with and without load shedding is shown in Table 1-5 and Table 1-6 respectively.


#### 4.5 Peak Demand of Substations

A projection at a sub-station is the most peculiar feature of this report. It is indeed a very rare and useful forecast. It's the base of transmission system expansion planning. It also provides a very solid ground for proposing a new sub-station or augmentation, extension and conversion of a sub-station. Only distribution losses have been considered in preparing the grid station peak demand.

The peak demand of each substation, existing as well as proposed, situated in the service area of the DISCO has been shown in the Table 1-17.

#### 4.6 Per Capita Consumption

Per capita consumption is a very vivid indicator of development in a country. Usually developed countries have very high per capita consumption. The consumption for the years 2017-18, 2019-20 and 2023-24 are obtained from forecasted data. Per capita consumption (kWh/person) is given in Figure 1-9.



**Figure 1- 9:** Per Capita Consumption

#### **4.7 Category-wise Substation-wise Energy and Demand Projections**

The category-wise substation-wise energy and demand projections have been presented in Table 1-18. The last column of the table contains power factor and reactive power values. In order to reduce the volume of the report, only the values of the last year i.e. 2022-23-have been presented in the table.

#### **4.8 Civil Administrative Area Forecast**

The LESCO service area comprises of one civil administrative division i-e Lahore which has five districts; Kasur, Lahore, Nankana, Okara and Sheikhupura. The District-wise and civil administrative Division-wise energy and demand projections have been presented in Tables 1-7 to 1-12. The last column of the table contains peak demand.

#### **4.9 Monthly Demand (MW) Projections**

The Month-wise demand (MW) projections have been presented in Table 1-13. To develop this projection, monthly demand factors are computed for last five years and then its average is taken as a base for monthly demand projection.

#### **4.10 List of Overloaded Substations**

There have been several incidents of damage and fire at a number of sub-stations across the country due to overloading and they need augmentation or addition of a transformer. The list of overloaded substation will inform about that particular year in which a substation will be overloaded. The overloading criterion of a substation has been considered as 85% i.e. when any substation is 85% loaded the remedial measures should be taken in the form of new substation or augmentation of the existing transformers. Table 1-14 & Table 1-15 shows the list of overloaded substations based on overloading criterion of 85% and 100% respectively.

#### **4.11 List of Grids with their Codes and MVA Capacities**

The list of Grids contains each substation having their codes and tranformers' MVA capacities are enlisted in the Table 1-16.

**Table 1-1: PMS Recorded Forecast (Excluding Load Shedding)**

Year	Energy Sale		Distribution Losses		Transmission Losses		Energy Sent out	Load Factor	Peak Demand
	(GWh)	G.R	(GWh)	(%)	(GWh)	(%)	(GWh)	(%)	(MW)
2013-14	15948		2331	12.7	146	0.79	18425	72	2911
2014-15	17976	12.7	2511	12.2	162	0.78	20649	73	3226
2015-16	19625	9.2	2656	11.8	174	0.77	22455	73	3500
2016-17	21364	8.9	2793	11.5	186	0.76	24342	73	3786
2017-18	22942	7.4	2885	11.1	196	0.75	26023	73	4047
2018-19	24373	6.2	2965	10.8	205	0.74	27544	74	4275
2019-20	25625	5.1	3015	10.5	212	0.73	28853	74	4469
2020-21	26863	4.8	3051	10.1	218	0.72	30132	74	4656
2021-22	28207	5.0	3087	9.8	225	0.71	31519	74	4858
2022-23	29580	4.9	3113	9.5	232	0.70	32926	74	5063
2023-24	30974	4.7	3129	9.1	238	0.69	34341	74	5269

**Table 1-2: PMS Base Forecast**

Year	Energy Sale	Computed Energy Load Shed	G.R	Distribution Losses		Transmission Losses		Computed Energy Sent Out	Load Factor	Computed Peak Demand	G.R
	(GWh)	(GWh)	(%)	(GWh)	(%)	(GWh)	(%)	(GWh)	(%)	(MW)	(%)
2013-14	15948	20693		3024	12.8	189.3	0.79	23906	59	4588	
2014-15	17976	23006	11.2	3227	12.3	207.2	0.78	26439	60	5020	9.4
2015-16	19625	24916	8.3	3387	12.0	220.8	0.77	28524	60	5407	7.7
2016-17	21364	26931	8.1	3540	11.6	234.6	0.76	30705	60	5811	7.5
2017-18	22942	28708	6.6	3634	11.2	245.8	0.75	32588	60	6167	6.1
2018-19	24373	30318	5.6	3712	10.9	255.2	0.74	34285	60	6479	5.0
2019-20	25625	31707	4.6	3751	10.6	262.4	0.73	35720	61	6739	4.0
2020-21	26863	33058	4.3	3773	10.2	268.9	0.72	37100	61	6984	3.6
2021-22	28207	34519	4.4	3794	9.9	275.8	0.71	38588	61	7249	3.8
2022-23	29580	36010	4.3	3804	9.6	282.7	0.70	40097	61	7517	3.7
2023-24	30974	37525	4.2	3803	9.2	288.5	0.69	41616	61	7788	3.6

**Table 1-3: Category Wise Sale – GWh (Excluding Load Shedding)**

Year	Domestic		Commercial		Public Light		Small Industries		M&L Industries		Tube Well		Total	
	Energy	G.R	Energy	G.R	Energy	G.R	Energy	G.R	Energy	G.R	Energy	G.R	Energy	G.R
2013-14	6664		1251		103		471		6333		1127		15948	
2014-15	7484	12.3	1413	12.9	108	5.2	513	8.8	7211	13.9	1248	10.8	17976	12.7
2015-16	8212	9.7	1613	14.2	113	4.7	554	8.1	7757	7.6	1375	10.2	19625	9.2
2016-17	9032	10.0	1803	11.7	119	4.8	592	6.9	8306	7.1	1512	10.0	21364	8.9
2017-18	9769	8.2	1983	10.0	125	5.0	626	5.7	8834	6.4	1606	6.2	22942	7.4
2018-19	10577	8.3	2161	9.0	131	5.1	661	5.6	9154	3.6	1690	5.2	24373	6.2
2019-20	11327	7.1	2327	7.7	136	4.1	697	5.4	9364	2.3	1775	5.0	25625	5.1
2020-21	12145	7.2	2473	6.3	142	4.0	734	5.4	9509	1.5	1861	4.8	26863	4.8
2021-22	13051	7.5	2629	6.3	148	4.2	774	5.4	9656	1.6	1949	4.7	28207	5.0
2022-23	13980	7.1	2789	6.1	152	3.1	814	5.3	9807	1.6	2038	4.6	29580	4.9
2023-24	14920	6.7	2952	5.8	157	3.1	856	5.1	9960	1.6	2128	4.4	30974	4.7

**Table 1-4: Category-wise Sale – GWh (Base Forecast)**

Year	Domestic		Commercial		Public Light		Small Industries		M&L Industries		Tube Well		Total	
	Energy	G.R	Energy	G.R	Energy	G.R	Energy	G.R	Energy	G.R	Energy	G.R	Energy	G.R
2013-14	8647		1623		133		611		8217		1462		20693	
2014-15	9603	11.0	1807	11.3	140	5.1	659	7.8	9193	11.9	1605	9.8	23006	11.2
2015-16	10435	8.7	2030	12.4	147	4.5	706	7.2	9843	7.1	1755	9.4	24916	8.3
2016-17	11365	8.9	2244	10.5	153	4.6	749	6.1	10503	6.7	1917	9.2	26931	8.1
2017-18	12171	7.1	2446	9.0	161	4.8	786	4.9	11122	5.9	2023	5.5	28708	6.6
2018-19	13051	7.2	2642	8.0	168	4.9	824	4.9	11518	3.6	2115	4.5	30318	5.6
2019-20	13850	6.1	2822	6.8	175	3.8	863	4.8	11788	2.3	2208	4.4	31707	4.6
2020-21	14719	6.3	2978	5.5	182	3.8	904	4.7	11973	1.6	2303	4.3	33058	4.3
2021-22	15676	6.5	3144	5.6	189	3.9	947	4.8	12163	1.6	2400	4.2	34519	4.4
2022-23	16657	6.3	3314	5.4	194	2.9	991	4.7	12356	1.6	2499	4.1	36010	4.3
2023-24	17651	6.0	3487	5.2	200	2.9	1036	4.5	12553	1.6	2598	4.0	37525	4.2

**Table 1-5: Category-wise Demand – MW (Excluding Load Shedding)**

Year	Domestic		Commercial		Public Light		Small Industries		M&L Industries		Tube Well		Total	
	Demand	G.R	Demand	G.R	Demand	G.R	Demand	G.R	Demand	G.R	Demand	G.R	Demand	G.R
2013-14	1211		260		21		108		1425		161		2522	
2014-15	1351	11.5	291	12.2	22	5.0	117	8.2	1583	11.1	175	9.0	2811	11.5
2015-16	1484	9.9	331	13.6	23	4.7	127	8.0	1699	7.3	193	10.2	3062	8.9
2016-17	1633	10.1	368	11.4	24	4.8	135	6.9	1815	6.8	213	9.9	3326	8.6
2017-18	1768	8.2	405	9.9	26	5.0	143	5.7	1927	6.2	226	6.2	3571	7.4
2018-19	1915	8.3	441	8.9	27	5.1	151	5.6	1998	3.7	238	5.2	3786	6.0
2019-20	2051	7.1	474	7.6	28	4.1	159	5.4	2047	2.5	249	5.0	3973	4.9
2020-21	2200	7.2	504	6.3	29	4.0	168	5.3	2081	1.7	262	4.8	4154	4.6
2021-22	2365	7.5	536	6.3	30	4.2	177	5.4	2116	1.7	274	4.7	4351	4.7
2022-23	2534	7.1	569	6.1	31	3.1	186	5.2	2151	1.7	287	4.6	4552	4.6
2023-24	2705	6.8	602	5.9	32	3.1	195	5.1	2187	1.7	299	4.4	4756	4.5

**Table 1-6: Category-wise Demand – MW (Base Forecast)**

Year	Domestic		Commercial		Public Light		Small Industries		M&L Industries		Tube Well		Total	
	Demand	G.R	Demand	G.R	Demand	G.R	Demand	G.R	Demand	G.R	Demand	G.R	Demand	G.R
2013-14	1909		409		33		171		2245		254		3975	
2014-15	2105	10.3	453	10.6	35	4.8	183	7.2	2463	9.7	274	8.0	4373	10.0
2015-16	2289	8.8	506	11.9	37	4.5	196	7.1	2633	6.9	300	9.4	4727	8.1
2016-17	2495	9.0	558	10.3	38	4.6	208	6.0	2805	6.5	327	9.2	5100	7.9
2017-18	2673	7.2	608	8.9	40	4.8	218	4.9	2968	5.8	346	5.5	5438	6.6
2018-19	2868	7.3	656	7.9	42	4.9	229	4.9	3076	3.6	361	4.5	5734	5.4
2019-20	3044	6.1	701	6.7	44	3.8	240	4.7	3153	2.5	377	4.4	5987	4.4
2020-21	3235	6.3	739	5.5	45	3.8	251	4.7	3206	1.7	393	4.3	6228	4.0
2021-22	3447	6.5	781	5.6	47	3.9	263	4.7	3260	1.7	410	4.2	6490	4.2
2022-23	3664	6.3	823	5.4	48	2.9	275	4.6	3315	1.7	427	4.1	6756	4.1
2023-24	3884	6.0	866	5.2	50	2.9	287	4.5	3371	1.7	444	4.0	7027	4.0

**Table 1-7: District-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For District: Kasur**

Year	Energy Sale		Distribution Losses		Transmission Losses		Generation	Load Factor	Peak Demand
	(GWh)	G.R.(%)	(GWh)	%	(GWh)	%	(GWh)	%	(MW)
2013-14	3294	0.00	485	12.83	30	0.79	3809	44	994
2014-15	3513	6.67	489	12.21	32	0.78	4034	45	1033
2015-16	3630	3.32	490	11.90	32	0.77	4152	45	1064
2016-17	3759	3.55	491	11.56	33	0.76	4283	44	1101
2017-18	3995	6.29	500	11.12	34	0.75	4529	45	1159
2018-19	4184	4.72	507	10.81	35	0.74	4726	45	1207
2019-20	4381	4.71	514	10.50	36	0.73	4931	45	1257
2020-21	4587	4.70	520	10.17	37	0.72	5144	45	1309
2021-22	4802	4.70	524	9.85	38	0.71	5365	45	1363
2022-23	5028	4.71	528	9.51	39	0.70	5596	45	1420
2023-24	5265	4.71	531	9.17	40	0.69	5837	45	1478

**Table 1-8: District-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For District: Lahore**

Year	Energy Sale		Distribution Losses		Transmission Losses		Generation	Load Factor	Peak Demand
	(GWh)	G.R.(%)	(GWh)	%	(GWh)	%	(GWh)	%	(MW)
2013-14	11963	0.00	1760	12.82	110	0.79	13833	40	3920
2014-15	12690	6.07	1785	12.33	114	0.78	14589	41	4107
2015-16	13328	5.03	1808	11.95	118	0.77	15254	41	4272
2016-17	14007	5.10	1837	11.59	122	0.76	15966	41	4459
2017-18	14908	6.43	1882	11.21	128	0.75	16918	41	4729
2018-19	15806	6.03	1930	10.88	133	0.74	17870	41	4991
2019-20	16731	5.85	1976	10.56	138	0.73	18846	41	5262
2020-21	17732	5.98	2023	10.24	144	0.72	19899	41	5554
2021-22	18831	6.20	2071	9.91	150	0.71	21052	41	5873
2022-23	19962	6.01	2112	9.57	157	0.70	22230	41	6199
2023-24	21117	5.79	2145	9.22	162	0.69	23424	41	6533

**Table 1-9: District-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For District: Nankana**

Year	Energy Sale		Distribution Losses		Transmission Losses		Generation	Load Factor	Peak Demand
	(GWh)	G.R.(%)	(GWh)	%	(GWh)	%	(GWh)	%	(MW)
2013-14	606	0.00	77	11.31	5	0.79	689	42	187
2014-15	946	55.91	122	11.43	8	0.78	1076	47	259
2015-16	999	5.66	126	11.20	9	0.77	1134	47	276
2016-17	1060	6.10	131	10.97	9	0.76	1200	47	294
2017-18	1134	6.99	136	10.74	10	0.75	1280	46	316
2018-19	1211	6.75	142	10.49	10	0.74	1363	46	338
2019-20	1290	6.53	147	10.22	11	0.73	1447	46	361
2020-21	1371	6.33	151	9.94	11	0.72	1534	46	384
2021-22	1456	6.16	155	9.64	12	0.71	1623	45	408
2022-23	1543	6.00	159	9.33	12	0.70	1714	45	432
2023-24	1633	5.85	162	9.01	13	0.69	1808	45	457

**Table 1-10: District-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For District: Okara**

Year	Energy Sale		Distribution Losses		Transmission Losses		Generation	Load Factor	Peak Demand
	(GWh)	G.R.(%)	(GWh)	%	(GWh)	%	(GWh)	%	(MW)
2013-14	1611	0.00	257	13.76	15	0.79	1883	37	587
2014-15	946	6.85	266	13.38	16	0.78	2004	38	604
2015-16	999	6.19	273	13.01	16	0.77	2118	38	634
2016-17	1060	5.89	280	12.63	17	0.76	2233	38	665
2017-18	1134	6.23	287	12.24	18	0.75	2361	38	703
2018-19	1211	6.03	293	11.86	19	0.74	2492	38	742
2019-20	1290	5.85	299	11.47	19	0.73	2626	38	783
2020-21	1371	5.68	304	11.07	20	0.72	2763	38	824
2021-22	1456	5.53	308	10.67	21	0.71	2903	38	866
2022-23	1543	5.40	311	10.27	21	0.70	3045	38	909
2023-24	1633	5.27	313	9.87	22	0.69	3191	38	954

**Table 1-11: District-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For District: Sheikhupura**

Year	Energy Sale		Distribution Losses		Transmission Losses		Generation	Load Factor	Peak Demand
	(GWh)	G.R.(%)	(GWh)	%	(GWh)	%	(GWh)	%	(MW)
2013-14	3218	0.00	445	12.15	29	0.79	3692	45	932
2014-15	3183	-1.07	418	11.60	28	0.78	3629	44	935
2015-16	3347	5.13	423	11.22	29	0.77	3799	44	984
2016-17	3586	7.14	427	10.65	31	0.76	4044	44	1043
2017-18	3814	6.37	438	10.31	32	0.75	4285	44	1112
2018-19	4035	5.80	449	10.00	34	0.74	4517	44	1172
2019-20	4236	4.97	458	9.75	35	0.73	4729	44	1224
2020-21	4445	4.94	466	9.49	36	0.72	4948	44	1277
2021-22	4675	5.17	475	9.22	37	0.71	5187	44	1337
2022-23	4915	5.13	483	8.94	38	0.70	5436	44	1399
2023-24	5165	5.09	489	8.65	39	0.69	5694	44	1463

**Table 1-12: Division-wise Sale (GWh), Generation (GWh) and Demand (MW) Forecast For Division: Lahore.**

Year	Energy Sale		Distribution Losses		Transmission Losses		Generation	Load Factor	Peak Demand
	(GWh)	G.R.(%)	(GWh)	%	(GWh)	%	(GWh)	%	(MW)
2013-14	20693	0.00	3024	12.75	189	0.79	23906	59	4588
2014-15	22054	6.58	3080	12.25	199	0.78	25332	60	4809
2015-16	23132	4.89	3121	11.89	205	0.77	26457	60	5010
2016-17	24348	5.26	3166	11.51	212	0.76	27726	60	5241
2017-18	25908	6.41	3243	11.13	222	0.75	29373	60	5558
2018-19	27417	5.82	3321	10.81	231	0.74	30969	60	5857
2019-20	28946	5.58	3394	10.49	239	0.73	32579	60	6159
2020-21	30575	5.63	3463	10.18	248	0.72	34287	60	6479
2021-22	32339	5.77	3533	9.85	258	0.71	36130	60	6824
2022-23	34162	5.64	3592	9.51	268	0.70	38022	60	7180
2023-24	36037	5.49	3640	9.17	277	0.69	39954	60	7544

**Table 1-13: Monthly Peak Demand Forecast**

Year	July	August	September	October	November	December	January	February	March	April	May	June
	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)
2013-14	4244	4515	4331	3868	2629	2803	2592	2266	3313	3868	4588	4377
2014-15	4644	4940	4739	4232	2877	3067	2836	2480	3625	4232	5020	4789
2015-16	5001	5320	5104	4558	3098	3304	3055	2671	3904	4558	5407	5158
2016-17	5375	5718	5485	4898	3329	3550	3283	2870	4195	4898	5811	5543
2017-18	5705	6069	5822	5199	3534	3768	3485	3047	4453	5199	6167	5884
2018-19	5993	6375	6116	5461	3712	3958	3660	3200	4677	5461	6479	6181
2019-20	6234	6631	6362	5681	3861	4118	3808	3329	4866	5681	6739	6429
2020-21	6461	6873	6593	5888	4002	4267	3946	3450	5043	5888	6984	6663
2021-22	6705	7133	6843	6111	4154	4429	4096	3581	5234	6111	7249	6916
2022-23	6954	7397	7096	6337	4308	4593	4247	3714	5428	6337	7517	7172
2023-24	7204	7663	7352	6565	4462	4758	4400	3847	5623	6565	7788	7430

**Table 1-14: List of Overloaded Substations during Period 2012-13 to 2022-23 Overloading Criterion= 85%**

S.No.	Name	Rating	Grid #	Total Capacity	Total Capacity	Overloading Criterion	Overloading Criterion	Year of Overloading	Overloading Status	Power Factor
		KV		(MVA)	(MW)	(MW)	(%)		(MW)	(%)
1	Attabad	132	6	92	81.88	69.60	85.00	2013-14	71.40	0.89
2	Batapur	132	13	78	66.30	56.36	85.00	2013-14	80.40	0.85
3	Bhai Pheru	132	15	78	68.64	58.34	85.00	2013-14	109.80	0.88
4	Bucheki	132	20	52	44.72	38.01	85.00	2015-16	36.90	0.86
5	Chah Miran	132	23	80	71.20	60.52	85.00	2013-14	89.00	0.89
6	Chung	132	30	92	80.04	68.03	85.00	2013-14	109.40	0.87
7	Fateh Garh	132	38	106	94.34	80.19	85.00	2013-14	117.70	0.89
8	Fort	132	40	52	46.28	39.34	85.00	2013-14	59.00	0.89
9	Garden Town	132	43	132	118.80	100.98	85.00	2013-14	133.70	0.90
10	Havali	132	60	78	63.96	54.37	85.00	2013-14	76.30	0.82
11	K.Lakhpat.Old	132	82	106	95.40	81.09	85.00	2013-14	111.40	0.90
12	K.Lakhpat.New	220	113	78	67.86	57.68	85.00	2013-14	87.70	0.87
13	LEFO	132	121	78	67.08	57.02	85.00	2013-14	70.90	0.86
14	Okara City-I	132	152	66	56.76	48.25	85.00	2013-14	87.00	0.86
15	Pattoki	132	158	52	44.20	37.57	85.00	2013-14	68.30	0.85
16	Ravi	220	173	52	44.72	38.01	85.00	2013-14	63.40	0.86
17	Renala Khurd	132	176	52	44.20	37.57	85.00	2013-14	50.80	0.85
18	Saidpur	132	184	92	81.88	69.60	85.00	2013-14	97.20	0.89
19	Shahkot	132	193	78	68.64	58.34	85.00	2013-14	76.50	0.88
20	Shalamar-I	132	194	78	67.86	57.68	85.00	2013-14	81.60	0.87
21	Skp. City	132	197	78	67.86	57.68	85.00	2013-14	77.40	0.87
22	W.Radha Ram	132	221	52	44.72	38.01	85.00	2013-14	45.40	0.86
23	Ali Jaj	66	229	26	21.32	18.12	85.00	2013-14	25.60	0.82
24	Basirpur	66	241	41	34.03	28.93	85.00	2013-14	41.80	0.83
25	Chunian	132	254	52	43.68	37.13	85.00	2013-14	39.60	0.84

**Table 1-14: List of Overloaded Substations during Period 2012-13 to 2022-23 Overloading Criterion= 85% (Contd...)**

S.No.	Name	Rating	Grid #	Total Capacity	Total Capacity	Overloading Criterion	Overloading Criterion	Year of Overloading	Overloading Status	Power Factor
		KV		(MVA)	(MW)	(MW)	(%)		(MW)	(%)
26	Depalpur	132	265	78	65.52	55.69	85.00	2013-14	100.00	0.84
27	Farooqabad	132	271	78	67.08	57.02	85.00	2013-14	72.50	0.86
28	Hujra	132	287	52	43.16	36.69	85.00	2013-14	54.00	0.83
29	Khuddian	132	310	78	63.96	54.37	85.00	2013-14	83.90	0.82
30	Lalyani	132	314	52	45.76	38.90	85.00	2013-14	46.80	0.88
31	Malikpur	66	320	26	21.84	18.56	85.00	2013-14	25.70	0.84
32	Mohlan	66	330	13	11.44	9.72	85.00	2013-14	13.30	0.88
33	Narang Mandi	132	336	26	23.14	19.67	85.00	2013-14	21.30	0.89
34	Okara Cantt	132	338	26	23.14	19.67	85.00	2013-14	22.80	0.89
35	Raiwind	132	353	92	80.96	68.82	85.00	2013-14	99.40	0.88
36	Rewaz Garden	132	357	80	71.20	60.52	85.00	2013-14	86.80	0.89
37	Sangla Hill	132	362	26	23.40	19.89	85.00	2013-14	19.60	0.90
38	Shahdara New	132	369	92	79.12	67.25	85.00	2013-14	98.60	0.86
39	Sharqpur	132	372	52	44.20	37.57	85.00	2015-16	36.80	0.85
40	UIS	66	399	13	11.70	9.95	85.00	2013-14	13.60	0.90
41	Warburton	132	401	52	46.28	39.34	85.00	2013-14	55.10	0.89
42	Manga Mandi	132	411	78	69.42	59.01	85.00	2013-14	78.10	0.89
43	Rustum	132	412	78	67.86	57.68	85.00	2013-14	89.70	0.87
44	Defence	132	426	106	95.40	81.09	85.00	2013-14	105.40	0.90
45	Town Ship	132	428	132	114.84	97.61	85.00	2013-14	126.90	0.87
46	Gulshan Ravi	132	429	80	68.00	57.80	85.00	2013-14	90.10	0.85
47	Wapda Town	220	503	92	82.80	70.38	85.00	2013-14	103.90	0.90
48	Model Town	132	504	118	106.20	90.27	85.00	2013-14	107.00	0.90
49	Shahdara Scarp	132	505	23	20.01	17.01	85.00	2013-14	21.70	0.87
50	Elahabad	132	506	52	43.68	37.13	85.00	2013-14	51.80	0.84

**Table 1-14: List of Overloaded Substations during Period 2012-13 to 2022-23 Overloading Criterion= 85% (Contd...)**

S.No.	Name	Rating	Grid #	Total Capacity	Total Capacity	Overloading Criterion	Overloading Criterion	Year of Overloading	Overloading Status	Power Factor
		KV		(MVA)	(MW)	(MW)	(%)		(MW)	(%)
51	Green View	132	507	118	106.20	90.27	85.00	2013-14	103.60	0.90
52	Shamky	132	508	118	105.02	89.27	85.00	2013-14	93.30	0.89
53	Nankana	132	520	52	44.20	37.57	85.00	2013-14	40.50	0.85
54	Sadar Gogera	132	540	52	43.68	37.13	85.00	2013-14	40.10	0.84
55	Mcleod Road	132	583	80	71.20	60.52	85.00	2013-14	69.80	0.89
56	Bund Road	220	599	52	44.20	37.57	0.00	2013-14	56.30	0.85
57	Boggiwal	132	617	132	116.16	98.74	0.00	2013-14	132.10	0.88
58	Khanqa Dogran	132	647	52	43.68	37.13	85.00	2014-15	35.80	0.84
59	Mochi Gate	132	710	52	46.28	39.34	85.00	2013-14	47.40	0.89
60	Bhati Gate	132	711	80	68.00	57.80	85.00	2013-14	86.50	0.85
61	Sarfraz Nagar	220	737	66	59.40	50.49	85.00	2013-14	59.20	0.90
62	ICI	132	753	52	46.80	39.78	85.00	2013-14	57.80	0.90
63	Willongton Mall	132	781	92	82.80	70.38	85.00	2013-14	86.30	0.90
64	Johar Town	132	782	132	118.80	100.98	85.00	2013-14	137.90	0.90
65	Chak-65	132	800	104	93.60	79.56	85.00	2015-16	78.50	0.90
66	Valgon Sohial	132	826	52	46.28	39.34	85.00	2013-14	56.20	0.89
67	Okara City-II	132	849	66	56.76	48.25	85.00	2013-14	69.10	0.86
68	Kot Radha Kis	132	850	39	34.71	29.50	85.00	2013-14	36.60	0.89
69	Bhikki	132	871	78	70.20	59.67	85.00	2013-14	79.10	0.90
70	Shalamar-II	132	893	78	67.08	57.02	85.00	2013-14	81.10	0.86
71	Sharqpur Rd.	132	897	26	22.88	19.45	85.00	2013-14	27.90	0.88
72	SKP-Industrial	132	902	26	22.10	18.79	85.00	2013-14	28.60	0.85
73	Aysha	132	912	52	45.24	38.45	85.00	2013-14	55.90	0.87
74	Lahore Cantt	132	949	52	46.80	39.78	85.00	2013-14	57.80	0.90
75	Sabzazar	132	950	78	69.42	59.01	85.00	2013-14	75.70	0.89

**Table 1-15: List of Overloaded Substations during Period 2012-13 to 2022-2    Overloading Criterion=100%**

S.No.	Name	Rating	Grid #	Total Capacity	Total Capacity	Overloading Criterion	Overloading Criterion	Year of Overloading	Overloading Status	Power Factor
		KV		(MVA)	(MW)	(MW)	(%)		(MW)	(%)
1	Attabad	132	6	92	81.88	81.88	100.00	2022-23	78.70	0.89
2	Batapur	132	13	78	66.30	66.30	100.00	2013-14	80.40	0.85
3	Bhai Pheru	132	15	78	68.64	68.64	100.00	2013-14	109.80	0.88
4	Bucheki	132	20	52	44.72	44.72	100.00	2019-20	44.30	0.86
5	Chah Miran	132	23	80	71.20	71.20	100.00	2013-14	89.00	0.89
6	Chung	132	30	92	80.04	80.04	100.00	2013-14	109.40	0.87
7	Fateh Garh	132	38	106	94.34	94.34	100.00	2013-14	117.70	0.89
8	Garden Town	132	43	132	118.80	118.80	100.00	2013-14	133.70	0.90
9	Havali	132	60	78	63.96	63.96	100.00	2013-14	76.30	0.82
10	K.Lakhpat.Old	132	82	106	95.40	95.40	100.00	2013-14	111.40	0.90
11	K.Lakhpat.New	220	113	78	67.86	67.86	100.00	2013-14	87.70	0.87
12	LEFO	132	121	78	67.08	67.08	100.00	2013-14	70.90	0.86
13	Okara City-I	132	152	66	56.76	56.76	100.00	2013-14	87.00	0.86
14	Pattoki	132	158	52	44.20	44.20	100.00	2013-14	68.30	0.85
15	Renala Khurd	132	176	52	44.20	44.20	100.00	2013-14	50.80	0.85
16	Saidpur	132	184	92	81.88	81.88	100.00	2013-14	97.20	0.89
17	Shahkot	132	193	78	68.64	68.64	100.00	2013-14	76.50	0.88
18	Shalamar-I	132	194	78	67.86	67.86	100.00	2013-14	81.60	0.87
19	Skp. City	132	197	78	67.86	67.86	100.00	2013-14	77.40	0.87
20	W.Radha Ram	132	221	52	44.72	44.72	100.00	2013-14	45.40	0.86
21	Ali Jaj	66	229	26	21.32	21.32	100.00	2013-14	25.60	0.82
22	Basirpur	66	241	41	34.03	34.03	100.00	2013-14	41.80	0.83
23	Chunian	132	254	52	43.68	43.68	100.00	2016-17	42.80	0.84

**Table 1-15: List of Overloaded Substations during Period 2012-13 to 2022-23 Overloading Criterion=100% (Contd....)**

S.No.	Name	Rating	Grid #	Total Capacity	Total Capacity	Overloading Criterion	Overloading Criterion	Year of Overloading	Overloading Status	Power Factor
		KV		(MVA)	(MW)	(MW)	(%)		(MW)	(%)
24	Depalpur	132	265	78	65.52	65.52	100.00	2013-14	100.00	0.84
25	Farooqabad	132	271	78	67.08	67.08	100.00	2013-14	72.50	0.86
26	Hujra	132	287	52	43.16	43.16	100.00	2013-14	54.00	0.83
27	Khuddian	132	310	78	63.96	63.96	100.00	2013-14	83.90	0.82
28	Lalyani	132	314	52	45.76	45.76	100.00	2013-14	46.80	0.88
29	Malikpur	66	320	26	21.84	21.84	100.00	2013-14	25.70	0.84
30	Mohlan	66	330	13	11.44	11.44	100.00	2013-14	13.30	0.88
31	Narang Mandi	132	336	26	23.14	23.14	100.00	2015-16	23.10	0.89
32	Okara Cantt	132	338	26	23.14	23.14	100.00	2013-14	22.80	0.89
33	Raiwind	132	353	92	80.96	80.96	100.00	2013-14	99.40	0.88
34	Rewaz Garden	132	357	80	71.20	71.20	100.00	2013-14	86.80	0.89
35	Sangla Hill	132	362	26	23.40	23.40	100.00	2016-17	23.10	0.90
36	Shahdara New	132	369	92	79.12	79.12	100.00	2013-14	98.60	0.86
37	Sharqpur	132	372	52	44.20	44.20	100.00	2020-21	44.00	0.85
38	UIS	66	399	13	11.70	11.70	100.00	2013-14	13.60	0.90
39	Warburton	132	401	52	46.28	46.28	100.00	2013-14	55.10	0.89
40	Rustam	132	412	78	67.86	67.86	100.00	2013-14	89.70	0.87
41	Town Ship	132	428	132	114.84	114.84	100.00	2013-14	126.90	0.87
42	Gulshan Ravi	132	429	80	68.00	68.00	100.00	2013-14	90.10	0.85
43	Model Town	132	504	118	106.20	106.20	100.00	2013-14	107.00	0.90
44	Shahdara Scarp	132	505	23	20.01	20.01	100.00	2013-14	21.70	0.87
45	Elahabad	132	506	52	43.68	43.68	100.00	2013-14	51.80	0.84

**Table 1-15: List of Overloaded Substations during Period 2012-13 to 2022-23 Overloading Criterion=100% (Contd....)**

S.No.	Name	Rating	Grid #	Total Capacity	Total Capacity	Overloading Criterion	Overloading Criterion	Year of Overloading	Overloading Status	Power Factor
		KV		(MVA)	(MW)	(MW)	(%)		(MW)	(%)
46	Green View	132	507	118	106.20	106.20	100.00	2022-23	102.80	0.90
47	Shamky	132	508	118	105.02	105.02	100.00	2019-20	101.20	0.89
48	Nankana	132	520	52	44.20	44.20	100.00	2013-14	40.50	0.85
49	Sadar Gogera	132	540	52	43.68	43.68	100.00	2019-20	42.40	0.84
50	Mcleod Road	132	583	80	71.20	71.20	100.00	2014-15	71.20	0.89
51	Bund Road	220	599	52	44.20	44.20	100.00	2013-14	56.30	0.85
52	Boggiwal	132	617	132	116.16	116.16	100.00	2013-14	132.10	0.88
53	Mochi Gate	132	710	52	46.28	46.28	100.00	2013-14	47.40	0.89
54	Bhati Gate	132	711	80	68.00	68.00	100.00	2013-14	86.50	0.85
55	ICI	132	753	52	46.80	46.80	#REF!	2013-14	57.80	0.90
56	Willongton Mall	132	781	92	82.80	82.80	#REF!	2013-14	86.30	0.90
57	Chak-65	132	800	104	93.60	93.60	100.00	2022-23	88.80	0.90
58	Valgon Sohial	132	826	52	46.28	46.28	100.00	2013-14	56.20	0.89
59	Okara City-II	132	849	66	56.76	56.76	100.00	2013-14	69.10	0.86
60	Kot Radha Kis	132	850	39	34.71	34.71	100.00	2013-14	36.60	0.89
61	Bhikki	132	871	78	70.20	70.20	100.00	2013-14	79.10	0.90
62	Shalamar-II	132	893	78	67.08	67.08	100.00	2013-14	81.10	0.86
63	Sharqpur Rd.	132	897	26	22.88	22.88	100.00	2013-14	27.90	0.88
64	SKP-Industrial	132	902	26	22.10	22.10	100.00	2013-14	28.60	0.85
65	Aysha	132	912	52	45.24	45.24	100.00	2013-14	55.90	0.87
66	Lahore Cantt	132	949	52	46.80	46.80	100.00	2013-14	57.80	0.90
67	Sabzazar	132	950	78	69.42	69.42	100.00	2013-14	75.70	0.89

**Table 1-16: List of Grids with their Codes and MVA Capacities**

SR. No.	Grid No.	Grid KV	Grid Name	Transformers					(MVA) Total	SR. No.	Grid No.	Grid KV	Grid Name	Transformers					(MVA) Total
				T1	T2	T3	T4	T1						T1	T2	T3	T4		
1	1	132	A.I.Town	40	40	26		106		2	6	132	Attabad	40	26	26		92	
3	13	132	Batapur	26	26	26		78		4	15	132	Bhai Pheru	26	26	26	26	104	
5	18	132	Bongha Hayat	26	13			39		6	20	132	Bucheki	26	26			52	
7	23	132	Chah Miran	40	40			80		8	30	132	Chung	26	40	26	26	118	
9	38	132	Fateh Garh	40	40	26		106		10	40	132	Fort	26	26			52	
11	43	132	Garden Town	26	40	40	26	132		12	45	132	Ghazi	40	40	40	13	133	
13	60	132	Havali	26	26	26		78		14	82	132	K.Lakhpat.Old	40	40	26		106	
15	84	220	Kala Shah Kaku	40	26			66		16	99	132	Kasur	26	40	26	26	118	
17	113	220	K.Lakhpat.New	26	26	26		78		18	121	132	LEFO	26	26	26		78	
19	152	132	Okara City-I	40	26	26		92		20	153	132	P.W.R	26	40	40		106	
21	158	132	Pattoki	26	26	26		78		22	167	132	Qartaba	40	40	40		120	
23	173	220	Ravi	26	26			52		24	175	132	Rehman Park	26	40	40		106	
25	176	132	Renala Khurd	26	26	26		78		26	184	132	Saidpur	40	26	40		106	
27	191	132	Shadman	40	40	26		106		28	193	132	Shahkot	26	26	26		78	
29	194	132	Shalamar-I	26	26	26		78		30	197	132	Skp. City	26	26	26		78	
31	206	132	Sunny View	26	40			66		32	221	132	W.Radha Ram	26	26			52	
33	229	66	Ali Jaj	13	13			26		34	233	132	Badami Bagh	40	40	26		106	
35	241	66	Basirpur	13	13	15		41		36	254	132	Chunian	26	26			52	

SR. No.	Grid No.	Grid KV	Grid Name	Transformers					(MVA) Total	SR. No.	Grid No.	Grid KV	Grid Name	Transformers					(MVA) Total
				T1	T2	T3	T4	Total						T1	T2	T3	T4	Total	
37	265	132	Depalpur	26	40	26		92	38	270	66	EMCO	13	13	13		39		
39	271	132	Farooqabad	26	26	26		78	40	287	132	Hujra	26	26			52		
41	303	66	Kanganpur	13	19	8		39	42	310	132	Khuddian	26	26	26		78		
43	314	132	Lalyani	26	26	13		65	44	320	66	Malikpur	13	13			26		
45	330	66	Mohlan	13				13	46	336	132	Narang Mandi	13	13			26		
47	338	132	Okara Cantt	26				26	48	353	132	Raiwind	40	26	26		92		
49	357	132	Rewaz Garden	40	40			80	50	362	132	Sangla Hill	26	26			52		
51	369	132	Shahdara New	40	26	26		92	52	372	132	Sharqpur	26	26			52		
53	380	132	Sukheki	26	13			39	54	399	66	UIS	13				13		
55	401	132	Warburton	26	26			52	56	411	132	Manga Mandi	26	26	26	26	104		
57	412	132	Rustum	26	26	26		78	58	426	132	Defence	26	40	40		106		
59	428	132	Town Ship	26	40	26	40	132	60	429	132	Gulshan Ravi	40	40			80		
61	447	11	Chichoke Mall P					0	62	503	220	Wapda Town	26	40	26		92		
63	504	132	Model Town	40	26	26	26	118	64	505	132	Shahdara Scarp	13	10			23		
65	506	132	Elahabad	26	26			52	66	507	132	Green View	26	26	40	26	118		
67	508	132	Shamky	26	26	40	26	118	68	520	132	Nankana	26	26			52		
69	540	132	Sadar Gogera	26	26			52	70	583	132	McLeod Road	40	40			80		
71	599	220	Bund Road	26	26			52	72	617	132	Boggiwal	40	40	26	26	132		

SR. No.	Grid No.	Grid KV	Grid Name	Transformers					(MVA) Total	SR. No.	Grid No.	Grid KV	Grid Name	Transformers					(MVA) Total
				T1	T2	T3	T4	Total						T1	T2	T3	T4	Total	
73	647	132	Khanqa Dogran	26	26			52		74	659	11	Renala P/H					0	
75	710	132	Mochi Gate	26	26			52		76	711	132	Bhati Gate	40	40			80	
77	737	220	Sarfraz Nagar	40	26			66		78	753	132	ICI	26	26	26		78	
79	781	132	Willongton Mall	26	40	26		92		80	782	132	Johar Town	40	40	26	26	132	
81	800	132	Chak-65	26	26	26	26	104		82	826	132	Valgon Sohial	26	26			52	
83	849	132	Okara City-II	26	40			66		84	850	132	Kot Radha Kis	26	26			52	
85	871	132	Bhikki	26	26	26		78		86	893	132	Shalamar-II	26	26	26		78	
87	897	132	Sharqpur Rd.	26				26		88	902	132	SKP-Industrial	13	13			26	
89	912	132	Aysha	26	26			52		90	949	132	Lahore Cantt	26	26	26		78	
91	950	132	Sabzazar	26	26	26		78		92	958	132	Punjab Uni-Town	26				26	
93	960	132	City Steel SKP					0		94	964	132	Muridky		13			13	
95	979	132	Descon Oxy					0		96	985	132	Hira Terry					0	
97	994	132	Bahria Town					0		98	999	132	Colony Ind .					0	
99	1003	132	Daroghwala	40	26			66		100	1007	132	Sunder Ind. Est					0	
101	1008	132	AWT	26	26			52		102	1009	132	LUMS					0	
103	1016	132	Raiwind New	26	26			52		104	1020	132	Kasur New					0	
105	1050	132	Sukh Chain	26	26			52		106	1073	132	Mughal Steel					0	
107	1074	132	New Smr St.2 Lh					0		108	1083	132	Nishat Chunian					0	
109	1096	132	Blessed					0		110	0	0						0	

**Table 1-17: Maximum Demand (MW) of Substations**

POWER MARKET SURVEY LOAD CENTRE SUMMARY MAXIMUM DEMAND (MW) OF GRIDSTATIONS															
DISCO: LESCO		GRID NO.	NAME OF GRIDSTATION	KV	2013-14	2014-15	2015-16	2016-17	2017-18	Y 2018-19	E 2019-20	A 2020-21	R 2021-22	2022-23	2023-24
1.	599	Bund Road	220	56.3	60.7	64.7	68.9	72.1	75.1	77.6	58.3	59.7	61.2	62.6	
2.	113	K.Lakhpat.New	220	87.7	80.5	86.6	72.1	76.4	80.6	80.9	84.0	76.7	79.5	82.3	
3.	84	Kala Shah Kak	220	62.8	33.4	37.6	42.1	46.0	49.7	53.1	56.3	59.6	46.3	48.4	
4.	173	Ravi	220	63.4	68.4	72.5	76.7	79.9	82.9	68.7	70.5	42.0	43.4	44.8	
5.	737	Sarfraz Nagar	220	59.2	73.9	78.4	76.8	80.1	82.9	71.9	73.4	74.9	49.5	50.6	
6.	503	Wapda Town	220	103.9	97.6	105.6	92.4	95.9	77.8	77.6	79.4	80.1	81.9	83.7	
7.	1	A.I.Town	132	86.7	94.8	83.1	89.3	94.2	99.0	102.9	106.6	83.0	67.6	69.9	
8.	1000	A.I.Town-II	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	42.5	43.8	45.2	
9.	1008	AWT	132	20.5	22.9	25.3	27.8	30.0	23.0	24.6	26.1	27.6	29.1	30.7	
10.	2083	AirAvenue(Ph-	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7.2	10.7	14.2	17.7	
11.	2073	Al Bashir Ste	132	0.0	0.0	0.0	0.0	0.0	14.1	14.1	14.1	14.1	14.1	14.1	
12.	931	Al- Shafi	132	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	
13.	2015	Ali Asia Stee	132	0.0	0.0	0.0	0.0	0.0	6.3	6.3	6.3	6.3	6.3	6.3	
14.	1021	AmirSapphireK	132	10.2	10.2	10.2	10.2	10.2	10.2	10.2	10.2	10.2	10.2	10.2	
15.	2043	Anyatpura	132	0.0	29.2	32.6	36.1	39.2	42.2	44.9	47.5	50.1	52.8	55.5	
16.	2076	Askari XIB&C(	132	0.0	0.0	0.0	3.7	8.0	12.8	17.9	23.2	28.5	33.8	39.2	
17.	1041	Askari- X	132	0.0	0.0	31.2	35.2	38.8	42.3	45.5	48.6	51.7	54.9	58.1	
18.	6	Attabad	132	71.4	76.7	82.4	87.3	91.1	94.3	96.7	98.3	99.9	76.3	77.6	
19.	983	Audit & Accou	132	0.0	0.0	0.0	7.2	9.6	12.1	14.6	17.0	19.5	22.0	24.5	
20.	912	Aysha	132	55.9	59.5	63.1	67.0	69.9	72.5	74.6	76.3	78.0	79.8	81.6	
21.	1025	BROTHER POWER	132	1.7	1.8	1.9	2.0	2.0	2.1	2.1	2.1	2.2	2.2	2.2	
22.	233	Badami Bagh	132	71.0	76.4	76.3	81.1	79.0	82.1	67.7	69.4	71.0	72.7	74.4	
23.	1047	Baggrian	132	0.0	0.0	0.0	0.0	0.0	59.3	60.6	61.5	62.5	63.5	64.4	
24.	2051	Baghbanpura	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	55.7	56.8	57.9	59.1	
25.	2008	Bahria Archer	132	0.0	0.0	0.0	3.5	5.5	7.5	9.5	11.5	13.5	15.5	17.5	

## POWER MARKET SURVEY

: LOAD CENTRE SUMMARY  
MAXIMUM DEMAND (MW) OF GRIDSTATIONS

DISCO: LESCO

GRID	NAME OF	KV	LOAD CENTRE SUMMARY											
			2013-14	2014-15	2015-16	2016-17	2017-18	Y	E	A	R	2019-20	2020-21	2021-22
NO.	GRIDSTATION													
26.	994 Bahria Town	132	13.5	16.5	19.5	21.0	22.5	24.0	25.6	27.2	29.0	30.9	32.9	
27.	1061 Bakkar Mandi	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	45.4	47.2	48.9	50.7	
28.	650 Barkat Textil	132	8.9	11.0	11.0	11.0	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1
29.	2091 Bashir Steel	132	0.0	0.0	0.0	0.0	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5
30.	13 Batapur	132	80.4	77.1	83.0	71.3	74.9	78.2	80.9	83.4	85.8	88.3	90.8	
31.	2031 Bhadarpura	132	0.0	0.0	0.0	0.0	44.7	46.1	47.4	48.4	49.5	50.7	51.8	
32.	15 Bhai Pheru	132	109.8	117.4	127.8	135.7	113.6	117.4	120.3	122.5	124.7	127.0	129.3	
33.	711 Bhati Gate	132	86.5	77.3	81.6	85.9	89.2	92.1	94.4	96.3	73.9	75.4	77.0	
34.	2068 Bhenro K.R.K	132	0.0	0.0	0.0	0.0	5.7	5.7	5.7	5.7	5.7	5.7	5.7	
35.	871 Bhikki	132	79.1	88.4	98.4	110.5	115.2	106.7	109.8	111.9	114.1	116.3	118.6	
36.	916 Black Gold	132	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	
37.	1096 Blessed	132	16.6	16.6	16.6	16.6	16.6	16.6	16.6	16.6	16.6	16.6	16.6	
38.	617 Boggiwal	132	132.1	149.3	161.8	164.4	171.1	141.8	137.8	140.4	142.9	145.5	148.2	
39.	18 Bongha Hayat	132	12.3	13.1	13.8	14.7	15.2	15.6	15.9	16.2	16.4	16.7	16.9	
40.	965 Broadway	132	0.0	0.0	6.9	11.1	15.5	19.9	24.2	28.4	32.6	36.8	41.2	
41.	20 Bucheki	132	35.9	37.6	40.2	43.1	45.2	47.1	48.7	50.0	51.4	52.9	54.3	
42.	981 Central Park	132	0.0	0.0	15.3	18.6	21.8	24.9	27.9	30.8	33.8	36.7	39.8	
43.	651 Century Paper	132	10.0	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	
44.	23 Chah Miran	132	89.0	95.0	100.2	105.6	82.6	85.4	87.6	89.5	91.5	93.5	95.6	
45.	1018 Chak 40/D	132	0.0	0.0	0.0	0.0	0.0	56.2	58.5	60.5	62.5	64.5	66.6	
46.	800 Chak-65	132	76.6	80.5	86.5	92.1	96.5	100.3	103.2	105.2	107.2	86.0	87.7	
47.	1072 Chaurasta	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	46.4	48.3	50.2	52.1	
48.	2012 Chichoke Mall	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16.5	17.8	
49.	986 Chinar Bagh	132	0.0	0.0	0.0	0.0	0.0	0.0	20.6	20.9	22.6	24.3	26.1	
50.	1071 Chucak	132	0.0	36.3	39.0	41.7	43.7	45.6	47.2	48.7	50.2	51.8	53.4	

## POWER MARKET SURVEY

:

LOAD CENTRE SUMMARY  
MAXIMUM DEMAND (MW) OF GRIDSTATIONS

DISCO: LESCO

GRID NO.	NAME OF GRIDSTATION	KV	CENTRE AVERAGE										
			2013-14	2014-15	2015-16	2016-17	2017-18	2018-19	2019-20	2020-21	2021-22	2022-23	2023-24
51.	30 Chung	132	109.4	119.1	109.6	117.8	124.4	131.9	110.2	113.2	93.9	96.7	99.4
52.	254 Chunian	132	39.6	41.7	44.7	48.0	50.4	52.6	54.5	56.2	57.9	59.6	61.4
53.	960 City Steel SK	132	9.7	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8	18.8
54.	1048 Coca Cola	132	12.5	17.9	17.9	17.9	17.9	17.9	17.9	17.9	17.9	17.9	17.9
55.	999 Colony Indust	132	9.3	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1
56.	2099 DHA Ph-VII-4(	132	0.0	0.0	0.0	0.0	0.0	7.9	13.3	18.5	23.9	29.2	34.7
57.	2084 DHA Phase IX	132	0.0	0.0	0.0	0.0	8.0	12.8	17.5	22.3	27.2	32.1	37.0
58.	1032 DHA Rahber	132	0.0	0.0	5.5	8.7	11.9	15.0	18.2	21.3	24.4	27.7	30.9
59.	991 DHA- Ph. V	132	35.6	40.7	45.7	50.9	55.4	59.8	63.8	67.7	71.6	75.6	79.6
60.	980 DHA-P-VI-3	132	0.0	0.0	31.3	36.4	41.1	45.8	50.1	54.4	58.7	63.1	67.5
61.	2049 DHA-P-VI.2Der	132	0.0	0.0	0.0	9.2	14.0	18.8	23.6	28.4	33.2	38.1	43.1
62.	2097 DHAPh-VIIAdd.	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.8	9.6	14.5	19.5
63.	2096 DHAPh-VIII(T-	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.6	11.3	17.0
64.	2095 DHAPh-VIII(V-	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.4	8.8	13.3	17.8
65.	1003 Daroghwala	132	61.8	50.7	54.4	58.2	61.3	64.1	66.4	68.2	70.1	72.0	73.9
66.	426 Defence	132	105.4	113.2	120.2	127.6	126.1	132.7	132.4	86.6	89.3	91.9	94.6
67.	992 Defence XXY	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	49.2	49.9	50.7	51.5
68.	265 Depalpur	132	100.0	106.7	114.2	122.4	128.5	117.4	121.3	110.5	113.7	101.9	105.0
69.	979 Descon Oxy.	132	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1
70.	2058 Dew Kalan	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10.4	10.8	11.1
71.	1036 Diamond Fabri	132	10.6	10.6	10.6	10.6	10.6	10.6	10.6	10.6	10.6	10.6	10.6
72.	2082 Dina Nath	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	27.0	27.4
73.	1030 Dost Steel	132	0.0	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1
74.	2066 EME	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11.6	15.6	19.6
75.	987 Eden City	132	0.0	0.0	0.0	8.1	9.7	12.3	14.7	17.1	19.6	22.1	24.6

## POWER MARKET SURVEY

:

LOAD CENTRE SUMMARY  
MAXIMUM DEMAND (MW) OF GRIDSTATIONS

DISCO: LESCO

GRID	NAME OF				2013-14	2014-15	2015-16	2016-17	2017-18	Y	E	A	R			
NO.	GRIDSTATION	KV								2018-19	2019-20	2020-21	2021-22	2022-23	2023-24	
76.	2063 Eden Value Ho	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15.4	17.4	19.4	21.5	23.5		
77.	2041 Ejaz Textile	132	0.0	0.0	0.0	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	
78.	506 Elahabad	132	51.8	54.2	57.9	61.8	64.6	67.0	69.0	70.7	72.4	74.2	76.0			
79.	2075 EllcotSpinnin	132	0.0	0.0	0.0	0.0	0.0	0.0	6.8	6.8	6.8	6.8	6.8	6.8	6.8	
80.	2098 Emporium Mall	132	0.0	0.0	3.9	6.2	8.7	11.1	13.5	13.7	13.9	14.1	14.3			
81.	271 Farooqabad	132	72.5	79.0	81.6	88.4	93.7	81.1	85.0	88.8	92.6	96.4	100.3			
82.	38 Fateh Garh	132	117.7	115.4	122.2	104.9	109.3	113.6	103.3	106.1	109.0	111.8	114.7			
83.	982 Fazzia	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.1	9.5	12.7	16.0	19.3		
84.	2094 Fazzia-2	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.2	8.8	12.3		
85.	1028 Ferozepur Roa	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	48.7	49.4	50.2	51.0	51.8		
86.	40 Fort	132	59.0	62.8	34.5	36.5	38.0	39.3	40.4	41.3	42.2	43.1	44.1			
87.	2059 Fruit Mandi	132	0.0	0.0	0.0	44.9	47.1	49.1	50.7	51.9	53.2	54.5	55.8			
88.	43 Garden Town	132	133.7	143.0	138.1	146.6	153.2	159.2	116.3	119.3	122.4	125.4	128.5			
89.	2069 Ghani Gases	132	0.0	0.0	0.0	0.0	0.0	0.0	13.1	13.1	13.1	13.1	13.1			
90.	45 Ghazi	132	133.2	148.3	102.0	96.0	84.6	88.2	91.2	93.9	82.6	85.1	87.7			
91.	652 Ghazi Fabirc	132	9.7	9.7	9.7	9.7	9.7	9.7	9.7	9.7	9.7	9.7	9.7			
92.	507 Green View	132	103.6	110.8	117.5	133.9	135.7	115.3	94.6	96.2	97.9	99.6	101.3			
93.	997 Gulberg Lahor	132	0.0	0.0	0.0	0.0	0.0	0.0	60.2	61.2	62.1	63.1	64.0			
94.	429 Gulshan Ravi	132	90.1	82.3	87.7	93.3	97.7	78.2	80.5	82.6	84.7	86.9	89.0			
95.	2086 Hadeed Pakist	132	0.0	0.0	0.0	0.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0			
96.	1092 Hadyara	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	14.1	14.3	14.5			
97.	2057 Hanjarwal	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	39.4	40.7			
98.	60 Havali	132	76.3	80.8	87.0	93.5	98.2	102.4	106.1	97.5	100.7	104.0	107.3			
99.	985 Hira Terry	132	27.0	30.6	30.6	30.6	30.6	23.8	23.8	23.8	23.8	23.8	23.8			
100.	287 Hujra	132	54.0	59.1	64.7	70.7	63.9	68.0	71.7	75.3	78.8	82.4	86.1			

## POWER MARKET SURVEY

:

LOAD CENTRE SUMMARY  
MAXIMUM DEMAND (MW) OF GRIDSTATIONS

DISCO: LESCO

GRID NO.	NAME OF GRIDSTATION	KV	Y E A R										
			2013-14	2014-15	2015-16	2016-17	2017-18	2018-19	2019-20	2020-21	2021-22	2022-23	2023-24
101.	753 ICI	132	57.8	58.3	61.4	64.8	67.5	63.8	65.4	66.5	67.5	68.5	69.6
102.	2061 IEEP Town	132	0.0	0.0	0.0	4.7	5.3	6.6	8.2	9.9	11.6	13.3	15.0
103.	2064 Indus Home	132	0.0	0.0	0.0	6.4	12.5	12.5	12.5	12.5	12.5	12.5	12.5
104.	66 Ittahad Chemi	132	40.8	40.8	40.8	40.8	40.8	40.8	40.8	40.8	40.8	40.8	40.8
105.	2028 Jail Road	132	0.0	0.0	0.0	0.0	0.0	0.0	30.7	31.2	31.7	32.2	32.7
106.	952 Jamber	132	0.0	0.0	0.0	0.0	51.8	54.0	55.8	57.4	58.9	60.5	62.2
107.	1029 Jandiala S.Kh	132	0.0	0.0	16.8	18.9	20.7	22.4	24.0	25.6	27.1	28.7	30.3
108.	782 Johar Town	132	137.9	116.9	124.9	133.3	141.3	140.3	109.0	112.6	116.2	119.9	123.6
109.	957 Johar Town-II	132	0.0	33.2	36.7	40.3	43.4	46.5	49.2	51.9	54.5	57.2	59.9
110.	1019 Jubli Town	132	0.0	0.0	20.8	24.6	28.1	31.6	34.8	38.0	41.2	44.4	47.7
111.	977 K.E. Medical	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.0	9.2	10.4	11.6
112.	82 K.Lakhpat.Old	132	111.4	119.6	126.8	134.4	114.5	118.5	106.7	109.0	111.3	113.7	116.1
113.	2044 Kala Khatai	132	0.0	0.0	0.0	0.0	0.0	0.0	22.0	22.6	23.2	23.7	24.3
114.	1026 Kamran Steel	132	0.0	0.0	8.5	8.5	8.5	8.5	8.5	8.5	8.5	8.5	8.5
115.	2000 Karol	132	0.0	0.0	0.0	0.0	0.0	55.6	57.5	58.9	60.4	61.9	63.5
116.	2055 Kashmir Colon	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.5	7.3	
117.	99 Kasur	132	88.3	93.8	100.4	107.4	59.6	61.9	63.7	65.3	67.0	68.6	70.3
118.	1020 Kasur New	132	57.9	61.9	65.6	69.4	72.2	74.7	76.7	78.4	80.3	82.1	83.9
119.	1015 Kasur-II	132	0.0	0.0	0.0	0.0	8.4	9.3	10.2	11.0	11.8	12.7	13.6
120.	1044 Khana Nau	132	73.6	80.7	86.3	68.1	71.8	75.2	77.9	72.3	74.5	76.8	79.1
121.	647 Khanqa Dogran	132	34.0	37.4	41.4	45.5	49.0	52.3	55.2	58.0	40.3	42.3	44.3
122.	2046 Khay. Amin	132	0.0	0.0	0.0	0.0	8.7	11.5	14.3	17.1	20.0	22.9	25.8
123.	1093 Khokkar Road	132	0.0	0.0	0.0	0.0	0.0	0.0	33.4	34.0	34.5	35.0	35.6
124.	310 Khuddian	132	83.9	88.2	94.0	100.2	104.4	73.0	75.0	76.8	78.7	80.6	82.4
125.	850 Kot Radha Kis	132	36.6	38.6	41.3	44.1	46.3	48.4	50.1	51.7	53.4	55.0	56.7

## POWER MARKET SURVEY

:

LOAD CENTRE SUMMARY  
MAXIMUM DEMAND (MW) OF GRIDSTATIONS

DISCO: LESCO

GRID NO.	NAME OF GRIDSTATION	KV	2013-14	2014-15	2015-16	2016-17	2017-18	Y 2018-19	E 2019-20	A 2020-21	R 2021-22	2022-23	2023-24
126.	984 LDA Ave-I	132	0.0	7.1	10.2	13.4	16.4	19.4	22.4	25.3	28.3	31.3	34.4
127.	121 LEFO	132	70.9	66.2	73.7	81.6	88.5	95.2	67.7	69.3	71.0	72.7	74.4
128.	2067 LHR SKP Road	132	0.0	0.0	0.0	0.0	0.0	0.0	24.1	32.0	32.9	33.7	34.6
129.	1009 LUMS	132	2.1	3.2	4.4	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6
130.	949 Lahore Cantt	132	57.8	62.4	66.5	70.9	74.3	77.5	80.0	82.2	84.5	86.7	89.0
131.	2047 Lake City	132	0.0	0.0	0.0	0.0	0.0	13.5	18.1	22.7	27.3	31.9	36.6
132.	314 Lalyani	132	46.8	51.6	42.1	45.0	47.2	49.3	50.9	52.3	53.7	55.1	56.5
133.	954 M.A.Abad	132	0.0	0.0	27.5	30.1	32.2	34.1	35.8	37.4	39.1	40.8	42.6
134.	953 M.Usmanwala	132	0.0	0.0	0.0	0.0	0.0	39.9	41.0	42.0	43.0	44.0	45.0
135.	1027 Machikay	132	0.0	0.0	0.0	0.0	0.0	51.4	53.5	55.4	57.4	59.4	61.5
136.	2102 Makhdoom/Doul	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15.0	15.2
137.	951 Malik Paper	132	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0
138.	2093 Mandali Pape	132	0.0	0.0	0.0	0.0	0.0	8.0	8.0	8.0	8.0	8.0	8.0
139.	411 Manga Mandi	132	78.1	84.0	89.1	87.6	91.3	94.5	96.9	98.7	79.2	65.2	66.6
140.	2056 Manga-II	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	39.0	39.9
141.	1034 Master Textil	132	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5
142.	583 Mcleod Road	132	69.8	74.6	79.3	84.2	88.1	91.7	94.4	96.6	98.8	82.5	84.4
143.	2052 Mehmood Steel	132	0.0	0.0	0.0	0.0	6.3	6.3	6.3	6.3	6.3	6.3	6.3
144.	998 Mobile	132	22.3	23.7	25.0	26.3	27.3	28.2	28.8	29.2	29.7	30.2	30.6
145.	710 Mochi Gate	132	47.4	50.9	54.2	57.6	60.2	62.7	64.7	66.4	68.2	69.9	71.7
146.	504 Model Town	132	107.0	115.4	105.1	112.3	118.0	123.3	127.6	111.0	113.6	116.3	119.0
147.	2050 ModelTownSoci	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	20.4	21.6	22.9	24.1
148.	1040 Momanpura G.T	132	0.0	40.6	44.1	47.9	51.0	53.9	56.4	58.7	61.0	63.4	65.8
149.	2072 Mughal Alloya	132	0.0	0.0	0.0	0.0	26.5	26.5	26.5	26.5	26.5	26.5	26.5
150.	1073 Mughal Steel	132	24.9	24.9	35.7	54.7	54.7	54.7	54.7	54.7	54.7	54.7	54.7

## POWER MARKET SURVEY

:

LOAD CENTRE SUMMARY  
MAXIMUM DEMAND (MW) OF GRIDSTATIONS

DISCO: LESCO

GRID NO.	NAME OF GRIDSTATION	KV	Y E A R											
			2013-14	2014-15	2015-16	2016-17	2017-18	2018-19	2019-20	2020-21	2021-22	2022-23	2023-24	
151.	679 Muhammad Bukh	132	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	
152.	964 Muridke	132	0.0	40.0	43.6	46.7	49.2	51.6	53.5	55.2	57.0	58.8	60.6	
153.	1037 Mustafabad	132	0.0	0.0	0.0	0.0	0.0	0.0	33.8	34.4	34.9	35.4	36.0	
154.	2024 Nain Sukh	132	0.0	0.0	0.0	0.0	0.0	0.0	23.5	23.9	24.3	24.6	25.0	
155.	520 Nankana	132	40.5	46.7	52.9	59.4	65.1	70.6	75.6	80.5	85.3	90.3	95.3	
156.	336 Narang Mandi	132	21.3	22.9	25.0	27.2	28.9	30.7	32.2	33.6	35.1	36.5	38.0	
157.	2074 Naveena Expor	132	0.0	5.4	5.4	5.4	5.4	9.0	9.0	9.0	9.0	9.0	9.0	
158.	866 New Airport	132	11.6	14.8	18.1	18.1	18.1	18.1	18.1	18.1	18.1	18.1	18.1	
159.	1074 New Smr St.2	132	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	
160.	996 New Smr St.3	132	0.0	0.0	0.0	7.2	12.4	12.4	12.4	12.4	12.4	12.4	12.4	
161.	989 Niazi Chowk	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	54.6	55.4	56.3	
162.	2007 Nisar Spinnin	132	0.0	0.0	0.0	0.0	0.0	6.9	6.9	6.9	6.9	6.9	6.9	
163.	1083 Nishat Chunia	132	28.0	28.9	28.9	28.9	28.9	28.9	28.9	28.9	28.9	28.9	28.9	
164.	2080 Nishat Mills	132	0.0	0.0	0.0	0.0	0.0	12.4	12.4	12.4	12.4	12.4	12.4	
165.	2054 OFF Lahore	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.3	8.1	11.0	
166.	338 Okara Cantt	132	22.8	24.5	26.0	27.6	28.7	29.8	30.6	31.3	32.1	32.8	33.6	
167.	152 Okara City-I	132	87.0	92.4	99.1	106.9	113.2	79.3	82.7	85.8	88.9	92.1	95.3	
168.	849 Okara City-II	132	69.1	76.0	85.7	94.5	102.1	109.4	89.3	93.7	98.1	102.6	107.2	
169.	1002 OkaraFSDRd	132	0.0	0.0	0.0	0.0	0.0	0.0	36.9	38.8	40.8	42.8	44.8	
170.	153 P.W.R	132	92.3	98.5	104.1	109.9	114.1	118.1	100.7	75.4	77.2	79.0	80.8	
171.	2088 PAEC Mraka	132	0.0	0.0	0.0	0.0	1.8	3.7	5.5	6.5	7.6	8.6	9.6	
172.	654 Packages	132	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	
173.	946 Packages Kasu	132	24.6	24.6	24.6	30.6	30.6	30.6	30.6	30.6	30.6	30.6	30.6	
174.	2053 Pak Arab	132	0.0	0.0	0.0	0.0	0.0	0.0	36.7	40.7	44.8	49.0	53.2	
175.	2017 Panwan	132	0.0	0.0	0.0	0.0	31.2	32.4	33.3	34.2	35.0	35.9	36.8	

## POWER MARKET SURVEY

:

LOAD CENTRE SUMMARY  
MAXIMUM DEMAND (MW) OF GRIDSTATIONS

DISCO: LESCO

GRID NO.	NAME OF GRIDSTATION	KV	Y										
			2013-14	2014-15	2015-16	2016-17	2017-18	2018-19	2019-20	2020-21	2021-22	2022-23	2023-24
176.	2089 Paragon H/S	132	0.0	0.0	0.0	8.0	9.6	12.1	14.6	17.0	19.4	21.9	24.4
177.	1082 Park View	132	0.0	0.0	0.0	0.0	26.5	30.8	34.9	38.9	43.0	47.1	51.3
178.	158 Pattoki	132	68.3	61.3	65.8	70.5	50.1	52.4	54.3	56.1	57.9	59.7	61.6
179.	2036 Press Club	132	0.0	0.0	0.0	41.7	42.9	46.4	49.5	52.6	55.7	58.7	61.9
180.	993 Punjab Assemb	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	44.7	45.4
181.	1043 Punjab Uni	132	0.0	0.0	50.9	54.3	56.8	59.2	61.1	62.8	64.5	66.2	67.9
182.	958 Punjab UnivTow	132	0.0	16.6	17.5	18.4	19.1	21.5	23.7	25.8	27.9	30.0	32.1
183.	168 Qadirabad	132	11.4	12.1	12.7	13.4	13.9	14.4	14.7	14.9	15.1	15.4	15.6
184.	167 Qartaba	132	69.3	74.3	78.7	83.4	87.0	90.2	92.8	95.0	82.7	84.7	86.8
185.	1080 Qila Sattar S	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	25.2	25.6
186.	1085 Quetta Textil	132	12.5	16.4	16.4	16.4	16.4	16.4	16.4	16.4	16.4	16.4	16.4
187.	1090 Rachna Town	132	0.0	0.0	0.0	0.0	45.4	48.0	50.3	52.5	54.7	56.9	59.1
188.	353 Raiwind	132	99.4	107.7	117.8	125.8	132.3	91.0	74.0	76.8	79.6	82.4	85.3
189.	1016 Raiwind New	132	42.8	46.7	49.9	53.3	56.0	58.3	60.2	61.4	62.7	64.0	65.4
190.	956 Raiwind-III	132	0.0	0.0	0.0	0.0	0.0	40.2	41.5	42.4	43.4	44.3	45.3
191.	175 Rehman Park	132	82.0	87.6	92.9	98.6	103.2	107.2	63.6	65.2	66.9	68.6	70.3
192.	2071 Rehman Steel	132	0.0	0.0	0.0	0.0	0.0	0.0	7.4	7.4	7.4	7.4	7.4
193.	929 Rehmat Nazir	132	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6
194.	2079 Reliance Cott	132	0.0	0.0	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1
195.	176 Renala Khurd	132	50.8	41.8	45.1	48.4	38.3	40.5	42.4	44.3	46.2	48.1	50.0
196.	357 Rewaz Garden	132	86.8	70.6	74.8	79.2	82.4	85.4	87.8	89.8	91.8	93.9	96.0
197.	2005 Riaz Textile	132	0.0	0.0	0.0	8.6	8.6	8.6	8.6	8.6	8.6	8.6	8.6
198.	2020 Roya Golf Clu	132	0.0	6.0	8.0	10.0	12.0	14.0	16.0	18.0	20.0	22.0	24.0
199.	412 Rustam	132	89.7	95.6	101.2	106.9	111.2	115.1	94.5	96.6	98.6	100.7	102.9
200.	902 SKP-Industria	132	28.6	33.0	24.9	27.8	30.4	33.0	35.3	37.5	39.7	42.0	44.3

## POWER MARKET SURVEY

:

LOAD CENTRE SUMMARY  
MAXIMUM DEMAND (MW) OF GRIDSTATIONS

DISCO: LESCO

GRID NO.	NAME OF GRIDSTATION	KV	Y E A R										
			2013-14	2014-15	2015-16	2016-17	2017-18	2018-19	2019-20	2020-21	2021-22	2022-23	2023-24
201.	950 Sabzazar	132	75.7	81.4	86.4	91.6	95.4	99.6	103.0	82.2	84.5	86.8	89.2
202.	540 Sadar Gogera	132	40.1	42.7	46.1	49.6	52.3	54.9	46.7	48.6	50.5	52.3	54.3
203.	973 Safdarabad	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	21.2	22.1	23.0
204.	969 Saggian	132	0.0	51.8	54.9	58.1	60.5	62.8	64.6	66.1	67.6	69.2	70.8
205.	184 Saidpur	132	97.2	104.0	109.8	116.0	120.4	124.6	127.7	130.4	133.3	115.5	118.0
206.	1060 Sanda	132	0.0	0.0	0.0	0.0	0.0	23.6	24.6	25.5	26.4	27.3	28.3
207.	362 Sangla Hill	132	19.6	21.3	23.4	25.6	27.4	29.2	30.7	32.3	33.8	35.4	37.0
208.	1087 Sapphire -3	132	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8
209.	1066 Sapphire -5	132	12.8	17.9	17.9	17.9	17.9	17.9	17.9	17.9	17.9	17.9	17.9
210.	2077 Sapphire F (1	132	0.0	0.0	0.0	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
211.	1022 SapphireFinis	132	7.6	7.6	7.6	7.6	7.6	7.6	7.6	7.6	7.6	7.6	7.6
212.	191 Shadman	132	73.1	78.2	83.0	87.9	91.7	95.2	67.2	69.0	70.8	72.6	74.5
213.	369 Shahdara New	132	98.6	106.8	114.7	122.9	96.9	100.8	87.6	89.7	91.8	94.0	96.2
214.	505 Shahdara Scar	132	21.7	23.1	24.3	25.6	26.4	27.2	22.1	22.4	22.8	23.1	23.5
215.	193 Shahkot	132	76.5	82.4	89.1	95.8	75.2	79.2	82.4	85.3	88.2	91.2	94.2
216.	1010 Shalamar Stee	132	0.0	0.0	0.0	8.5	8.5	8.5	8.5	8.5	8.5	8.5	8.5
217.	194 Shalamar-I	132	81.6	90.2	96.2	102.4	107.3	91.2	93.6	95.5	97.5	99.4	101.4
218.	893 Shalamar-II	132	81.1	86.8	91.6	96.7	100.4	103.8	106.4	80.2	81.7	83.2	84.7
219.	508 Shamky	132	93.3	98.3	104.4	110.8	103.0	106.9	110.0	112.1	114.2	116.4	118.6
220.	372 Sharqpur	132	36.1	37.8	40.1	42.5	44.3	46.0	47.2	48.4	49.5	50.6	51.8
221.	897 Sharqpur Rd.	132	27.9	34.0	36.4	39.0	41.1	42.9	44.4	45.7	47.0	48.2	49.6
222.	971 Sheranwala	132	0.0	0.0	36.7	38.7	40.2	41.6	42.5	43.2	43.8	44.5	45.2
223.	988 Shergarh	132	0.0	0.0	0.0	0.0	24.3	25.0	25.5	25.9	26.3	26.7	27.1
224.	2065 Shoib Steel	132	0.0	0.0	0.0	0.0	0.0	10.6	10.6	10.6	10.6	10.6	10.6
225.	197 Skp. City	132	77.4	85.4	96.6	97.5	104.4	77.4	81.5	85.4	89.2	93.2	97.1

## POWER MARKET SURVEY

:

LOAD CENTRE SUMMARY  
MAXIMUM DEMAND (MW) OF GRIDSTATIONS

DISCO: LESCO

GRID	NAME OF			LOAD	CENTRE	SUMMARY													
NO.	GRIDSTATION	KV	2013-14	2014-15	2015-16	2016-17	2017-18	Y	E	A	R								
226.	2060 Spring Meadows	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.5	6.0	7.4	8.9					
227.	2087 Style Textile	132	0.0	0.0	0.0	0.0	5.7	5.7	5.7	5.7	5.7	5.7	5.7	5.7					
228.	2048 Sui Gas	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.6	7.2	8.8	10.3	11.9					
229.	2103 Sui Gas-2	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.0	4.1	6.1					
230.	1050 Sukh Chain	132	17.7	15.1	18.0	21.0	23.8	26.6	29.1	31.5	33.9	36.4	38.9						
231.	380 Sukheki	132	1.0	1.1	1.1	1.2	1.2	1.2	1.3	1.3	0.6	0.7	0.7						
232.	2018 Sunder Manga	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	34.9	35.4	36.0						
233.	1007 Sunder( Ind.	132	46.1	62.1	78.1	78.1	78.1	78.1	78.1	78.1	78.1	78.1	78.1						
234.	206 Sunny View	132	56.2	59.9	63.3	66.9	69.8	72.3	74.2	75.8	77.3	52.8	54.0						
235.	2090 TanveerCotton	132	0.0	0.0	0.0	0.0	0.0	7.8	7.8	7.8	7.8	7.8	7.8						
236.	2100 Tariq Garden	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.8	6.6	9.3						
237.	2078 Tariq Glass	132	0.0	0.0	0.0	0.0	0.0	9.8	9.8	9.8	9.8	9.8	9.8						
238.	2014 Tech Society	132	0.0	0.0	0.0	0.0	0.0	8.4	9.9	11.3	12.8	14.3	15.8						
239.	1084 Thokkar	132	0.0	0.0	0.0	0.0	0.0	0.0	48.9	50.2	51.6	52.9	54.4						
240.	428 Town Ship	132	126.9	136.9	145.2	153.9	160.5	128.6	132.2	135.3	138.4	141.6	144.8						
241.	2101 UET	132	0.0	0.0	0.0	0.0	0.0	0.0	4.5	6.7	9.0	11.3	13.5						
242.	2070 Uni Lever	132	0.0	0.0	0.0	0.0	6.9	6.9	6.9	6.9	6.9	6.9	6.9						
243.	963 Valancia	132	0.0	0.0	0.0	9.8	10.1	14.4	18.6	22.9	27.2	31.6	35.9						
244.	826 Valgon Sohial	132	56.2	61.0	65.1	60.9	64.5	67.7	70.4	72.7	75.0	77.3	79.7						
245.	221 W.Radha Ram	132	45.4	36.8	41.0	43.4	45.2	46.8	48.0	49.1	50.2	51.3	52.5						
246.	959 Walton Road	132	0.0	0.0	0.0	0.0	55.2	57.4	59.1	60.7	62.3	63.9	65.6						
247.	2092 Wapda Town Sk	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.9	9.8	14.8						
248.	401 Warburton	132	55.1	64.4	62.0	66.9	70.9	66.9	70.1	73.0	76.0	79.0	82.0						
249.	970 Wassanpura	132	0.0	0.0	0.0	0.0	32.7	33.6	34.3	34.8	35.4	35.9	36.5						
250.	781 Willongton Ma	132	86.3	92.5	97.8	103.5	77.8	80.8	83.2	85.2	87.3	89.5	91.6						

## POWER MARKET SURVEY

:

LOAD CENTRE SUMMARY  
MAXIMUM DEMAND (MW) OF GRIDSTATIONS

DISCO: LESCO

GRID NO.	NAME OF GRIDSTATION	KV	2013-14	2014-15	2015-16	2016-17	2017-18	Y 2018-19	E 2019-20	A 2020-21	R 2021-22	2022-23	2023-24
251. 1012	Yaqoob Steel	132	0.0	16.1	16.1	16.1	16.1	16.1	16.1	16.1	16.1	16.1	16.1
252. 658	Zahoor.Textil	132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
253. 229	Ali Jaj	66	25.6	28.1	31.3	34.7	37.6	40.3	42.8	45.2	47.5	49.9	52.4
254. 241	Basirpur	66	41.8	47.2	41.8	46.6	50.5	54.1	57.6	40.7	42.7	44.6	46.6
255. 270	EMCO	66	40.1	46.5	39.4	33.7	34.8	27.7	28.4	21.7	22.1	22.4	22.8
256. 303	Kanganpur	66	34.7	37.1	23.4	25.1	26.2	22.4	23.2	24.0	24.7	25.5	26.3
257. 320	Malikpur	66	25.7	31.0	36.2	41.7	46.6	51.5	56.1	60.6	65.2	69.8	74.4
258. 330	Mohlan	66	13.3	14.8	16.2	17.6	13.4	14.4	15.3	16.2	17.1	18.0	18.9
259. 399	UIS	66	13.6	14.7	15.6	16.5	17.3	17.9	18.3	18.6	18.9	19.2	19.5
260. 447	Chichoke Mall	11	10.7	11.4	12.0	12.6	13.1	13.4	13.7	13.9	14.2	14.4	14.6
261. 1099	Gulistan P/H	11	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
262. 659	Renala P/H	11	1.9	2.0	2.1	2.2	2.2	2.3	2.3	2.4	2.4	2.4	2.5
<b>Total L.C.</b>			<b>6912.9</b>	<b>7565.1</b>	<b>8148.8</b>	<b>8758.1</b>	<b>9296.2</b>	<b>9766.5</b>	<b>10160.3</b>	<b>10531.2</b>	<b>10931.1</b>	<b>11336.7</b>	<b>11746.9</b>

**Table 1-18: Category-wise Maximum Demand (MW) of Substations**

## POWER MARKET SURVEY

## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO

Year :2023-24

SR GRID  NO. NUMBER	NAME OF GRID STATION	DOMESTIC	COMMERCIAL	PUBLIC LIGHTING	SMALL INDUSTRIES	M & L INDUSTRIES	TUBE WELLS PRIVATE	PUBLIC	TRACTION	TOTAL OF GRIDSTATION	POWER FACTOR(%) REACT-POWER(Mvar)
1. 1	132kV A.I.Town	GWh 191.26	30.89	4.32	3.35	4.00	9.79	0.00	0.00	243.60	0.89
		MW 62.38	11.75	1.64	1.43	13.40	2.61	0.00	0.00	69.91	36.00
2. 1000	132kV A.I.Town-II	GWh 109.87	26.76	6.42	1.59	0.70	6.19	0.00	0.00	151.53	0.89
		MW 35.83	10.18	2.44	0.68	9.54	1.65	0.00	0.00	45.25	23.00
3. 1008	132kV AWT	GWh 53.68	14.17	0.12	2.88	19.51	1.17	0.00	0.00	91.52	0.86
		MW 17.51	5.39	0.05	1.23	16.48	0.31	0.00	0.00	30.72	18.00
4. 2083	132kV AirAvenue(Ph-VI	GWh 58.31	12.02	0.00	0.00	0.00	0.25	0.00	0.00	70.58	0.90
		MW 19.02	4.57	0.00	0.00	0.00	0.07	0.00	0.00	17.74	9.00
5. 2073	132kV Al Bashir Steel	GWh 0.00	0.00	0.00	0.00	25.25	0.00	0.00	0.00	25.25	0.90
		MW 0.00	0.00	0.00	0.00	14.11	0.00	0.00	0.00	14.11	7.00
6. 931	132kV Al- Shafi	GWh 0.00	0.00	0.00	0.00	59.97	0.00	0.00	0.00	59.97	0.90
		MW 0.00	0.00	0.00	0.00	17.72	0.00	0.00	0.00	17.72	9.00
7. 2015	132kV Ali Asia Steel	GWh 0.00	0.00	0.00	0.00	12.70	0.00	0.00	0.00	12.70	0.90
		MW 0.00	0.00	0.00	0.00	6.30	0.00	0.00	0.00	6.30	3.00
8. 229	66kV Ali Jaj	GWh 67.89	3.27	0.00	3.29	1.22	42.60	0.00	0.00	118.27	0.83
		MW 29.45	1.44	0.00	1.33	18.62	10.78	0.00	0.00	52.38	35.00
9. 1021	132kV AmirSapphireKni	GWh 0.32	0.00	0.00	0.00	49.51	0.00	0.00	0.00	49.82	0.90
		MW 0.10	0.00	0.00	0.00	10.12	0.00	0.00	0.00	10.22	5.00
10. 2043	132kV Anyatpura	GWh 159.88	20.61	1.21	7.58	17.41	3.21	0.00	0.00	209.92	0.89
		MW 52.15	7.84	0.46	3.23	9.47	0.86	0.00	0.00	55.51	28.00
11. 2076	132kV Askari XIB&C(Sh	GWh 134.84	12.68	1.71	1.25	0.00	8.52	0.00	0.00	158.99	0.89
		MW 43.98	4.82	0.65	0.53	0.00	2.27	0.00	0.00	39.19	20.00
12. 1041	132kV Askari- X	GWh 168.48	21.60	2.88	1.45	7.00	3.36	0.00	0.00	204.77	0.90
		MW 54.95	8.22	1.10	0.62	11.66	0.89	0.00	0.00	58.08	28.00
13. 6	132kV Attabad	GWh 7.57	2.41	0.00	1.02	332.23	3.02	0.00	0.00	346.26	0.90
		MW 3.46	1.38	0.00	0.43	85.20	0.81	0.00	0.00	77.58	38.00
14. 983	132kV Audit & Account	GWh 75.92	16.56	0.01	2.14	0.00	2.62	0.00	0.00	97.25	0.90
		MW 24.76	6.30	0.01	0.91	0.00	0.70	0.00	0.00	24.51	12.00
15. 912	132kV Aysha	GWh 152.61	22.96	-0.22	13.07	167.44	18.86	0.00	0.00	374.73	0.87
		MW 47.46	8.34	-0.08	5.29	42.93	4.77	0.00	0.00	81.61	46.00
16. 1025	132kV BROTHER POWER	GWh 4.47	0.77	0.00	0.13	0.78	0.05	0.00	0.00	6.21	0.90
		MW 2.04	0.44	0.00	0.05	0.09	0.01	0.00	0.00	2.24	1.00
17. 233	132kV Badami Bagh	GWh 59.69	8.74	0.01	13.84	164.68	3.28	0.00	0.00	250.24	0.88
		MW 19.47	3.32	0.00	5.90	69.64	0.87	0.00	0.00	74.40	40.00
18. 1047	132kV Baggrian	GWh 88.57	23.47	4.68	5.75	97.36	6.60	0.00	0.00	226.42	0.87
		MW 28.89	8.93	1.78	2.45	42.10	1.76	0.00	0.00	64.43	37.00
19. 2051	132kV Baghbanpura	GWh 146.32	24.59	6.45	10.52	6.68	11.68	0.00	0.00	206.24	0.89
		MW 47.72	9.36	2.45	4.48	11.62	3.11	0.00	0.00	59.06	30.00
20. 2008	132kV Bahria Archer	GWh 53.65	0.00	0.00	0.00	0.00	0.00	0.00	0.00	53.65	0.90
		MW 17.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	17.50	8.00
21. 994	132kV Bahria Town	GWh 100.85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.85	0.90
		MW 32.89	0.00	0.00	0.00	0.00	0.00	0.00	0.00	32.89	16.00
22. 1061	132kV Bakkar Mandi	GWh 113.19	17.32	1.52	14.15	28.00	10.85	0.00	0.00	185.04	0.85
		MW 36.99	6.23	0.58	6.03	14.89	2.89	0.00	0.00	50.71	31.00
23. 650	132kV Barkat Textile	GWh 0.00	0.00	0.00	0.00	22.69	0.00	0.00	0.00	22.69	0.90
		MW 0.00	0.00	0.00	0.00	4.13	0.00	0.00	0.00	4.13	2.00
24. 2091	132kV Bashir Steel	GWh 0.00	0.00	0.00	0.00	19.15	0.00	0.00	0.00	19.15	0.90
		MW 0.00	0.00	0.00	0.00	9.50	0.00	0.00	0.00	9.50	5.00
25. 241	66kV Basirpur	GWh 73.50	5.51	0.00	7.01	4.44	90.06	0.00	0.00	180.52	0.82
		MW 25.24	2.21	0.00	2.84	3.39	22.79	0.00	0.00	46.63	33.00

## POWER MARKET SURVEY

## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO

YEAR :2023-24

SR GRID  NO.NUMBER	NAME OF GRID STATION			PUBLIC	SMALL INDUSTRIES	M & L INDUSTRIES	TUBE WELLS PRIVATE	PUBLIC	TRACTION	TOTAL OF GRIDSTATION	POWER FACTOR(%)	REACT-POWER(Mvar)	
		DOMESTIC	COMMERCIAL	LIGHTING									
26.	13	132kV Batapur	GWh	167.16	15.44	1.97	12.51	94.05	45.85	0.00	0.00	336.98	0.86
		MW		51.83	5.58	0.71	5.06	46.14	11.60	0.00	0.00	90.76	54.00
27.	2031	132kV Bhadarpura	GWh	46.92	2.68	0.00	2.63	8.94	69.28	0.00	0.00	130.45	0.83
		MW		21.43	1.53	0.00	1.12	18.39	18.45	0.00	0.00	51.78	35.00
28.	15	132kV Bhai Pheru	GWh	113.07	13.79	0.15	5.73	439.65	58.24	0.00	0.00	630.63	0.88
		MW		40.97	6.01	0.06	2.32	97.44	14.74	0.00	0.00	129.27	70.00
29.	711	132kV Bhati Gate	GWh	134.81	28.33	3.19	35.67	29.91	6.21	0.00	0.00	238.12	0.85
		MW		38.47	9.24	1.21	15.20	36.90	1.65	0.00	0.00	77.01	48.00
30.	2068	132kV Bhenro K.R.K	GWh	0.00	0.00	0.00	0.00	32.56	0.00	0.00	0.00	32.56	0.90
		MW		0.00	0.00	0.00	0.00	5.72	0.00	0.00	0.00	5.72	3.00
31.	871	132kV Bhikki	GWh	23.10	4.64	0.00	3.10	565.15	14.51	0.00	0.00	610.50	0.89
		MW		10.55	2.65	0.00	1.32	121.09	3.86	0.00	0.00	118.55	61.00
32.	916	132kV Black Gold	GWh	0.00	0.00	0.00	0.00	35.23	0.00	0.00	0.00	35.23	0.90
		MW		0.00	0.00	0.00	0.00	11.95	0.00	0.00	0.00	11.95	6.00
33.	1096	132kV Blessed	GWh	0.00	0.00	0.00	0.00	1.35	0.00	0.00	0.00	1.35	0.90
		MW		0.00	0.00	0.00	0.00	16.59	0.00	0.00	0.00	16.59	8.00
34.	617	132kV Boggiwal	GWh	114.43	8.83	2.89	31.87	302.50	14.25	0.00	0.00	474.76	0.88
		MW		37.32	3.36	1.10	13.58	138.42	3.79	0.00	0.00	148.18	80.00
35.	18	132kV Bongha Hayat	GWh	5.91	0.19	0.00	0.22	1.09	25.27	0.00	0.00	32.69	0.77
		MW		2.70	0.11	0.00	0.10	10.27	6.73	0.00	0.00	16.92	14.00
36.	965	132kV Broadway	GWh	0.00	168.24	0.00	0.00	0.00	0.00	0.00	0.00	168.24	0.90
		MW		54.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	41.15	20.00
37.	20	132kV Bucheki	GWh	52.24	5.05	0.00	3.84	59.69	43.77	0.00	0.00	164.59	0.85
		MW		22.66	2.74	0.00	1.55	25.84	11.08	0.00	0.00	54.29	34.00
38.	599	220kV Bund Road	GWh	173.46	16.42	1.47	14.36	34.12	10.16	0.00	0.00	249.99	0.89
		MW		49.50	5.35	0.56	6.12	19.26	2.71	0.00	0.00	62.63	32.00
39.	981	132kV Central Park	GWh	92.30	19.59	0.00	2.84	13.81	3.34	0.00	0.00	131.88	0.90
		MW		30.11	7.45	0.00	1.21	7.11	0.89	0.00	0.00	39.76	19.00
40.	651	132kV Century Paper	GWh	0.00	0.00	0.00	0.00	59.80	0.00	0.00	0.00	59.80	0.90
		MW		0.00	0.00	0.00	0.00	18.27	0.00	0.00	0.00	18.27	9.00
41.	23	132kV Chah Miran	GWh	262.00	26.10	3.74	12.91	19.30	12.36	0.00	0.00	336.41	0.89
		MW		85.45	9.93	1.42	5.50	21.81	3.29	0.00	0.00	95.56	49.00
42.	1018	132kV Chak 40/D	GWh	60.79	8.76	0.00	6.45	49.38	29.82	0.00	0.00	155.20	0.85
		MW		26.45	4.87	0.00	2.75	36.30	7.94	0.00	0.00	66.57	41.00
43.	800	132kV Chak-65	GWh	14.98	2.31	0.00	0.71	401.61	1.50	0.00	0.00	421.11	0.90
		MW		6.50	1.25	0.00	0.29	94.78	0.38	0.00	0.00	87.72	42.00
44.	1072	132kV Chaurasta	GWh	40.82	2.50	0.00	3.79	15.60	86.52	0.00	0.00	149.24	0.82
		MW		17.22	1.33	0.00	1.62	18.12	23.05	0.00	0.00	52.13	36.00
45.	447	11kV Chichoke Mall P	GWh	15.76	1.15	0.00	0.54	8.27	5.36	0.00	0.00	31.09	0.85
		MW		7.20	0.66	0.00	0.23	7.65	1.43	0.00	0.00	14.59	9.00
46.	2012	132kV Chichoke Mallia	GWh	39.11	2.86	0.00	2.77	1.55	4.75	0.00	0.00	51.03	0.89
		MW		14.88	1.09	0.00	1.18	2.49	1.26	0.00	0.00	17.77	9.00
47.	986	132kV Chinar Bagh	GWh	20.88	5.88	0.00	1.06	63.30	0.91	0.00	0.00	92.02	0.88
		MW		7.94	2.69	0.00	0.45	23.46	0.24	0.00	0.00	26.09	14.00
48.	1071	132kV Chucak	GWh	76.74	5.20	0.00	7.68	4.51	52.50	0.00	0.00	146.62	0.83
		MW		33.28	2.67	0.00	3.27	9.56	13.98	0.00	0.00	53.35	36.00
49.	30	132kV Chung	GWh	158.37	25.05	5.26	5.42	204.43	6.60	0.00	0.00	405.13	0.87
		MW		49.07	9.05	1.90	2.19	68.61	1.67	0.00	0.00	99.43	56.00
50.	254	132kV Chunian	GWh	104.05	9.26	0.00	3.17	12.68	44.86	0.00	0.00	174.01	0.84
		MW		35.20	3.70	0.00	1.28	24.44	11.35	0.00	0.00	61.39	40.00

## POWER MARKET SURVEY

## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO

YEAR :2023-24

SR GRID   NO. NUMBER	NAME OF GRID STATION	DOMESTIC	COMMERCIAL	PUBLIC LIGHTING	SMALL INDUSTRIES	M & L INDUSTRIES	TUBE WELLS PRIVATE	PUBLIC	TRACTION	TOTAL OF GRIDSTATION	POWER FACTOR(%) REACT-POWER(Mvar)
51.	960 132kV City Steel SK	GWh 0.00	0.00	0.00	0.00	39.24	0.00	0.00	0.00	39.24	0.90
		MW 0.00	0.00	0.00	0.00	18.75	0.00	0.00	0.00	18.75	9.00
52.	1048 132kV Coca Cola	GWh 0.00	0.00	0.00	0.00	62.68	0.00	0.00	0.00	62.68	0.90
		MW 0.00	0.00	0.00	0.00	17.86	0.00	0.00	0.00	17.86	9.00
53.	999 132kV Colony Indust	GWh 0.01	0.00	0.00	0.00	52.64	0.00	0.00	0.00	52.65	0.90
		MW 0.00	0.00	0.00	0.00	11.14	0.00	0.00	0.00	11.15	5.00
54.	2099 132kV DHA Ph-VII-4(U-	GWh 129.29	9.21	0.00	0.00	0.00	2.17	0.00	0.00	140.67	0.90
		MW 42.17	3.51	0.00	0.00	0.00	0.58	0.00	0.00	34.69	17.00
55.	2084 132kV DHA Phase IX	GWh 129.45	10.90	1.47	1.08	0.00	7.37	0.00	0.00	150.27	0.89
		MW 42.22	4.15	0.56	0.46	0.00	1.96	0.00	0.00	37.01	19.00
56.	1032 132kV DHA Rahber	GWh 113.04	7.28	0.00	3.28	0.00	0.56	0.00	0.00	124.16	0.90
		MW 36.87	2.77	0.00	1.40	0.00	0.15	0.00	0.00	30.89	15.00
57.	991 132kV DHA- Ph. V	GWh 239.62	24.87	1.61	4.94	12.49	3.43	0.00	0.00	286.95	0.90
		MW 78.15	9.46	0.61	2.10	14.93	0.91	0.00	0.00	79.63	39.00
58.	980 132kV DHA-P-VI-3	GWh 177.57	21.96	0.33	4.39	4.55	32.25	0.00	0.00	241.04	0.88
		MW 57.92	8.36	0.13	1.87	13.11	8.59	0.00	0.00	67.48	36.00
59.	2049 132kV DHA-P-VI.2Derac	GWh 153.82	14.59	0.00	2.88	0.00	2.02	0.00	0.00	173.31	0.90
		MW 50.17	5.55	0.00	1.23	0.00	0.54	0.00	0.00	43.11	21.00
60.	2097 132kV DHAPh-VIIAdd.Ar	GWh 70.11	6.01	0.00	1.38	0.00	0.97	0.00	0.00	78.47	0.90
		MW 22.87	2.29	0.00	0.59	0.00	0.26	0.00	0.00	19.50	9.00
61.	2096 132kV DHAPh-VIII(T-B)	GWh 57.26	8.92	0.00	1.03	0.00	0.72	0.00	0.00	67.93	0.90
		MW 18.68	3.40	0.00	0.44	0.00	0.19	0.00	0.00	17.03	8.00
62.	2095 132kV DHAPh-VIII(V-B)	GWh 63.09	6.01	0.00	1.38	0.00	0.97	0.00	0.00	71.45	0.90
		MW 20.58	2.29	0.00	0.59	0.00	0.26	0.00	0.00	17.78	9.00
63.	1003 132kV Daroghwala	GWh 59.49	4.90	0.05	22.06	115.84	0.35	0.00	0.00	202.69	0.87
		MW 19.40	1.86	0.02	9.40	67.72	0.09	0.00	0.00	73.88	42.00
64.	426 132kV Defence	GWh 238.79	51.68	5.21	1.72	10.78	2.62	0.00	0.00	310.80	0.90
		MW 77.88	19.67	1.98	0.74	25.23	0.70	0.00	0.00	94.65	46.00
65.	992 132kV Defence XXY	GWh 89.02	41.19	1.03	0.46	3.87	0.00	0.00	0.00	135.58	0.90
		MW 29.04	15.67	0.39	0.20	23.37	0.00	0.00	0.00	51.50	25.00
66.	265 132kV Depalpur	GWh 146.32	17.48	0.05	6.16	72.63	118.12	0.00	0.00	360.75	0.84
		MW 48.40	6.55	0.02	2.49	52.63	29.89	0.00	0.00	104.99	68.00
67.	979 132kV Descon Oxy.	GWh 0.00	0.00	0.00	0.00	17.13	0.00	0.00	0.00	17.13	0.90
		MW 0.00	0.00	0.00	0.00	3.11	0.00	0.00	0.00	3.11	2.00
68.	2058 132kV Dew Kalan	GWh 20.41	2.07	0.00	2.23	35.33	1.32	0.00	0.00	61.37	0.88
		MW 6.66	0.79	0.00	0.95	6.12	0.35	0.00	0.00	11.15	6.00
69.	1036 132kV Diamond Fabrics	GWh 0.00	0.00	0.00	0.00	51.05	0.00	0.00	0.00	51.05	0.90
		MW 0.00	0.00	0.00	0.00	10.59	0.00	0.00	0.00	10.59	5.00
70.	2082 132kV Dina Nath	GWh 0.12	0.00	0.00	0.00	161.67	0.00	0.00	0.00	161.80	0.90
		MW 0.06	0.00	0.00	0.00	32.19	0.00	0.00	0.00	27.41	13.00
71.	1030 132kV Dost Steel	GWh 0.00	0.00	0.00	0.00	18.34	0.00	0.00	0.00	18.34	0.90
		MW 0.00	0.00	0.00	0.00	9.10	0.00	0.00	0.00	9.10	4.00
72.	270 66kV EMCO	GWh 0.00	0.00	0.00	0.00	92.72	0.00	0.00	0.00	92.72	0.90
		MW 0.00	0.00	0.00	0.00	26.77	0.00	0.00	0.00	22.76	11.00
73.	2066 132kV EME	GWh 79.89	0.05	0.00	0.00	0.00	0.00	0.00	0.00	79.94	0.90
		MW 26.06	0.02	0.00	0.00	0.00	0.00	0.00	0.00	19.56	9.00
74.	987 132kV Eden City	GWh 88.76	3.68	1.38	0.00	0.54	0.51	0.00	0.00	94.88	0.90
		MW 28.95	1.40	0.53	0.00	1.75	0.14	0.00	0.00	24.57	12.00
75.	2063 132kV Eden Value Home	GWh 65.38	5.30	0.22	1.01	7.90	2.71	0.00	0.00	82.53	0.90
		MW 21.33	2.02	0.08	0.43	6.80	0.72	0.00	0.00	23.54	11.00

## POWER MARKET SURVEY

## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO

YEAR :2023-24

SR GRID  NO. NUMBER	NAME OF GRID STATION	GWh	PUBLIC	SMALL INDUSTRIES	M & L INDUSTRIES	TUBE WELLS PRIVATE	PUBLIC	TRACTION	TOTAL OF GRIDSTATION	POWER FACTOR(%)	REACT-POWER(Mvar)
		MW	DOMESTIC	COMMERCIAL	LIGHTING						
76. 2041	132kV Ejaz Textile	0.01	0.00	0.00	23.93	0.00	0.00	0.00	23.95	0.90	
		MW	0.01	0.00	0.00	5.59	0.00	0.00	0.00	5.59	3.00
77. 506	132kV Elahabad	71.94	5.65	0.00	4.44	56.39	80.21	0.00	0.00	218.63	0.84
		MW	29.29	2.67	0.00	1.80	36.18	20.30	0.00	76.00	49.00
78. 2075	132kV Ellcot Spinning	0.11	0.00	0.00	0.00	35.23	0.00	0.00	0.00	35.34	0.90
		MW	0.04	0.00	0.00	6.76	0.00	0.00	0.00	6.79	3.00
79. 2098	132kV Emporium Mall	GWh	0.00	67.03	0.00	0.00	0.00	0.00	0.00	67.03	0.90
		MW	0.00	19.13	0.00	0.00	0.00	0.00	0.00	14.35	7.00
80. 271	132kV Farooqabad	GWh	166.10	10.28	0.03	6.76	104.72	101.14	0.00	389.03	0.85
		MW	60.14	4.48	0.01	2.74	35.12	25.59	0.00	100.27	62.00
81. 38	132kV Fateh Garh	GWh	309.62	43.11	3.93	23.41	21.42	17.61	0.00	419.09	0.89
		MW	88.36	14.06	1.50	9.98	34.36	4.69	0.00	114.71	59.00
82. 982	132kV Fazzia	GWh	74.85	2.58	0.00	0.00	0.00	1.25	0.00	78.68	0.90
		MW	24.41	0.98	0.00	0.00	0.00	0.33	0.00	19.29	9.00
83. 2094	132kV Fazzia-2	GWh	43.52	4.46	0.00	1.03	0.00	0.48	0.00	49.49	0.90
		MW	14.19	1.70	0.00	0.44	0.00	0.13	0.00	12.34	6.00
84. 1028	132kV Ferozepur Road	GWh	120.11	36.20	1.18	2.18	9.37	4.12	0.00	173.16	0.90
		MW	37.59	12.93	0.45	0.93	16.04	1.10	0.00	51.78	25.00
85. 40	132kV Fort	GWh	92.10	20.94	3.43	5.69	10.93	11.38	0.00	144.47	0.89
		MW	30.04	7.97	1.30	2.42	14.01	3.03	0.00	44.08	23.00
86. 2059	132kV Fruit Mandi	GWh	71.97	10.04	0.59	6.91	105.77	5.50	0.00	200.79	0.87
		MW	23.47	3.82	0.22	2.94	42.48	1.47	0.00	55.80	32.00
87. 43	132kV Garden Town	GWh	191.54	134.96	2.87	4.25	9.38	13.79	0.00	356.78	0.89
		MW	62.47	51.35	1.09	1.81	50.99	3.67	0.00	128.55	66.00
88. 2069	132kV Ghani Gases	GWh	0.00	0.00	0.00	0.00	52.27	0.00	0.00	52.27	0.90
		MW	0.00	0.00	0.00	0.00	13.09	0.00	0.00	13.09	6.00
89. 45	132kV Ghazi	GWh	251.80	27.37	1.83	9.83	9.78	10.21	0.00	310.82	0.89
		MW	78.09	9.91	0.66	3.98	21.62	2.58	0.00	87.69	45.00
90. 652	132kV Ghazi Fabirc	GWh	0.00	0.00	0.00	0.00	47.06	0.00	0.00	47.06	0.90
		MW	0.00	0.00	0.00	0.00	9.65	0.00	0.00	9.65	5.00
91. 507	132kV Green View	GWh	20.29	3.32	0.00	3.16	293.03	-1.09	0.00	318.72	0.90
		MW	6.62	1.26	0.00	1.35	126.15	-0.29	0.00	101.32	49.00
92. 997	132kV Gulberg Lahore	GWh	80.24	99.89	1.45	0.97	8.24	1.60	0.00	192.38	0.90
		MW	23.20	33.84	0.55	0.41	26.94	0.43	0.00	64.03	31.00
93. 1099	11kV Gulistan P/H	GWh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.77
		MW	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
94. 429	132kV Gulshan Ravi	GWh	207.73	30.22	7.40	23.10	32.72	20.51	0.00	321.68	0.89
		MW	59.28	9.86	2.81	9.85	31.46	5.46	0.00	89.05	46.00
95. 2086	132kV Hadeed Pakistan	GWh	0.00	0.00	0.00	0.00	14.15	0.00	0.00	14.15	0.90
		MW	0.00	0.00	0.00	0.00	7.02	0.00	0.00	7.02	3.00
96. 1092	132kV Hadyara	GWh	17.41	3.51	0.24	1.02	2.61	14.67	0.00	39.46	0.83
		MW	5.68	1.34	0.09	0.43	7.90	3.91	0.00	14.51	10.00
97. 2057	132kV Hanjarwal	GWh	76.33	12.34	2.25	8.61	10.44	4.76	0.00	114.73	0.89
		MW	26.03	4.70	0.86	3.67	17.72	1.27	0.00	40.68	21.00
98. 60	132kV Haveli	GWh	133.30	10.66	0.00	9.82	13.78	155.35	0.00	322.90	0.83
		MW	46.00	4.27	0.00	3.97	35.89	39.31	0.00	107.28	72.00
99. 985	132kV Hira Terry	GWh	0.02	0.00	0.00	0.00	108.16	0.00	0.00	108.18	0.90
		MW	0.01	0.00	0.00	0.00	23.77	0.00	0.00	23.78	12.00
100. 287	132kV Hujra	GWh	154.83	8.51	0.02	6.70	17.62	103.81	0.00	291.48	0.83
		MW	50.17	3.29	0.01	2.71	25.93	26.27	0.00	86.10	58.00

## POWER MARKET SURVEY

## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO

YEAR :2023-24

SR GRID  NO. NUMBER	NAME OF GRID STATION	GWh	2.10	0.17	0.00	0.11	355.05	0.17	0.00	0.00	357.61	0.90
		MW	0.80	0.08	0.00	0.05	91.82	0.05	0.00	0.00	69.59	34.00
101.	753 132kV ICI	GWh	52.81	0.82	0.00	1.24	0.15	2.99	0.00	0.00	58.00	0.89
102.	2061 132kV IEEP Town	MW	17.22	0.31	0.00	0.53	1.18	0.80	0.00	0.00	15.03	8.00
103.	2064 132kV Indus Home	GWh	0.22	0.00	0.00	0.00	47.70	0.00	0.00	0.00	47.92	0.90
104.	66 132kV Ittahad Chemi	MW	0.10	0.00	0.00	0.00	12.45	0.00	0.00	0.00	12.55	6.00
105.	2028 132kV Jail Road	GWh	0.41	0.13	0.00	0.18	128.17	0.07	0.00	0.00	128.96	0.90
106.	952 132kV Jamber	MW	0.19	0.07	0.00	0.08	40.49	0.02	0.00	0.00	40.85	20.00
107.	1029 132kV Jandiala S.Khan	GWh	68.66	22.01	2.38	0.91	1.90	4.55	0.00	0.00	100.41	0.89
108.	782 132kV Johar Town	MW	22.39	8.38	0.90	0.39	10.28	1.21	0.00	0.00	32.67	17.00
109.	957 132kV Johar Town-II	GWh	61.77	7.14	0.00	3.80	125.83	32.40	0.00	0.00	230.93	0.87
110.	1019 132kV Jubli Town	MW	28.20	4.07	0.00	1.62	30.61	8.63	0.00	0.00	62.17	35.00
111.	977 132kV K.E. Medical H/	GWh	38.17	4.03	0.00	3.75	0.52	24.45	0.00	0.00	70.94	0.83
112.	113 220kV K.Lakhpat.New	MW	17.43	2.30	0.00	1.60	7.86	6.51	0.00	0.00	30.35	20.00
113.	82 132kV K.Lakhpat.Old	GWh	284.54	72.73	3.40	10.93	10.11	5.17	0.00	0.00	386.89	0.90
114.	2044 132kV Kala Khatai	MW	81.21	23.72	1.30	4.66	52.50	1.38	0.00	0.00	123.57	60.00
115.	84 220kV Kala Shah Kaku	GWh	170.04	67.77	4.21	7.19	3.54	7.86	0.00	0.00	260.60	0.89
116.	1026 132kV Kamran Steel	MW	48.53	22.10	1.60	3.06	2.54	2.09	0.00	0.00	59.95	31.00
117.	303 66kV Kanganpur	GWh	116.38	21.17	0.32	3.82	32.96	2.95	0.00	0.00	177.60	0.90
118.	2000 132kV Karol	MW	37.96	8.05	0.12	1.63	14.99	0.78	0.00	0.00	47.66	23.00
119.	2055 132kV Kashmir Colony	GWh	22.27	0.74	0.00	0.69	16.77	0.89	0.00	0.00	41.35	0.87
120.	99 132kV Kasur	MW	7.26	0.28	0.00	0.29	7.36	0.24	0.00	0.00	11.57	7.00
121.	1020 132kV Kasur New	GWh	163.62	38.40	0.22	7.93	86.34	5.44	0.00	0.00	301.96	0.86
122.	1015 132kV Kasur-II	MW	53.37	14.61	0.09	3.38	36.88	1.45	0.00	0.00	82.33	49.00
123.	1044 132kV Khana Nau	GWh	317.69	46.82	3.15	11.48	55.54	13.05	0.00	0.00	447.74	0.89
124.	647 132kV Khanqa Dogran	MW	90.66	15.27	1.20	4.89	39.28	3.48	0.00	0.00	116.09	59.00
125.	2046 132kV Khay. Amin	GWh	39.34	2.61	0.00	2.50	29.63	4.83	0.00	0.00	78.92	0.86
		MW	12.83	0.99	0.00	1.07	16.27	1.29	0.00	0.00	24.34	14.00
		GWh	58.32	12.91	0.09	3.92	171.02	22.64	0.00	0.00	268.90	0.88
		MW	21.18	5.63	0.03	1.59	22.78	5.73	0.00	0.00	48.40	26.00
		GWh	0.00	0.00	0.00	0.00	21.15	0.00	0.00	0.00	21.15	0.90
		MW	0.00	0.00	0.00	0.00	8.46	0.00	0.00	0.00	8.46	4.00
		GWh	25.57	1.59	0.00	1.55	1.26	46.81	0.00	0.00	76.77	0.82
		MW	11.09	0.86	0.00	0.63	6.47	11.85	0.00	0.00	26.26	18.00
		GWh	37.25	4.88	2.37	6.51	132.17	13.96	0.00	0.00	197.15	0.88
		MW	12.15	1.86	0.90	2.77	63.22	3.72	0.00	0.00	63.47	34.00
		GWh	27.55	1.18	0.00	0.39	0.00	0.26	0.00	0.00	29.39	0.90
		MW	8.99	0.45	0.00	0.17	0.00	0.07	0.00	0.00	7.25	4.00
		GWh	131.44	18.64	0.61	11.59	35.43	34.79	0.00	0.00	232.50	0.85
		MW	40.90	6.78	0.22	4.69	32.20	8.80	0.00	0.00	70.27	44.00
		GWh	154.94	15.12	0.81	32.14	23.90	41.31	0.00	0.00	268.22	0.84
		MW	50.53	5.75	0.31	13.70	30.61	11.00	0.00	0.00	83.93	54.00
		GWh	27.41	3.54	0.00	1.57	10.61	5.19	0.00	0.00	48.31	0.85
		MW	8.94	1.35	0.00	0.67	3.61	1.38	0.00	0.00	13.55	8.00
		GWh	124.03	9.66	0.03	7.84	153.54	1.07	0.00	0.00	296.16	0.87
		MW	40.45	3.68	0.01	3.34	57.67	0.28	0.00	0.00	79.07	45.00
		GWh	59.33	5.65	0.00	2.74	8.22	43.74	0.00	0.00	119.68	0.83
		MW	23.58	2.75	0.00	1.11	13.60	11.07	0.00	0.00	44.29	30.00
		GWh	103.06	1.64	0.00	0.00	0.00	0.52	0.00	0.00	105.22	0.90
		MW	33.62	0.62	0.00	0.00	0.00	0.14	0.00	0.00	25.78	12.00

## POWER MARKET SURVEY

## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO

YEAR :2023-24

SR GRID   NO. NUMBER	NAME OF GRID STATION	DOMESTIC	COMMERCIAL	PUBLIC   LIGHTING	SMALL INDUSTRIES	M & L INDUSTRIES	TUBE WELLS PRIVATE   PUBLIC	TRACTION	TOTAL OF GRIDSTATION	POWER FACTOR(%)	REACT-POWER(Mvar)
126.	1093 132kV Khokkar Road	GWh 43.20	4.50	0.12	15.15	89.24	3.54 0.00	0.00	155.74	0.87	
		MW 14.09	1.71	0.05	6.46	24.18	0.94 0.00	0.00	35.57	20.00	
127.	310 132kV Khuddian	GWh 90.09	6.20	0.00	5.21	10.41	101.04 0.00	0.00	212.95	0.83	
		MW 37.29	3.03	0.00	2.11	29.90	25.57 0.00	0.00	82.45	55.00	
128.	850 132kV Kot Radha Kis	GWh 139.32	15.15	0.00	9.38	16.06	14.50 0.00	0.00	194.42	0.89	
		MW 47.55	6.11	0.00	3.80	7.05	3.67 0.00	0.00	56.74	29.00	
129.	984 132kV LDA Ave-I	GWh 135.60	3.31	0.00	0.00	0.00	1.49 0.00	0.00	140.40	0.90	
		MW 44.23	1.26	0.00	0.00	0.00	0.40 0.00	0.00	34.41	17.00	
130.	121 132kV LEFO	GWh 145.65	33.70	1.19	8.52	95.77	6.38 0.00	0.00	291.22	0.86	
		MW 45.20	12.18	0.43	3.45	36.24	1.62 0.00	0.00	74.40	44.00	
131.	2067 132kV LHR SKP Road	GWh 18.88	3.04	0.00	3.40	88.74	3.52 0.00	0.00	117.57	0.88	
		MW 6.39	1.18	0.00	1.45	36.21	0.94 0.00	0.00	34.63	19.00	
132.	1009 132kV LUMS	GWh 0.00	29.28	0.00	0.00	0.00	0.00 0.00	0.00	29.28	0.90	
		MW 0.00	5.57	0.00	0.00	0.00	0.00 0.00	0.00	5.57	3.00	
133.	949 132kV Lahore Cantt	GWh 196.08	39.47	0.86	2.11	8.79	2.71 0.00	0.00	250.03	0.90	
		MW 63.95	15.02	0.33	0.90	37.71	0.72 0.00	0.00	88.98	43.00	
134.	2047 132kV Lake City	GWh 109.54	16.90	0.71	0.22	6.48	1.19 0.00	0.00	135.04	0.90	
		MW 35.73	6.43	0.27	0.10	5.97	0.32 0.00	0.00	36.61	18.00	
135.	314 132kV Lalyani	GWh 71.12	7.43	0.00	5.27	111.01	5.11 0.00	0.00	199.94	0.88	
		MW 24.39	2.99	0.00	2.13	37.19	1.29 0.00	0.00	56.50	30.00	
136.	954 132kV M.A.Abad	GWh 53.62	3.92	0.00	3.48	1.45	50.35 0.00	0.00	112.81	0.83	
		MW 24.48	2.24	0.00	1.48	8.45	13.41 0.00	0.00	42.55	29.00	
137.	953 132kV M.Uzmanwala	GWh 43.68	2.32	0.00	3.00	1.67	59.98 0.00	0.00	110.65	0.82	
		MW 19.95	1.32	0.00	1.28	14.45	15.98 0.00	0.00	45.03	31.00	
138.	1027 132kV Machikay	GWh 102.78	12.54	0.46	3.70	25.10	12.41 0.00	0.00	156.99	0.85	
		MW 46.93	7.16	0.17	1.58	13.15	3.31 0.00	0.00	61.45	38.00	
139.	2102 132kV Makhdoom/Doula	GWh 7.98	0.11	0.00	0.26	1.17	23.44 0.00	0.00	32.96	0.82	
		MW 3.04	0.05	0.00	0.11	8.48	6.24 0.00	0.00	15.23	11.00	
140.	951 132kV Malik Paper	GWh 0.00	0.00	0.00	0.00	36.39	0.00 0.00	0.00	36.39	0.90	
		MW 0.00	0.00	0.00	0.00	9.03	0.00 0.00	0.00	9.03	4.00	
141.	320 66kV Malikpur	GWh 115.94	15.31	0.00	22.41	8.22	18.01 0.00	0.00	179.89	0.84	
		MW 52.94	8.74	0.00	9.55	11.53	4.80 0.00	0.00	74.42	48.00	
142.	2093 132kV Mandali Paper	GWh 0.00	0.00	0.00	0.00	9.20	0.00 0.00	0.00	9.20	0.90	
		MW 0.00	0.00	0.00	0.00	8.02	0.00 0.00	0.00	8.02	4.00	
143.	411 132kV Manga Mandi	GWh 57.22	7.12	0.40	2.48	321.86	8.25 0.00	0.00	397.33	0.89	
		MW 21.77	3.25	0.15	1.06	49.87	2.20 0.00	0.00	66.55	34.00	
144.	2056 132kV Manga-II	GWh 7.04	0.54	0.00	0.27	206.54	1.53 0.00	0.00	215.92	0.90	
		MW 2.98	0.29	0.00	0.11	43.16	0.41 0.00	0.00	39.92	19.00	
145.	1034 132kV Master Textil	GWh 0.00	0.00	0.00	0.00	57.59	0.00 0.00	0.00	57.59	0.90	
		MW 0.00	0.00	0.00	0.00	12.46	0.00 0.00	0.00	12.46	6.00	
146.	583 132kV Mcleod Road	GWh 103.22	91.68	5.74	12.57	7.54	1.63 0.00	0.00	222.38	0.89	
		MW 33.67	34.89	2.18	5.36	36.06	0.43 0.00	0.00	84.44	43.00	
147.	2052 132kV Mehmood Steel	GWh 0.00	0.00	0.00	0.00	12.70	0.00 0.00	0.00	12.70	0.90	
		MW 0.00	0.00	0.00	0.00	6.30	0.00 0.00	0.00	6.30	3.00	
148.	998 132kV Mobile	GWh 40.46	6.92	0.00	0.58	35.79	0.43 0.00	0.00	84.19	0.87	
		MW 13.20	2.63	0.00	0.25	19.83	0.11 0.00	0.00	30.62	17.00	
149.	710 132kV Mochi Gate	GWh 126.42	57.65	8.66	15.66	6.87	12.04 0.00	0.00	227.29	0.89	
		MW 41.23	21.94	3.29	6.67	19.28	3.21 0.00	0.00	71.72	37.00	
150.	504 132kV Model Town	GWh 233.62	92.78	3.97	3.19	9.79	10.58 0.00	0.00	353.92	0.90	
		MW 76.20	35.30	1.51	1.36	41.45	2.82 0.00	0.00	118.98	58.00	

## POWER MARKET SURVEY

## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO

YEAR :2023-24

SR GRID  NO. NUMBER	NAME OF GRID STATION	GWh	PUBLIC	SMALL INDUSTRIES	M & L INDUSTRIES	TUBE WELLS PRIVATE	PUBLIC	TRACTION	TOTAL OF GRIDSTATION	POWER FACTOR(%)	REACT-POWER(Mvar)	
		MW	DOMESTIC	COMMERCIAL	LIGHTING							
151.	2050	132kV ModelTownSociet	85.45	9.52	0.00	0.00	2.62	0.00	0.00	97.59	0.90	
		MW	27.87	3.62	0.00	0.00	0.70	0.00	0.00	24.14	12.00	
152.	330	66kV Mohlan	41.86	1.44	0.00	0.82	1.81	4.75	0.00	50.69	0.89	
		MW	19.11	0.82	0.00	0.35	0.69	1.27	0.00	18.91	10.00	
153.	1040	132kV Momanpura G.T	118.55	9.58	0.73	16.71	78.93	10.90	0.00	235.39	0.86	
		MW	37.02	3.49	0.28	7.12	36.89	2.90	0.00	65.77	39.00	
154.	2072	132kV Mughal Alloya	GWh	0.00	0.00	0.00	78.49	0.00	0.00	78.49	0.90	
		MW	0.00	0.00	0.00	0.00	26.54	0.00	0.00	26.54	13.00	
155.	1073	132kV Mughal Steel	GWh	0.00	0.00	0.00	147.67	0.00	0.00	147.67	0.90	
		MW	0.00	0.00	0.00	0.00	54.70	0.00	0.00	54.70	26.00	
156.	679	132kV Muhammad Bukh	GWh	0.00	0.00	0.00	17.37	0.00	0.00	17.37	0.90	
		MW	0.00	0.00	0.00	0.00	3.05	0.00	0.00	3.05	1.00	
157.	964	132kV Muridke	GWh	99.70	12.83	0.06	15.21	109.56	14.00	0.00	251.37	0.87
		MW	32.42	17.14	0.02	6.16	17.40	3.54	0.00	60.56	34.00	
158.	1037	132kV Mustafabad	GWh	110.82	14.35	2.11	2.62	1.31	4.30	0.00	135.51	0.89
		MW	34.51	5.18	0.80	1.12	5.22	1.15	0.00	35.99	18.00	
159.	2024	132kV Nain Sukh	GWh	39.42	5.64	0.15	6.32	21.91	7.29	0.00	80.73	0.86
		MW	12.86	2.15	0.06	2.69	13.66	1.94	0.00	25.01	15.00	
160.	520	132kV Nankana	GWh	192.74	19.02	0.09	18.66	33.77	37.44	0.00	301.73	0.85
		MW	64.72	7.11	0.03	7.55	30.21	9.47	0.00	95.30	59.00	
161.	336	132kV Narang Mandi	GWh	94.33	7.85	0.10	3.27	10.53	11.09	0.00	127.17	0.89
		MW	32.27	3.12	0.04	1.33	6.16	2.81	0.00	38.02	19.00	
162.	2074	132kV Naveena Export	GWh	0.01	0.00	0.00	45.27	0.00	0.00	0.00	45.27	0.90
		MW	0.00	0.00	0.00	0.00	9.05	0.00	0.00	9.05	4.00	
163.	866	132kV New Airport	GWh	0.00	47.50	0.00	0.00	0.00	0.00	0.00	47.50	0.90
		MW	0.00	18.07	0.00	0.00	0.00	0.00	0.00	18.07	9.00	
164.	1074	132kV New Smr St.2 Lh	GWh	0.00	0.00	0.00	16.80	0.00	0.00	0.00	16.80	0.90
		MW	0.00	0.00	0.00	0.00	9.97	0.00	0.00	9.97	5.00	
165.	996	132kV New Smr St.3 Sk	GWh	0.00	0.00	0.00	31.63	0.00	0.00	0.00	31.63	0.90
		MW	0.00	0.00	0.00	0.00	12.44	0.00	0.00	12.44	6.00	
166.	989	132kV Niazi Chowk	GWh	69.93	14.59	0.92	43.49	98.78	6.03	0.00	233.74	0.86
		MW	20.94	5.01	0.35	18.53	28.57	1.61	0.00	56.26	33.00	
167.	2007	132kV Nisar Spinning	GWh	0.00	0.00	0.00	24.50	0.00	0.00	0.00	24.50	0.90
		MW	0.00	0.00	0.00	0.00	6.95	0.00	0.00	6.95	3.00	
168.	1083	132kV Nishat Chunian	GWh	0.00	0.00	0.00	59.83	0.00	0.00	0.00	59.83	0.90
		MW	0.00	0.00	0.00	0.00	28.93	0.00	0.00	28.93	14.00	
169.	2080	132kV Nishat Mills SK	GWh	0.00	0.00	0.00	77.12	0.00	0.00	0.00	77.12	0.90
		MW	0.00	0.00	0.00	0.00	12.44	0.00	0.00	12.44	6.00	
170.	2054	132kV OPF Lahore	GWh	41.85	1.78	0.00	0.59	0.00	0.27	0.00	44.50	0.90
		MW	13.65	0.68	0.00	0.25	0.00	0.07	0.00	10.99	5.00	
171.	338	132kV Okara Cantt	GWh	92.29	3.32	0.05	0.95	6.18	11.89	0.00	114.66	0.89
		MW	30.10	1.26	0.02	0.41	9.83	3.17	0.00	33.58	17.00	
172.	152	132kV Okara City-I	GWh	171.09	28.23	0.25	14.53	74.10	38.80	0.00	327.00	0.85
		MW	57.92	11.03	0.09	5.88	36.74	9.82	0.00	95.35	59.00	
173.	849	132kV Okara City-II	GWh	253.07	38.64	0.50	10.66	55.19	16.28	0.00	374.34	0.89
		MW	86.25	15.65	0.18	4.32	32.35	4.12	0.00	107.15	55.00	
174.	1002	132kV OkaraFSDRd	GWh	75.12	10.36	0.01	3.48	24.30	21.56	0.00	134.84	0.85
		MW	31.81	5.67	0.01	1.48	13.30	5.74	0.00	44.80	28.00	
175.	153	132kV P.W.R	GWh	136.62	41.40	3.39	4.45	70.65	10.11	0.00	266.63	0.86
		MW	44.56	15.76	1.29	1.90	41.48	2.69	0.00	80.76	48.00	

## POWER MARKET SURVEY

## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO

YEAR :2023-24

SR GRID  NO. NUMBER	NAME OF GRID STATION		PUBLIC	SMALL INDUSTRIES	M & L INDUSTRIES	TUBE WELLS PRIVATE	PUBLIC	TRACTION	TOTAL OF GRIDSTATION	POWER FACTOR(%)	REACT-POWER(Mvar)
		DOMESTIC	COMMERCIAL	LIGHTING							
176.	2088	132kV PAEC Mraka	GWh 36.63	1.09	0.73	0.29	0.00	0.36	0.00	0.00	39.11 0.90
		MW 11.95	0.41	0.28	0.12	0.00	0.10	0.00	0.00	9.65	5.00
177.	654	132kV Packages	GWh 0.00	0.00	0.00	0.00	6.83	0.00	0.00	0.00	6.83 0.90
		MW 0.00	0.00	0.00	0.00	6.54	0.00	0.00	0.00	6.54	3.00
178.	946	132kV Packages Kasur	GWh 0.01	0.00	0.00	0.00	22.63	0.00	0.00	0.00	22.63 0.90
		MW 0.00	0.00	0.00	0.00	30.64	0.00	0.00	0.00	30.64	15.00
179.	2053	132kV Pak Arab	GWh 169.05	18.92	1.60	5.61	5.13	3.49	0.00	0.00	203.79 0.90
		MW 55.14	7.20	0.61	2.39	4.61	0.93	0.00	0.00	53.15	26.00
180.	2017	132kV Panwan	GWh 58.77	2.75	0.00	1.84	2.60	11.77	0.00	0.00	77.73 0.88
		MW 26.83	1.57	0.00	0.79	10.96	3.14	0.00	0.00	36.80	20.00
181.	2089	132kV Paragon H/S	GWh 87.86	4.35	0.00	0.08	0.27	7.62	0.00	0.00	100.19 0.89
		MW 28.66	1.66	0.00	0.04	0.15	2.03	0.00	0.00	24.39	12.00
182.	1082	132kV Park View	GWh 142.57	33.30	0.72	3.74	2.58	2.64	0.00	0.00	185.55 0.90
		MW 46.50	12.67	0.28	1.59	6.64	0.70	0.00	0.00	51.29	25.00
183.	158	132kV Pattroki	GWh 129.92	16.73	0.74	6.42	18.76	42.27	0.00	0.00	214.84 0.84
		MW 45.09	6.58	0.27	2.60	12.72	10.70	0.00	0.00	61.57	40.00
184.	2036	132kV Press Club	GWh 183.18	17.64	1.87	7.54	8.20	19.58	0.00	0.00	238.01 0.89
		MW 53.74	5.89	0.71	3.21	13.71	5.22	0.00	0.00	61.86	32.00
185.	993	132kV Punjab Assembly	GWh 40.83	85.48	2.12	3.00	8.02	0.77	0.00	0.00	140.22 0.90
		MW 13.32	32.53	0.81	1.28	12.36	0.21	0.00	0.00	45.37	22.00
186.	1043	132kV Punjab Uni	GWh 150.62	48.33	3.68	1.85	3.89	13.92	0.00	0.00	222.29 0.89
		MW 49.13	18.39	1.40	0.79	17.17	3.71	0.00	0.00	67.94	35.00
187.	958	132kV Punjab UnivTown	GWh 57.99	16.67	0.19	3.41	20.26	1.23	0.00	0.00	99.76 0.86
		MW 18.91	6.34	0.07	1.46	15.68	0.33	0.00	0.00	32.09	19.00
188.	168	132kV Qadirabad	GWh 13.09	2.00	0.00	0.39	14.37	0.89	0.00	0.00	30.73 0.87
		MW 5.98	1.14	0.00	0.17	10.85	0.24	0.00	0.00	15.62	9.00
189.	167	132kV Qartaba	GWh 179.45	69.70	6.92	5.32	5.99	15.76	0.00	0.00	283.13 0.89
		MW 58.53	26.52	2.63	2.27	21.53	4.20	0.00	0.00	86.76	44.00
190.	1080	132kV Qila Sattar Sha	GWh 17.28	1.33	0.00	1.41	48.42	3.79	0.00	0.00	72.23 0.88
		MW 7.89	0.76	0.00	0.60	19.82	1.01	0.00	0.00	25.57	14.00
191.	1085	132kV Quetta Textile	GWh 0.00	0.00	0.00	0.00	26.61	0.00	0.00	0.00	26.61 0.90
		MW 0.00	0.00	0.00	0.00	16.36	0.00	0.00	0.00	16.36	8.00
192.	1090	132kV Rachna Town	GWh 137.44	18.81	0.93	13.96	21.90	5.49	0.00	0.00	198.52 0.89
		MW 44.83	7.16	0.35	5.95	19.03	1.46	0.00	0.00	59.08	30.00
193.	353	132kV Raiwind	GWh 165.65	18.23	0.50	6.79	131.63	10.86	0.00	0.00	333.66 0.87
		MW 55.68	7.07	0.18	2.75	45.32	2.75	0.00	0.00	85.31	48.00
194.	1016	132kV Raiwind New	GWh 8.57	1.12	0.00	0.63	255.94	1.35	0.00	0.00	267.62 0.90
		MW 3.91	0.64	0.00	0.27	71.74	0.36	0.00	0.00	65.38	32.00
195.	956	132kV Raiwind-III	GWh 35.48	2.72	0.16	1.72	191.80	6.39	0.00	0.00	238.28 0.89
		MW 13.50	1.24	0.06	0.73	36.05	1.70	0.00	0.00	45.30	23.00
196.	173	220kV Ravi	GWh 76.10	19.03	3.04	13.47	44.16	15.59	0.00	0.00	171.39 0.85
		MW 24.82	7.24	1.16	5.74	16.64	4.15	0.00	0.00	44.82	28.00
197.	175	132kV Rehman Park	GWh 87.31	105.12	2.41	1.54	39.30	5.21	0.00	0.00	240.90 0.90
		MW 24.92	34.29	0.92	0.66	31.54	1.39	0.00	0.00	70.28	34.00
198.	2071	132kV Rehman Steel	GWh 0.00	0.00	0.00	0.00	17.01	0.00	0.00	0.00	17.01 0.90
		MW 0.00	0.00	0.00	0.00	7.39	0.00	0.00	0.00	7.39	4.00
199.	929	132kV Rehmat Nazir	GWh 0.00	0.00	0.00	0.00	0.86	0.00	0.00	0.00	0.86 0.90
		MW 0.00	0.00	0.00	0.00	0.62	0.00	0.00	0.00	0.62	0.00
200.	2079	132kV Reliance Cotton	GWh 0.00	0.00	0.00	0.00	30.96	0.00	0.00	0.00	30.96 0.90
		MW 0.00	0.00	0.00	0.00	7.06	0.00	0.00	0.00	7.06	3.00

## POWER MARKET SURVEY

## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO

YEAR :2023-24

SR GRID  NO.NUMBER	NAME OF GRID STATION	DOMESTIC   COMMERCIAL	PUBLIC LIGHTING	SMALL INDUSTRIES	M & L INDUSTRIES	TUBE WELLS			TOTAL OF GRIDSTATION	POWER FACTOR(%) REACT-POWER(Mvar)		
						PRIVATE	PUBLIC	TRACTION				
201.	176 132kV Renala Khurd	GWh	126.95	10.77	0.31	11.22	19.09	16.33	0.00	0.00	184.69	0.85
		MW	43.79	4.41	0.11	4.54	4.24	4.13	0.00	0.00	50.05	31.00
202.	659 11kV Renala P/H	GWh	4.91	0.07	0.00	0.00	0.45	0.04	0.00	0.00	5.48	0.90
		MW	2.24	0.04	0.00	0.00	0.62	0.01	0.00	0.00	2.48	1.00
203.	357 132kV Rewaz Garden	GWh	249.10	66.06	6.58	7.32	5.31	15.33	0.00	0.00	349.70	0.89
		MW	71.09	21.55	2.51	3.12	25.67	4.08	0.00	0.00	96.01	49.00
204.	2005 132kV Riaz Textile	GWh	0.00	0.00	0.00	0.00	41.55	0.00	0.00	0.00	41.55	0.90
		MW	0.00	0.00	0.00	0.00	8.55	0.00	0.00	0.00	8.55	4.00
205.	2020 132kV Roya Golf Club	GWh	0.00	63.07	0.00	0.00	0.00	0.00	0.00	0.00	63.07	0.90
		MW	0.00	24.00	0.00	0.00	0.00	0.00	0.00	0.00	24.00	12.00
206.	412 132kV Rustam	GWh	156.61	19.30	0.15	31.35	176.22	7.73	0.00	0.00	391.35	0.87
		MW	51.08	7.34	0.06	13.36	63.24	2.06	0.00	0.00	102.85	58.00
207.	902 132kV SKP-Industrial	GWh	76.54	4.50	0.09	2.60	13.08	3.44	0.00	0.00	100.24	0.89
		MW	34.95	2.57	0.03	1.11	12.51	0.92	0.00	0.00	44.27	23.00
208.	950 132kV Sabzazar	GWh	225.20	25.68	7.47	6.30	10.97	11.29	0.00	0.00	286.91	0.89
		MW	80.34	9.77	2.84	2.68	20.26	3.01	0.00	0.00	89.18	46.00
209.	540 132kV Sadar Gogera	GWh	95.08	6.15	0.00	3.02	2.74	40.11	0.00	0.00	147.10	0.84
		MW	34.47	2.69	0.00	1.22	15.31	10.15	0.00	0.00	54.27	35.00
210.	973 132kV Safdarabad	GWh	39.81	3.46	0.00	1.53	1.00	9.12	0.00	0.00	54.93	0.88
		MW	18.18	1.98	0.00	0.65	5.47	2.43	0.00	0.00	23.01	12.00
211.	969 132kV Saggian	GWh	122.85	29.96	3.37	27.49	29.42	12.14	0.00	0.00	225.22	0.85
		MW	36.78	10.19	1.28	11.71	31.18	3.23	0.00	0.00	70.79	44.00
212.	184 132kV Saidpur	GWh	285.37	48.78	2.63	8.11	11.58	14.99	0.00	0.00	371.46	0.89
		MW	101.80	18.56	1.00	3.45	28.57	3.99	0.00	0.00	118.04	60.00
213.	1060 132kV Sanda	GWh	64.63	10.34	1.47	9.81	4.52	4.71	0.00	0.00	95.49	0.88
		MW	18.45	3.37	0.56	4.18	9.87	1.26	0.00	0.00	28.27	15.00
214.	362 132kV Sangla Hill	GWh	108.13	9.28	0.00	3.81	3.99	4.44	0.00	0.00	129.65	0.89
		MW	36.45	3.35	0.00	1.54	3.30	1.12	0.00	0.00	36.98	19.00
215.	1087 132kV Sapphire -3	GWh	0.00	0.00	0.00	0.00	13.57	0.00	0.00	0.00	13.57	0.90
		MW	0.00	0.00	0.00	0.00	7.79	0.00	0.00	0.00	7.79	4.00
216.	1066 132kV Sapphire -5	GWh	0.00	0.00	0.00	0.00	86.76	0.00	0.00	0.00	86.76	0.90
		MW	0.00	0.00	0.00	0.00	17.93	0.00	0.00	0.00	17.93	9.00
217.	2077 132kV Sapphire F (1,	GWh	0.00	0.01	0.00	0.00	35.67	0.00	0.00	0.00	35.68	0.90
		MW	0.00	0.01	0.00	0.00	7.45	0.00	0.00	0.00	7.46	4.00
218.	1022 132kV SapphireFinish	GWh	0.24	0.00	0.00	0.00	21.07	0.00	0.00	0.00	21.31	0.90
		MW	0.08	0.00	0.00	0.00	7.55	0.00	0.00	0.00	7.63	4.00
219.	737 220kV Sarfraz Nagar	GWh	9.19	0.87	0.00	0.61	243.95	1.31	0.00	0.00	255.93	0.90
		MW	3.99	0.47	0.00	0.25	54.53	0.33	0.00	0.00	50.63	25.00
220.	191 132kV Shadman	GWh	137.40	71.71	3.91	5.11	3.57	13.48	0.00	0.00	235.17	0.89
		MW	44.81	27.29	1.49	2.18	19.96	3.59	0.00	0.00	74.49	38.00
221.	369 132kV Shahdara New	GWh	137.52	25.44	1.73	27.75	91.72	11.63	0.00	0.00	295.79	0.86
		MW	44.85	9.68	0.66	11.83	58.12	3.10	0.00	0.00	96.18	57.00
222.	505 132kV Shahdara Scarp	GWh	51.08	1.78	0.00	0.58	28.35	1.29	0.00	0.00	83.08	0.87
		MW	16.66	0.68	0.00	0.25	13.36	0.34	0.00	0.00	23.47	13.00
223.	193 132kV Shahkot	GWh	131.69	10.73	0.02	6.30	213.96	4.37	0.00	0.00	367.07	0.88
		MW	53.31	5.19	0.01	2.55	52.34	1.11	0.00	0.00	94.16	51.00
224.	1010 132kV Shalamar Steel	GWh	0.00	0.00	0.00	0.00	17.17	0.00	0.00	0.00	17.17	0.90
		MW	0.00	0.00	0.00	0.00	8.54	0.00	0.00	0.00	8.54	4.00
225.	194 132kV Shalamar-I	GWh	106.24	13.53	1.99	21.18	185.14	7.78	0.00	0.00	335.86	0.87
		MW	34.65	5.15	0.76	9.03	83.54	2.07	0.00	0.00	101.40	57.00

## POWER MARKET SURVEY

## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO

YEAR :2023-24

SR GRID  NO. NUMBER	NAME OF GRID STATION	DOMESTIC   COMMERCIAL	PUBLIC LIGHTING	SMALL INDUSTRIES	M & L INDUSTRIES	TUBE WELLS			TOTAL OF GRIDSTATION	POWER FACTOR(%) REACT-POWER(Mvar)			
						PRIVATE	PUBLIC	TRACTION					
226.	893	132kV Shalamar-II	GWh	142.19	13.76	7.34	15.54	113.53	12.07	0.00	0.00	304.42	0.86
			MW	46.38	5.23	2.79	6.62	48.71	3.21	0.00	0.00	84.72	50.00
227.	508	132kV Shamky	GWh	61.02	11.13	0.00	3.45	318.22	4.06	0.00	0.00	397.88	0.89
			MW	19.08	4.07	0.00	1.40	132.48	1.03	0.00	0.00	118.61	61.00
228.	372	132kV Sharqpur	GWh	94.17	8.57	0.15	4.40	20.39	20.52	0.00	0.00	148.19	0.85
			MW	32.07	3.50	0.05	1.78	19.52	5.19	0.00	0.00	51.79	32.00
229.	897	132kV Sharqpur Rd.	GWh	50.56	7.72	0.00	3.59	118.73	5.99	0.00	0.00	186.60	0.88
			MW	19.24	3.53	0.00	1.53	32.41	1.60	0.00	0.00	49.55	27.00
230.	971	132kV Sheranwala	GWh	43.58	53.36	2.43	2.11	12.45	2.27	0.00	0.00	116.20	0.90
			MW	14.21	20.30	0.92	0.90	23.33	0.60	0.00	0.00	45.21	22.00
231.	988	132kV Shergarh	GWh	38.10	3.43	0.01	1.58	10.24	10.82	0.00	0.00	64.18	0.85
			MW	16.22	1.81	0.00	0.67	10.26	2.88	0.00	0.00	27.07	17.00
232.	2065	132kV Shoaib Steel	GWh	0.00	0.00	0.00	0.00	31.77	0.00	0.00	0.00	31.77	0.90
			MW	0.00	0.00	0.00	0.00	10.65	0.00	0.00	0.00	10.65	5.00
233.	197	132kV Skp. City	GWh	203.59	25.46	0.84	5.87	241.62	18.40	0.00	0.00	495.78	0.87
			MW	69.91	10.31	0.30	2.38	41.85	4.66	0.00	0.00	97.12	55.00
234.	2060	132kV Spring Medows	GWh	34.03	1.16	0.00	0.46	0.00	0.49	0.00	0.00	36.14	0.90
			MW	11.10	0.44	0.00	0.20	0.00	0.13	0.00	0.00	8.90	4.00
235.	2087	132kV Style Textile	GWh	0.00	0.00	0.00	0.00	32.46	0.00	0.00	0.00	32.46	0.90
			MW	0.00	0.00	0.00	0.00	5.70	0.00	0.00	0.00	5.70	3.00
236.	2048	132kV Sui Gas	GWh	43.66	3.69	0.53	0.00	0.00	0.26	0.00	0.00	48.14	0.90
			MW	14.24	1.40	0.20	0.00	0.00	0.07	0.00	0.00	11.94	6.00
237.	2103	132kV Sui Gas-2	GWh	20.82	2.23	0.34	0.45	0.00	0.48	0.00	0.00	24.33	0.90
			MW	6.79	0.85	0.13	0.19	0.00	0.13	0.00	0.00	6.07	3.00
238.	1050	132kV Sukh Chain	GWh	81.64	9.19	2.65	0.02	38.48	0.72	0.00	0.00	132.70	0.86
			MW	26.63	3.50	1.01	0.01	20.53	0.19	0.00	0.00	38.90	23.00
239.	380	132kV Sukheki	GWh	0.67	0.00	0.00	0.04	0.00	0.68	0.00	0.00	1.39	0.82
			MW	0.31	0.00	0.00	0.02	0.28	0.18	0.00	0.00	0.67	0.00
240.	2018	132kV Sunder Manga	GWh	39.80	6.36	0.22	2.45	51.84	9.04	0.00	0.00	109.71	0.87
			MW	16.30	3.02	0.08	1.04	21.65	2.41	0.00	0.00	35.97	20.00
241.	1007	132kV Sunder( Ind. ES	GWh	0.00	0.00	0.00	0.00	338.99	0.00	0.00	0.00	338.99	0.90
			MW	0.00	0.00	0.00	0.00	78.09	0.00	0.00	0.00	78.09	38.00
242.	206	132kV Sunny View	GWh	94.21	66.33	3.95	3.02	6.85	6.50	0.00	0.00	180.85	0.89
			MW	30.73	25.24	1.50	1.29	11.49	1.73	0.00	0.00	53.98	28.00
243.	2090	132kV TanveerCotton	GWh	0.00	0.00	0.00	0.00	38.39	0.00	0.00	0.00	38.39	0.90
			MW	0.00	0.00	0.00	0.00	7.82	0.00	0.00	0.00	7.82	4.00
244.	2100	132kV Tariq Garden	GWh	29.81	4.50	0.26	1.49	0.05	0.53	0.00	0.00	36.64	0.89
			MW	9.72	1.71	0.10	0.63	0.13	0.14	0.00	0.00	9.33	5.00
245.	2078	132kV Tariq Glass	GWh	0.00	0.00	0.00	0.00	40.20	0.00	0.00	0.00	40.20	0.90
			MW	0.00	0.00	0.00	0.00	9.81	0.00	0.00	0.00	9.81	5.00
246.	2014	132kV Tech Society	GWh	58.16	2.45	0.19	0.49	0.92	0.00	0.00	0.00	62.21	0.90
			MW	18.97	0.93	0.07	0.21	0.85	0.00	0.00	0.00	15.77	8.00
247.	1084	132kV Thokkar	GWh	73.79	25.38	0.06	5.24	45.26	3.64	0.00	0.00	153.39	0.86
			MW	24.07	9.66	0.02	2.24	35.51	0.97	0.00	0.00	54.35	32.00
248.	428	132kV Town Ship	GWh	270.94	66.26	5.33	10.59	130.83	12.95	0.00	0.00	496.90	0.86
			MW	88.37	25.21	2.03	4.51	69.48	3.45	0.00	0.00	144.79	86.00
249.	2101	132kV UET	GWh	41.46	9.48	0.14	0.60	0.28	0.52	0.00	0.00	52.48	0.90
			MW	13.52	3.61	0.05	0.26	0.48	0.14	0.00	0.00	13.54	7.00
250.	399	66kV UIS	GWh	0.00	0.00	0.00	0.00	88.37	0.00	0.00	0.00	88.37	0.90
			MW	0.00	0.00	0.00	0.00	22.92	0.00	0.00	0.00	19.48	9.00

## POWER MARKET SURVEY


## CATEGORY-WISE GRIDSTATION LOAD FOR DISCO

DISCO: LESCO


YEAR :2023-24

SR GRID  NO. NUMBER	NAME OF GRID STATION		PUBLIC	SMALL INDUSTRIES	M & L INDUSTRIES	TUBE WELLS			TOTAL OF GRIDSTATION	POWER FACTOR(%)	
		DOMESTIC	COMMERCIAL	LIGHTING	INDUSTRIES	PRIVATE	PUBLIC	TRACTION	GRIDSTATION	REACT-POWER(Mvar)	
251. 2070	132kV Uni Lever	GWh 0.00	0.00	0.00	23.48	0.00	0.00	0.00	23.48	0.90	
		MW 0.00	0.00	0.00	6.85	0.00	0.00	0.00	6.85	3.00	
252. 963	132kV Valancia	GWh 116.98	19.86	0.28	2.92	0.68	1.01	0.00	141.73	0.90	
		MW 38.16	7.56	0.11	1.25	0.58	0.27	0.00	35.93	17.00	
253. 826	132kV Valgon Sohial	GWh 76.93	8.76	0.12	4.77	253.15	12.56	0.00	356.29	0.88	
		MW 33.37	4.75	0.04	1.93	52.28	3.18	0.00	79.71	43.00	
254. 221	132kV W.Radha Ram	GWh 82.59	9.31	0.00	3.04	148.21	30.95	0.00	274.09	0.87	
		MW 29.96	4.06	0.00	1.23	18.64	7.83	0.00	52.46	30.00	
255. 959	132kV Walton Road	GWh 192.64	35.05	1.07	4.48	13.31	3.69	0.00	250.24	0.90	
		MW 58.21	12.46	0.41	1.91	13.46	0.98	0.00	65.57	32.00	
256. 503	220kV Wapda Town	GWh 224.64	19.36	1.05	5.47	71.47	3.07	0.00	325.04	0.90	
		MW 73.27	7.37	0.40	2.33	27.47	0.82	0.00	83.74	41.00	
257. 2092	132kV Wapda Town Skp	GWh 36.44	0.86	0.00	0.34	0.00	0.48	0.00	38.12	0.90	
		MW 16.64	0.49	0.00	0.15	0.00	0.13	0.00	14.79	7.00	
258. 401	132kV Warburton	GWh 96.09	9.06	0.00	4.03	263.80	30.30	0.00	403.28	0.88	
		MW 36.56	4.14	0.00	1.72	46.02	8.07	0.00	82.03	44.00	
259. 970	132kV Wassanpura	GWh 70.87	8.69	3.99	7.30	10.60	9.07	0.00	110.52	0.85	
		MW 23.12	3.31	1.52	3.11	15.16	2.42	0.00	36.47	23.00	
260. 781	132kV Willongton Mall	GWh 247.51	38.78	2.79	2.93	13.95	2.89	0.00	308.86	0.90	
		MW 80.73	14.76	1.06	1.25	23.62	0.77	0.00	91.64	44.00	
261. 1012	132kV Yaqoob Steel	GWh 0.00	0.02	0.00	0.00	33.79	0.00	0.00	33.81	0.90	
		MW 0.00	0.01	0.00	0.00	16.13	0.00	0.00	16.13	8.00	
262. 658	132kV Zahoor.Textil	GWh 0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.90	
		MW 0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
<b>TOTAL OF DISCO :</b>		GWh 19704.08	3880.98	222.97	1157.39	13747.76	2902.74	0.00	0.00	41615.91	
		MW 4335.43	964.06	55.68	320.97	3710.35	495.65	0.00	0.00	7787.93	

Figure 1- 10: Distribution Network Map





**Figure 1- 11: Distribution Network Map (Lahore Ring)**



## **Disclaimer**

All data used in this report are provided by LESCO.  
Planning Power, NTDCL does not own any error responsibility.







## LAHORE ELECTRIC SUPPLY COMPANY

JOINTLY PREPARED BY LESCO  
UNDER THE SUPERVISION OF  
PLANNING POWER, NTDC  
MAY 2015

