

WATER TEMPERATURE RECORD SHEET IN ACCORDANCE WITH L8 2001

HWS (Hot Water Services) above 50 °C CWS (Cold Water Services) below 20 °C	Water to be run for 1 minute & temperature recorded Water to be run for 2 minutes & temperature recorded
Client: Open Awards, Estuary Commerce Centre 17 De Havilland, Speke, Liverpool L24 8RN	Date: _____ Engineer(s): _____

Tap Ref/ Location	Time	Temp	Comments
Ground Floor			
Teapoint (Hot WH1)	1:00	°C	
Teapoint (Cold)	2:00	°C	
Male WC (Hot WH2)	1:00	°C	
Male WC (Cold)	2:00	°C	
Disabled WC (Hot WH2)	1:00	°C	
Disabled WC (Cold)	2:00	°C	
First Floor			
Teapoint (Hot WH3)	1:00	°C	
Teapoint (Cold)	2:00	°C	
Female WC (Hot WH4)	1:00	°C	
Female WC (Cold)	2:00	°C	
Disabled WC (Hot WH4)	1:00	°C	
Disabled WC (Cold)	2:00	°C	

All water treatment programmes that we manage on your behalf are designed to comply with the Health & Safety Executive document ACOP L8 2001 – The Control of Legionella Bacteria in Water Solutions, as a minimum requirement. For details of 'L8 2001' please refer to Section 3 of the PPM Manual.

Water Services Schematic

