

Building Type	County	
School	Gilliam	
Street		
1200 Main St		
City	State	Zip
Arlington	OR	97812
Latitude	Longitude	
45.7124	120.19996	
Tracking Code	Inspection Date	
RVS in 2006	8/29/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Arlington High School

Final RVS Score

Final Type Final Score

W2

0.5

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
44		1952	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
29359	1	No	Yes

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Steps in Elevation View: Single Change
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
Out of Plane Lateral-Force-Resistance Elements	Building On Hill or Sloped Site

Falling Hazards	Poor Conditions
Other: Brick Veneer	None
None	None
None	None



W General Site



NW Elevation View
YR 2000 CONST



N Plan Irregularity Tertiary



N Primary Structural Type



NE Elevation View



NE Primary Structural Type
WOOD SIDING BENEATH BRICK



SE Vertical Irregularity Tertiary



SE Plan Irregularity Primary



S Primary Structural Type

Building Type	County	
School	Gilliam	
Street		
1200 Main St		
City	State	Zip
Arlington	OR	97812
Latitude		Longitude
45.71203		120.19993
Tracking Code		Inspection Date
RVS in 2006		8/29/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Tertiary		0	0	0	0	0	0	0	0	0

Arlington High School

Final RVS Score

Final Type Final Score

C2

0.3

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
44		1952	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	Yes

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
None	Building On Hill or Sloped Site

Falling Hazards	Poor Conditions
Other: Brick Veneer	None
None	None
None	None



W Elevation View



NW Elevation View



E General Site
NEW CMU AND GYM BEYOND



SE Plan Irregularity Primary




S Primary Structural Type
FORM MARKS



SW Elevation View



S Primary Structural Type



SW Primary Structural Type
W WALL IS WOOD STUD ACCORDING TO MAINT STAFF