

ADDENDUM NO. 1
CONTRACT DOCUMENTS
FOR
2016 POLE TEST AND TREAT

Bid Opening June 1, 2016
Bid Number 161006

TO ALL PLANHOLDERS:

The plans and specifications for the above-named project are hereby amended in the following particulars; all other items and conditions remaining unchanged:


SECTION III –
SPECIFICATIONS

Please replace **11. MATERIALS** a. 1) with the following:

- 1) Exterior pole treatment below ground level; The District will allow the Paste Form of Cu-Bor, MP400Ext, MP 500 EXT and/or Cop-R-Plastic.

This addendum consists of one (1) page. This addendum must be acknowledged and included with any bid submitted.

PUBLIC UTILITY DISTRICT
NO. 1 OF CLALLAM COUNTY

By: 
Dennis Shaw, General Superintendent

Date: 5/23/16

Acknowledged by:

(Bidder)

By: _____

Date: _____