

Warranty Registration System

Help us to serve you better by registering your product for Warranty

- **Web** Registered at www.onida.com
- **Telephone** Call Centre No. 0XX-39889000(0XX-STD Code of State Capital)
- **Post / Visit** Post the Warranty Registration Card & Service Centre Copy or Visit the Nearest Service Centre.



MIRC Electronics Ltd.,

Onida House, G-1, MIDC, Mahakali Caves Road, Andheri (East), Mumbai – 400 093



3 STAR



Model: S09TRD-N4 / S12TRD-N4 / S18TRD-N4



AIR CONDITIONERS

The unit displayed is for representational purposes only. Actual unit may vary.

The Onida Ethos

Putting customers at the center of our existence.

The ONIDA logo is presented in a white, serif font within a dark grey, rounded rectangular box. Above the box, a large black speech bubble shape contains the main text of the advertisement. A small black circle is positioned above the box, and a larger black circle is positioned to its left, suggesting a thought bubble or a drop.

IMPORTANT :

- Please read this owner's manual carefully and thoroughly before installing and operating your room air conditioners.
- Please retain this owner's manual for future reference after reading it thoroughly.

Dear Customer

Congratulation on buying ONIDA Air Conditioner.

Your Air Conditioner comes with ONIDA Guarantee of Quality as detailed in the manual.

ONIDA takes great pride in providing its customers with state-of-the-art products that adheres to international quality standards.

ONIDA is committed to following quality policy laid by our chairman and managing director Mr. G. L. Mirchandani.

“We are committed to quality and strive for continuous improvement through innovation and human development to give customer better value for money always”

ONIDA stands committed to provide the ultimate customer satisfaction, as nothing brings us greater joy than having satisfied customers of ONIDA.

At ONIDA, feedback and suggestions based on your product usage experience is greatly appreciated.

Please contact to us at response@onida.com

*G. Sundar
Chief Executive Officer*

A smaller version of the ONIDA logo, consisting of the word "ONIDA" in a white serif font inside a dark grey rounded rectangle.

The Onida Ethos

Understanding customer
lives, dreams and
aspirations better
than anyone else.

ONIDA

CONTENTS

| | |
|---------------------------------------|----|
| Salient Features | 1 |
| Inside Overview | 2 |
| Indoor Unit Display | 3 |
| Remote Overview | 4 |
| Operations | 5 |
| General Instructions for Installation | 10 |
| Installation Sketch | 13 |
| Installation of Model | 14 |
| Take care of your Air Conditioner | 17 |
| Precautions to be taken | 18 |
| Trouble Shooting Chart | 19 |
| Installation and Satisfaction Report | 21 |
| Warranty Terms & Conditions | 23 |
| Preventive Maintenance Service Coupon | 25 |
| Warranty Card(Customer Copy) | 27 |
| Warranty Card(service Centre Copy) | 29 |

ONIDA

The Onida Ethos

Delivering products that enrich customer lifestyle reliably, stylishly and thoughtfully.

ONIDA

SALIENT FEATURES

0.8T / 1.0T / 1.5T Split Air Conditioner
Model Code : **S09TRD-N4 / S12TRD-N4 / S18TRD-N4**




3 STAR


- **Aesthetics:-**
 - a) Unique Power Trendy Panel
- **Performance:-**
 - a) High BTU, High Efficiency Compressor
 - b) Trapezoidal Inner Grooved Tube
 - c) Large L - Shaped Condenser Coil
 - d) High RPM Fan Motor with High Flow
 - e) High Technology 3 Star Energy Efficient
- **Features:-**
 - a) Turbo Mode
 - b) Sleep Mode
 - c) Child Lock
 - d) Blow Operation
 - e) Full Function LCD Remote
- **Safety & Reliability:-**
 - a) Low Deration Factor
 - b) Hydrophilic Fins
 - c) 5-Stage Epoxy Polyester Painting
 - d) Rugged Construction With Thicker Gauge Steel

ONIDA

INDOOR UNIT



OUTDOOR UNIT



Display on the indoor unit.


For the icon of LED windows, only relevant icons will light up with their displays on.



- ☀ Heat pump mode
- ❄ Cool mode
- 🌡 Temperature display
- 🔌 Power/Run
- 💧 Dry mode
- 📶 Remote Signal Receiver

Heat Pump mode -
Not available in models S09TRD-N4 / S12TRD-N4 / S18TRD-N4.

REMOTE OVERVIEW



1. Open back cover and put 2 Nos. AAA size alkaline batteries.
2. The remote signal can be reached upto six metres from the indoor unit.
3. When the button is pressed on remote, indoor unit will "beep" once, indicating the receipt of signal. If no "beep" sound is heard, press the button once again.
4. Remove batteries if remote control has not been used for long time.
5. Direct heat mode is not available with all models.


ONIDA

OPERATIONS


Operating Your Air Conditioner:

Your Split Air Conditioner can be conveniently operated using the intelligent cordless remote control.

1. Switch on the MCB.
Press **ON/OFF** button on remote handset to switch ON the AC.
The "RUN" light on Indoor unit will glow ON.
Your AC switches on with parameters that were set before power was switched off. The unit receives the signal with "BEEP" tone and your AC starts operation.
Time Delay: To protect the compressor, a time delay is incorporated in the circuit. The Time Delay ensures that the compressor switches ON only after a delay of about 3 minutes.
2. By Pressing the "MODE" button each time you can select either Auto, Cool, Dry, Fan or Heat Mode.



3. Press the "**FAN**" button to set the fan speed. Each press changes the fan speed from Low-Med.- High-Auto Fan speed. The selected fan setting symbol can be seen on the LCD.
4. The Set Temp. is displayed on LCD.
5. To switch off the AC, press the same **ON/OFF** Button.



Note: Heat Mode is not applicable for this model.

Setting the Desired Room Temp.:

You can set the temp. at which you would like your room to be.

Press "**+**" button to increase the set temp. On every press, the temp. increases by 1°C.

Press "**-**" button to decrease the set temp. On every press, the temp. decreases by 1°C

The two digit display shows the changing set temp. on LCD

The setting temp. range is from 16- 30°C.

ONIDA

OPERATIONS

Your split AC operates in one of four modes, COOL-DRY-FAN-AUTO. The modes button cyclically chooses between the four operating modes.

The COOL mode:


In the cool mode, the compressor is in operation and your AC functions in the standard operating mode, cooling your room to the desired set temp.

1. Press "MODE" button to cyclically step through the COOL, FAN, DRY & AUTO modes and stop when cool mode is selected.
2. Cool mode symbol can be seen on the LCD panel when you select the cool mode.

In this mode, you can change the temp. settings by pressing "+" and "-" temp. buttons.

You can change the fan speed setting by pressing FAN button.


3. If the Room temp. is more than the set temp., then the compressor & outdoor FAN will remain ON and perform the Cooling operation. If the room temp. achieves the temp. less than set temp., then the Compressor & Outdoor FAN will remain OFF.



The DRY Mode:


In the DRY mode, your AC reduces the humidity within the room faster.

1. Press "MODE" button to cyclically step through the COOL, FAN, DRY & AUTO modes and stop when DRY mode is selected.
2. DRY mode symbol can be seen on the LCD panel when you select the DRY mode.
3. Indoor FAN will run at low speed.
4. Temperature can be changed.



The FAN Mode:

1. Press "MODE" button to cyclically step through the COOL, FAN, DRY & AUTO modes and stop when FAN mode is selected.
2. FAN mode symbol can be seen on the LCD panel when you select the FAN mode.
3. In FAN mode, only Indoor FAN will run at set speed and Compressor & Outdoor Fan will remain off.
4. In this mode, you can change the Indoor FAN Speed.




ONIDA

OPERATIONS

The AUTO Mode :

1. Press "MODE" button to cyclically step through the COOL, FAN, DRY & AUTO modes and stop when AUTO mode is selected.
2. AUTO mode symbol can be seen on the remote display when you select the AUTO mode.
3. In AUTO mode, the fan speed can be changed by pressing FAN button.
4. In AUTO mode, the unit automatically runs at preset temp.



LIGHT Operation:

You can ON/OFF the LED DISPLAY on indoor unit by press "LIGHT" button on remote control.

CLOCK Setting:

Press the "CLOCK" button on remote to set the real time clock, clock time will blink on remote display. Press "+" or "-" keys to set the desired time. press again after setting to confirm the change.

TIMER Operation:

You can program your split AC to switch itself ON or OFF at particular time.

Maximum set time is 24 hrs, with 1 min increment.

ON TIMER:

When the AC is "OFF" (in standby), press "TIMER ON" Button on remote to use this feature as the ON TIMER. (make sure that MCB switch is "ON")

The "TIMER ON" symbol seen on the remote display.

For EXAMPLE:

Suppose you want to switch ON the AC at 08:00.

Press "TIMER ON" button, when AC is in OFF condition.

Press "+" or "-" buttons to set 08:00 to switch on AC. Press again

"TIMER ON" after setting the time to confirm Timer ON.


Display on Remote will show "TIMER ON".

TIMER OFF FUNCTION:

When the AC is "ON", press "TIMER OFF" Button on remote to use this feature as the OFF TIMER. The "TIMER OFF" symbol seen on the remote display.

For EXAMPLE:

Suppose you want to switch OFF the AC after 08:30. Press "TIMER OFF" button, when AC is in ON condition.



ONIDA

OPERATIONS

Press “+” or “-” buttons to set 08:30 to switch off AC. Press again “TIMER OFF” after setting the time to confirm Timer OFF. Display on Remote will show “TIMER OFF”.

CANCEL TIMER:

If you want to cancel the Timer what you set before. Press once “TIMER ON” or “TIMER OFF” buttons, and it will cancel the Timer. The “TIMER OFF” or “TIMER ON” display on LCD Panel of remote will go OFF.

BLOW OPERATION:

To set on BLOW Operation, Press “BLOW” button on the remote controller. BLOW is operational, when you turn off the machine the indoor fan will continue to run for a few minutes before switching off. The purpose is to ensure that the evaporator is at the same temperature as the indoor temperature.




TURBO OPERATION: To switch on the turbo operation press “TURBO” button on the remote controller. In TURBO mode the unit will run at the maximum cooling with highest Fan Speed. When pressing the MODE or FAN button, this function will be canceled.



CHILD LOCK Function: Press + and - keys on the remote controller simultaneously to lock or un-lock the keypad. When the key pad is locked the lock icon will be displayed on the remote controller LCD.

SLEEP Operation:

Press “SLEEP” button on remote to switch on sleep operation. In “SLEEP” mode your air conditioner increases the temperature by 1°C for every hour that it operates, After 2 hours and after the increase in set temp. by 2°C your AC maintains the same temp. at that level without further increase. Under Fan and Auto modes, sleep function is not available. To cancel the Sleep mode, press again the Sleep button.

TEMP Function:

Press once TEMP button, will show “” on remote display and set temp. will be shown on unit display. Press again will show “” on remote display and unit will show room temp. for 5 sec and again set temp will be displayed on indoor. Press again will show “” on remote display and set temp. on unit display. Next press, unit will be out of TEMP operation.



ONIDA


OPERATIONS


Air Flow direction Adjustment:

Your split AC has oscillating louvers for uniform cooling around your room. You can stop the oscillation if you so desire.

Up/Down Air Direction Adjustment:


1. Press “SWING” button to set swing angle, which circularly Changes as defined below:



Note: This remote controller is universal. If it receives three kind of following status, the swing will remain original. 

Left/Right Air Direction Adjustment:

Move manually, the left right air louver at desired position as shown in following figure.




Emergency Operation Switch:

In case the batteries in the remote are worn out, or remote is faulty or missing, use Emergency operation switch (AUTO) to ON/OFF AC.

Every time the switch is pressed, it changes in sequence of COOL and STOP. In Emergency operation mode the set temperature will be 25°C, Fan speed will be Auto and Up/Down Air louvers are in swinging mode.

To access emergency switch, open the grill as shown in the figure.




ONIDA

GENERAL INSTRUCTIONS FOR INSTALLATION


Locating the indoor and outdoor units properly will help optimise the performance of your airconditioner. While your Onida / Dealer's Technician will be happy to guide you on the best location for your airconditioner, here are a few helpful hints.

Locating the Indoor Unit


- Locate the IDU for the best cool air circulation. Preferably, there should be no obstructions nearby, as shown in the adjacent figure.



- Do not locate the unit directly opposite a door which is opened frequently. The cold air will go out of the room each time the door is opened, as shown in the adjacent figure.



- All indoor units will form condensate water. Please ensure that the condensate can be drained out of the room to a toilet / pantry, etc. The installation engineer will make sure that a "U" bend is provided in the drain to prevent insects from coming into the room through the drain tube, as shown in the adjacent figure.




GENERAL INSTRUCTIONS FOR INSTALLATION


Locating the Outdoor Unit

The outdoor unit houses the compressor, condenser fan and electrical components. The heat removed from the room is expelled to the atmosphere through the outdoor unit.


Once again, the Onida / dealer's Technician will ensure optimal installation of the ODU for you. However, the following information will be of interest to you.




- The Outdoor Unit can be mounted on a wall, sunshade or skirting.



- Ideally, the ODU should not be too far away from the IDU; the recommended distances are marked in the adjacent figure.



- Ensure that air can pass freely through the unit. Please allow at least 2 meters free space on the air outlet side, and 0.3 meters on the air inlet side.



- If more than one ODU is to be installed, they must be properly separated, so that the warm air from the outlet of one does not enter the inlet of the other.

GENERAL INSTRUCTIONS FOR INSTALLATION

- Avoid long and complicated routing between the IDU and ODU, as shown in the three adjacent figures.

- Too long _____
- Too high _____
- Too many bends _____


- The ODU must be placed on strong frame or support. If mounted on a wall, please ensure that the wall is thick enough and that the frame is supported adequately.

- Finally, it is most important for the ODU to be easily accessible to the service engineer. It is advisable to discuss the same with the engineer before deciding upon the location of the unit.

If the ODU is to be located on a high ledge, adequate space must be provided for the service engineer to service the unit. It is a good idea to provide a catwalk (a platform) around the unit and access door / window to the Unit.


Electrical outlet

After the location of the outdoor unit and indoor unit is finalised, you must provide a suitable electrical outlet near the indoor unit.



ONIDA

INSTALLATION SKETCH



- The dimensions of the space necessary for correct installation of the appliance including the minimum permissible distances to adjacent structures

This is just the schematic plan, please refer to the actual product.

ONIDA


INSTALLATION

■ INDOOR UNIT

1. Fitment of mounting plate

The mounting plate should be fitted on the structural part of wall on which indoor unit is to be installed.


2. Drill two holes at a distance of 450 mm between them for the expansion bolts.



| Model | Dimensions in mm | | |
|---------------|------------------|-----|-----|
| | A | B | C |
| 0.8 T & 1.0 T | 150 | 150 | 155 |
| 1.5 T | 175 | 260 | 245 |


■ Drill on the wall

Confirm the position of holes and drill holes of diameter 65 mm on the wall



■ Connecting of cables

1. Open the front panel
2. Dismantle the electric box cover and fastener
3. Connect the cable
4. Reassemble the fastener and electric box cover.




ONIDA


INSTALLATION

■ Installation of indoor unit

After putting the pipe assembly through the wall, attach the indoor unit to the mounting plate on the wall as shown in the figure.



■ Installation of outdoor unit




- The connecting cables must be clipped together.
- Special cable to be used to connect indoor unit and outdoor unit.
- The electric box cover must be mounted on its position on outdoor unit.

■ Connecting of pipes

| Pipe | Diameter of pipe | Torque (N · m) |
|-------------|-----------------------------|----------------|
| Liquid pipe | 6.35 mm (0.8T, 1.0T & 1.5T) | 13.7--17.6 |
| Gas Pipe | 9.52 mm (0.8T) | 13.7--17.6 |
| Gas pipe | 12.7 mm (1.0T & 1.5T) | 49.0--56.4 |

■ Sealing the wall hole and clamping the pipe

- Use putty to seal the wall hole.
- Use pipe fastener to clamp the pipe on wall




ONIDA

INSTALLATION

Discharge the air of the units:

It can used as vaccum pump.
Remove screw cap of closing valve and gas charging hole; Open the closing valve with Allen wrench(turn 90 clockwise), then push the gas hole for about 10 seconds, (When a gas like fog appears, it indicates that the air of unit has been discharged) put back the screw cap of gas charging hole. Do the leak test with leak detector or soap water.




Add refrigerant

- If the connecting pipe is longer than 7 meters, add refrigerant as needed. Add amount $A = (L - 7m) 15g/m$.
(A: add refrigerant amount, L: the length of connecting pipe)

| | | | | |
|-----------------------------------|---|----|----|----|
| the length of connecting pipe (m) | 7 | 8 | 9 | 10 |
| add amount (g) | 0 | 15 | 30 | 45 |

- Add refrigerant with the spring balance, as specified above.



Test

- Proceed leak test (with leak detector or soap water.) and inspect connecting cables before test operation.
Test procedure: (Control by emergency operation switch or remote controller) For detailed operation, see OPERATION OF AIR CONDITIONER in the manual.



TAKE CARE OF YOUR AIR CONDITIONER


Most of the maintenance work on your air conditioner, during warranty and subsequently under the maintenance contract, will be handled by a trained technician. However, there are some simple maintenance jobs that you, as a user, should carry out on your own.




- Lift the cover by applying gentle pressure on both sides and lift it upwards

- The filters will be visible

- Lift the filters slightly upwards



- Pull out the filters



- Wash the filters under a tap until they are clean



- Do not use detergents for cleaning the filter.



PRECAUTIONS TO BE TAKEN

Do's (✓)

- Seal all air gaps in the room
- Choose the right temperature to avoid over cooling
- Ventilate the room regularly.
- Switch off the power supply if not in use for long.
- Unplug the unit while cleaning.

Don't's (X)

- Don't leave the doors and windows open when the air conditioner is on.
- Don't use hot water to clean your front grill
- Don't use scouring powder, harsh soaps, wax or polish on the grill.
- Don't switch on the air conditioner immediately after switching it off. Wait for 2 minutes.
- Don't operate with a clogged filter
- Don't block air intake & outlet vents
- Don't change setting unnecessarily.

TROUBLE SHOOTING CHART

| Symptoms | Possible Causes | Suggested Remedy |
|--|---|---|
| Unit does not start | MCB has tripped | Reset MCB |
| | Fuse has burnt | Replace fuse wire |
| | Input voltage to the stabiliser is below acceptable range | If the input voltage to the stabiliser is below the acceptable range, the AC will not operate |
| Units does not cool (Even after the normal Time Delay of approx. 2/3 minutes for compressor to start) | The On/Off key is not pressed | Press the On/Off key on the control panel or the remote |
| | The airflow paths are not free | Remove all obstructions to make the airflow paths free |
| | The Units is in the fan mode | Change to COOL mode |
| | Selected temperature is more than room temperature | Make the selected temperature less than room temperature |
| | Air-filter is not clean | Clean the air-filter |

Note: If the unit still does not work, or if any other types of symptoms are encountered, shut off the mains (switch fuse unit) and call the service engineer.

INSTALLATION & SATISFACTION REPORT

Customer Name : _____

Address _____

Phone[O] _____ [R] _____

| Unit Model | Unit Serial Number | Dealer Name |
|------------|--------------------|-------------|
| | | |

| Invoice Number | Date of Purchase | Date of Installation |
|----------------|------------------|----------------------|
| | | |

| | | | |
|---------------|--|--------------------|--|
| MCB Rating | | Current (Amps.) | |
| Cable Size | | Ambient Temp. (°C) | |
| Earthing | | Room Temp. (°C) | |
| Stabiliser | | Grill Temp. (°C) | |
| Input Voltage | | Remote Operation | |

Customer's Response : To be filled up by the Customer

- Installation completed within:
12hrs (), 24 hrs (), 36 hrs (), more than 36 hrs ()
- How did you find the behavior of the Engineer :
Excellent (☺), Good (☹), Not satisfied (⊗)
- Overall rating of the service:
Excellent (☺), Good (☹), Not satisfied (⊗)
- Suggestion if any:

| Job Number | Engineer's Signature | Customer's Signature |
|------------|----------------------|----------------------|
| | | |

WARRANTY TERMS AND CONDITIONS

M/S. MIRC ELECTRONICS LTD, WARRANTS THIS ONIDA AIR CONDITIONER (except the front grill, knobs, remote unit and add-on plastic parts) TO THE ORIGINAL PURCHASER TO BE FREE FROM DEFECTS IN MATERIALS AND WORKMANSHIP WITHIN ONE YEAR FROM THE DATE OF PURCHASE AS PROVIDED IN THE WARRANTY REGISTRATION CARD.

WARRANTY FOR COMPRESSOR:

MIRC ELECTRONICS LTD, HEREAFTER WARRANTS TO THE PURCHASER OF THIS ONIDA AIR CONDITIONER THAT FOR A PERIOD OF SIXTY MONTHS FROM THE DATE OF INVOICE.

WE WILL REPAIR/REPLACE THE COMPRESSOR WHICH PROVES UPON INSPECTION BY US OR ANY OF OUR AUTHORISED SALES DEALERS TO HAVE BEEN DEFECTIVE DUE TO MANUFACTURING DEFECT.

This warranty is subject to terms and conditions as mentioned below:

1. This warranty shall be valid only for the said period of 12 months as specified above, irrespective of whether the said unit has been in use or not for any reason whatsoever, or the unit is moved from one location to another. Warranty does not cover accessories external to the equipment.
2. The warranty period specified above shall include time taken for repairs, replacements, break-downs, transit time etc. No notice of expiry period of warranty will be given by the company.
3. This warranty shall stand automatically terminated in the event of the said unit being serviced, repaired, installed, de-installed, re-installed or otherwise attended to by any person or organization or agency or by the said purchaser himself other than the authorized representative of the company.
4. Parts of the unit replaced or repaired under the terms of this warranty are warranted only for the remaining period of the original warranty period.
5. For attending any service call under this warranty beyond the municipal limits of the locality in which the authorized representative/dealer is situated (outstation locations), all to and fro travelling and other incidental expenses as prevailing from time to time incurred in connection with the visit of the service personnel, technicians, etc shall be borne by the said purchaser and shall be payable in advance. Additionally, all expenses incurred by the authorized representative /dealer in collecting the said unit or any part thereof from such outstation locations and its return to the original location shall be borne by the said purchaser.
6. Any loss of refrigerant caused due to sabotage, improper handling or treatment, carelessness, accident, fire, flood earthquake or any natural calamity any corrosive action on the original refrigerant pipes, fittings, valves etc for whatever reasons, shall not be covered under this warranty.
7. In the event of any change in the location of the unit during the warranty period, this warranty shall become null and void unless the fact of the proposed change is communicated in writing to the authorized dealer at least seven (7) days prior to the said change. On receipt of such information the authorized dealer or any of its counterparts shall arrange for de-installation of the said unit on chargeable basis. However, in the event of any damage occurring to the unit or to any of its parts during the course of its transit by the said purchaser, repair or replacement, the said unit or any part thereof damaged shall not be covered by this warranty.

8. It shall be the absolute discretion of the company to a) effect the repairs or replacement of parts whether at the site of installation or at any service centre, and b) have the job attended to either by the Company's service personnel or its authorised dealer
9. This warranty is in the nature of and for the purpose of set forth herein above and in particular the Company shall not in any event be liable for direct, indirect, incidental or consequential loss or damages to either the said purchaser and /or his property or any other third party.
10. The AC is designed to operate at a range (230V + /- 10%). Any failure due to operation of the machine beyond these limits will not be covered by the above warranty.

Customer shall ensure that a stabilizer is installed in those areas where voltage is not available within the warranty range (230V + /- 10%). The stabilizer should be of any reputed manufacturer, tested and recommended by the Company.

11. The purchaser should preserve the original invoice for necessary verification and produce, as and when required.
12. Warranty null and void if:
 - i. The Air Conditioner is not purchased from the authorized dealers of the company.
 - ii. The Service Centre copy of warranty card is not received within 10days of date of purchase at the nearest Authorised Service Centre.
 - iii. Any damage is caused by accident, mishandling, tampering with installation, or negligence in following instructions of the user manual issued by Company.
 - iv. Any damage is caused by improper electrical circuit outside the unit or by any defective electrical supply
 - v. At any time, during the warranty period if any part of the unit is tampered with, altered, repaired or serviced by any unauthorized person, not being the authorized representative of the company or its authorized dealers
 - vi. The serial number of the unit or any part thereof is damaged, defaced, altered, obliterated, or tampered with or removal for any reason whatsoever
 - viii. The unit is unauthorisedly moved from its original place of installation or re-installation
13. None of the employees and /or Authorized Dealers of the Company have any authority whatsoever to vary the terms and conditions of this warranty.
14. This warranty shall be deemed to have been issued at Mumbai, state of Maharashtra and courts at Mumbai shall have exclusive jurisdiction on matters covered by or following from this warranty, and the original purchaser alone shall have cause of action arising out of the transaction.



Preventive Maintenance Service



Customer Identification Number: _____

Preventive Maintenance Service 1

Date: _____

Unit Model: _____

Customer Identification Number: _____

Sr. No: _____

Name of the customer: _____

Name of Serviceman: _____

Installation address: _____

Date: _____ Time: _____

Phone: _____ Mobile: _____ Fax: _____

Sign. of Serviceman _____

E-mail: _____

Unit model: _____ Serial Number: _____

Service report number: _____

Customer's Signature: _____ Name: _____

Preventive Maintenance Service



Customer Identification Number: _____

Preventive Maintenance Service 2

Date: _____

Unit Model: _____

Customer Identification Number: _____

Sr. No: _____

Name of the customer: _____

Name of Serviceman: _____

Installation address: _____

Date: _____ Time: _____

Phone: _____ Mobile: _____ Fax: _____

Sign. of Serviceman _____

E-mail: _____

Unit model: _____ Serial Number: _____

Service report number: _____

Customer's Signature: _____ Name: _____



MIRC Electronics Limited Warranty Card Service Centre Copy

ONIDA

Serial No. _____

Customer Details

Title: Mr Ms Mrs M/s
 Name: _____

Residence Address: _____

Dist: _____ Pin: _____

State: _____ Occupation: _____

Tel: (____) _____ Res: (____) _____ Fax: _____
Code Code

Mobile No: _____ Email: _____

Product Details

Please Tick The Appropriate Product Colour TV B&W TV DVD Washing M/C. AC Plasma TV Rear Projection TV
 Microwave Oven LCD TV

Model No: _____

Serial No _____

Please Refer Sticker On Back Cover Of Your Product

Purchase Date
Day Month Year

Bill No. _____

| Dealer's Name & Address |
|-------------------------|
| |
| |
| |
| Signature |

I Accept The Terms And Conditions of The Warranty

Customer Signature

Thank you for selecting a World Class product and we assure you that it will perform as per your expectations

We thank you for taking your time to complete this form. All Information Provided by You will be Kept Confidential.

(Please Fill In, Tear off, Fold and Mail this form to Reach us within 10 days of the Product Purchase.)

We welcome your Valuable Suggestions, if any, to Improve our Products and Services :

FOR OFFICE USE ONLY

Customer Code: _____

Branch: _____

Mirc Electronics Ltd.

Note: Company Will Not Be Responsible For The Loss Of This Form During Transit.

For Other Details on Our Products & Services Log On To www.onida.com



ONIDA

BUSINESS REPLY ENVELOPE

**ONIDA CUSTOMER RELATION CENTRE
Adonis Electronics Pvt Ltd.**

Onida House - II Mukund Ground Floor,
Mahal Industrial Estate, off. Mahakali Caves
Road, Andheri East, Mumbai, Maharashtra,
India - 400093