ANO-1 ANO-2		] GGNS	☐ IP-2		IP-3	
🖸 JAF 🗌 PNPS	$\boxtimes$	RBS			N3	
🗆 NP-GGNS-3 🛛 NP-RBS-	3					
CALCULATION (1 COVER PAGE	EC # <u>2</u>	7437		<sup>(2)</sup> P	age 1 of	<u>22</u>
(3) Design Basis Calc. 🛛 YES 🗌 NO (4) 🖾 CALCULATION 🔄 EC Markup						
<sup>(5)</sup> Calculation No: G13.18	6.2-ENS*0	04			<sup>(6)</sup> Rev	ision: 1
<ul> <li>(7) Title: Loop Uncertainty Determination for DIV III Loss of Voltage Relays –</li> <li>(8) Editorial</li> <li>(8) GE Model NGV Undervoltage Relay</li> <li>(8) YES X NO</li> </ul>				orial ⊠ NO		
<sup>(9)</sup> System(s): 302		<sup>(10)</sup> Revi	ew Org (Depart	ment): N	ISBE3 (I&	C Design)
(11) Safety Class: (12) Component/Equipment/Structure Type/Number:						
Safety / Quality Related		E22-S004	-27N1	E22-S	004-27N2	
Augmented Quality Pro	gram	•				
Non-Safety Related						
<sup>(13)</sup> Document Type: F43.02						,
<sup>(14)</sup> Keywords (Description/ Codes):	Topical		an da ha da ka			
uncertainty, calculation			<u> </u>			
		REVIE	WS	T		
(15) Name/Signature/Date Chuck Mohr (see EC 11753 for signature)	(16) (s	Name/Sig Justin V ee EC 11753	nature/Date Vaters for signature)	<sup>(17)</sup> Na (see E	<b>me/Signa</b> Paul Mata C 11753 for	ature/Date zke signature)
Responsible Engineer		sign Verifi viewer	ier	Supe	ervisor/A	pproval
	IX Cor	mments At	tached	🖂 Co	mments.	Attached

· .

EN-DC-126 REV 4

•

.



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 2 OF 22

CALCULATION REFERENCE	CALCULATION NO:G.13.18.6.2-ENS*004					
SHEET REVISION: 1						
I. EC Markups Incorporated (N/A to NP calculations) None						
II. Relationships:	Sht	Rev	Input Doc	Output Doc	Impact Y/N	Tracking No.
1. EN-DC-126		002	R		N	
2. EN-IC-S-007-R		000	Ø		N	1
3. 7224.300-000-001B		300	R		N	1 1
4. 201.130-186		000			N	
5. 215.150		006			N	1 1
6. G080-1344		000			N	11
7. 6221.418-000-001A		300			N	
8. F137-0100		000			N	1 -1
9. 0221.418-000-008		300			N	
10. EE-001M		009	N		N	
11. GE-828E537AA	003	028			N	
12. GE-828E537AA	007	030			N	
13. GE-828E537AA	008	028	Ø		N	1
14. GE-828E537AA	011	029	N		N	
15. STP-302-1604		018			N	
16. GE-152D8167	005	004			N	
17. G13.18.6.3-012		000	R		N	
18. EDP-AN-02		300			N	
19. G13.18.3.1*002		004		2	Y	EC11753
20. GE-152D8167	003	006	N		N	<u> </u>
21. GE-152D8167	003A	006			N	
22. GE-152D8167	004	007			N	
23. BE-230D	1	010	Ø		N	
24. 0221.418-000-049	1	300			N	
		<u> </u>	<u> </u>		1	<u> </u>

۰.

	and the second
-	and and a subset of the second se
i	ENTERGY

CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 3 OF 22

#### III. CROSS REFERENCES:

1. Indus Asset Suite Equipment Data Base (EDB)

2. Technical Specifications section B3.3.8.1

3. ANSI Standards C57.13 (1993), C37.90 (1989)

4. Multi-Amp Instruction Book EPOCH-10

5. USAR Figures 3.11-1 through 5

IV. SOFTWARE USED: N/A

Title:\_\_\_\_\_\_ Ve

Version/Release:\_\_\_\_\_Disk/CD No.\_\_\_\_\_

V. DISK/CDS INCLUDED: N/A

Title:\_\_\_\_\_

Version/Release\_\_\_\_\_Disk/CD No.\_\_\_\_\_

VI. OTHER CHANGES: The following related references have been removed:

3221.418-000-003U, 0221.415-000-122, GE-828E537AA #006, GE-DL828E537AA, STP-302-0102



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 4 OF 22

Revision	Record of Revision
0	Initial issue to support determination of loss of voltage relay setpoints by Electrical Engineering
1	Incorporated new drift value and extended calibration period to 30 months per EC 11753.
	·
	-



CALC. NO. - REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 5 OF 22

#### **TABLE OF CONTENTS**

COVER SHEET

#### CALCULATION REFERENCES

**RECORD OF REVISION** 

#### **SECTION**

2

#### PAGE 1.0 2.0 3.0 4.0 Design Input ...... 10 5.0 6.0 Calculation Methodology ...... 14 7.0 8.0 9.0 Attachments: 1 E-mail message from General Electric Power Management to George Boles...... 1 page



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 6 OF 22

#### 1.0 **Purpose and Description**

#### 1.1. Purpose

The purpose of this calculation is to determine the uncertainty associated with the existing Division III, Safety-Related, 4.16 kV Loss of Voltage relays E22-27N1 and 27N2. Nominal trip Setpoints and Allowable values will be determined by the Electrical Engineering group in calculation G13.18.3.1\*002 and documented on the applicable BE drawing.

#### 1.2. Loop Descriptions

The DIV. III incoming Normal Supply power is monitored by two undervoltage relays (27N1 and 27N2) whose outputs are arranged in a one-out-of-two logic configuration (Reference 3.10.3). The channels include electronic equipment (e.g., trip units) that compare measured input signals with pre-established setpoints. When the setpoint is exceeded, the channel output relay actuates, opens the DIV III Normal Supply source breaker.

The Division III 4.16 kV emergency bus has its own independent Loss of Voltage instrumentation and associated trip logic. The DIV III emergency bus is monitored by undervoltage relays 27S1 through 27S4) whose outputs are arranged in a one-out-of-two, twice logic configuration (Reference 3.10.3).

#### 1.3. Design Bases/Design Bases Event

Per Bases B 3.3.8.1, Reference 3.7.3, "successful operation of the required safety functions of the Emergency Core Cooling Systems (ECCS) is dependent upon the availability of adequate power sources for energizing the various components such as pump motors, motor operated valves, and the associated control components. The LOP instrumentation monitors the 4.16 kV emergency buses. Offsite power is the preferred source of power for the 4.16 kV emergency buses. If the monitors determine that insufficient power is available, the buses are disconnected from the offsite power sources and connected to the onsite diesel generator (DG) power sources."

#### 1.4. Degree of Accuracy/Limits of Applicability

The results of this calculation are based on the statistical methods of at least 95% probability of occurrence for a one sided probability of distribution in accordance with "General Electric Instrument Setpoint Methodology," (Reference 3.3) and EN-IC-S-007-R, "Instrument Loop Uncertainty & Setpoint Calculations", (Reference 3.2).

The results of this calculation are valid under the Assumptions stated in Section 7.0 of this calculation. The appropriate use of this calculation to support design or station activities, other than those specified in Section 1.1 of this calculation, is the responsibility of the user.

#### 1.5. Applicability

A data analysis has been performed in order to determine which, if any, redundant instrument loops are bounded by the results of this calculation. This calculation is applicable to the Loops associated with the primary elements stated in Section 2.1. The results of this calculation are bounding for the applicable instrument loops, based on such factors as instrument manufacturer and model number, instrument location/environmental parameters, actual installation and use of the instrument in process measurements.



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 7 OF 22

#### 2.0 Results/Conclusion

#### 2.1. Results

The Loop Uncertainty and Total Loop Uncertainty for the Loss of Voltage and Loss of Voltage relays were calculated in Section 8.0. These values and other associated values such as loop drift are presented in table 2.1-1.

Table 2.1-1 Model NGV Loss of Voltage Relay – Voltage Trip						
System(s)	Loop	Loop	Channel	Total Loop	M&TE Loop	Maximum
	Identification	Uncertainty	Drift	Uncertainty	Accuracy	Loop
		(LU)	(D <sub>L</sub> )	(TLU)	Requirements	Setting Tol.
		VAC	VAC	VAC	(MTE <sub>L</sub> ) VAC	(PALB)
						VAC
302	E22-S004-27N1 E22-S004-27N2	$\pm 3.678$ *± 128.73	± 5.823	± 5.31 *± 185.85	± 0.375	± 2.61

\* Value adjusted to reflect uncertainty applied to the primary of the potential transformer.

#### 2.2. Conclusions

The calculated Loop Uncertainty and Total Loop Uncertainty presented in table 2.1-1 are bounding for the relays and circuits listed in Section 2.1.



#### 3.0 References

- 3.1. EN-DC-126, "Engineering Calculation Process"
- 3.2. EN-IC-S-007-R, "Instrument Loop Uncertainty & Setpoint Calculations"
- 3.3. 7224.300-000-001B, NEDC-31336P-A, General Electric Instrument Setpoint Methodology
- 3.4. Indus Asset Suite Equipment Data Base (EDB)
- 3.5. 201.130-186, "Peak Spreading of ARS Curves for the Control Building"
- 3.6. Environmental Design Criteria, Spec 215.150, including USAR figures 3.11-1 through 5 as outlined in EDP-AN-02 section 6.3.1
- 3.7. RBS Operating License
  - 3.7.1. Not used
  - 3.7.2. Not used
  - 3.7.3. Bases Sections B3.3.8.1
- 3.8. RBS USAR

None

- 3.9. Vendor Manuals/Documents
  - 3.9.1. G080-1344, General Electric Instructions Undervoltage Relays
  - 3.9.2. F137-0100, Fluke 45 Dual Display Multimeter Users Manual
  - 3.9.3. Multi-Amp Instructions for the EPOCH-10, Microprocessor-Enhanced Protective Relay Test Set, (maintained by the Standards Laboratory)
  - 3.9.4. 6221.418-000-001A, High Pressure Core Spray System Power Supply Unit, NEDO-10905
  - 3.9.5. 0221.418-000-008, Purchase Specification Data Sheet 21A9300AU, High Pressure Core Spray System
- , 3.10. Electrical Schematics
  - 3.10.1. EE-001M, 4160V One Line Diagram Standby Bus E22-S004
  - 3.10.2. GE-828E537AA#003, Elementary Diagram HPCS Power Supply System
  - 3.10.3. GE-828E537AA#007, Elementary Diagram HPCS Power Supply System
  - 3.10.4. GE-828E537AA#008, Elementary Diagram HPCS Power Supply System



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 9 OF 22

3.10.5. GE-828E537AA#011, Elementary Diagram HPCS Power Supply System

- 3.11. Surveillance Test Procedures:
  - 3.11.1. STP-302-1604, HPCS Loss of Voltage Channel Calibration And Logic System Functional Test
  - 3.11.2. Not used
- 3.12. Logic Diagrams
  - 3.12.1. GE-152D8167#003, Functional Control Diagram, High Pressure Core Spray Power Supply
  - 3.12.2. GE-152D8167#003A, Functional Control Diagram, High Pressure Core Spray Power Supply
  - 3.12.3. GE-152D8167#004, Functional Control Diagram, High Pressure Core Spray Power Supply
  - 3.12.4. GE-152D8167#005, Functional Control Diagram, High Pressure Core Spray Power Supply
- 3.13. Standards
  - 3.13.1. ANSI Standard C57.13, Requirements for Instrument Transformers
  - 3.13.2. ANSI Standard C37.90, Relays and Relay Systems Associated with Electric Power Apparatus
- 3.14. E-mail message from General Electric Power Management to George Boles, Attachment 1
- 3.15. G13.18.6.3-012, Rev.0, General Electric Model NGV13B Relay Drift Analysis
- 3.16. BE-230D, 4.16kV Bus 1E22-S004 Relay Settings
- 3.17. 0221.418-000-049, 1E22-S004 Equipment Summary



#### 4.0 Design Input

#### 4.1. Loop Input

4.1.1. Loop Data:

Form 1: Loop/Process Data Sheet			
Description	Data	Reference	
Loop Sensor(s)	E22-S004 PT-Line	3.10.4	
Location	E22-S004	3.10.4	
Output Range	0 – 120 VAC	3.10.4	
Input Range	0 – 4200 VAC	3.10.4	

4.1.2. Special Considerations:

- 4.1.2.1. Calibration shall be performed using the following instruments:
  - Multi-Amp EPOCH-10 relay tester set to Oscillator mode (Reference 3.9.3)
  - Fluke Model 45 Digital Multimeter set to medium resolution (Reference 3.9.2)
- 4.1.2.2. A minimum of 1 hour warm up time at the location where the M&TE will be used shall be allowed for the Fluke Model 45 Multimeter.

#### 4.2. Loop Instrumentation

Form 2: Instrument Data Sheet Calc. Device Number 1			
Description	Data	Reference	
Component Number(s)	E22-S004-PT-Bus	3.4	
Manufacturer	GE	3.17	
Model(s)	JVM	3.17	
Location(s)	CB. 116'EL/E22-S004	3.4	
Service Description	Transformer	3.4	
Instrument Range	0 – 4200 VAC	3.10.4	
Instrument Span	120 VAC	3.10.4	
Output Range	0-120 VAC	3.10.4	
Calibration Interval Evaluated	N/A	Note	
Device Setting Tolerance	N/A	Note	

Note: Potential transformers for instrument service cannot be calibrated or adjusted. Therefore there is no device setting tolerance or calibration interval.

.



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 11 OF 22

Form 2: Instrument Data Sheet Calc. Device Number 2				
Description	Data	Reference		
Component Number(s)	E22-S004-27N1 E22-S004-27N2	3.4		
Manufacturer	General Electric	3.16		
Model	12NGV	3.16		
Location(s)	CB. 116'EL/E22-S004	3.4		
Service Description	Relay	3.4		
Input Range	0 – 120 VAC	3.9.1		
Output	Contact Action .	3.10, 3.12		
Calibration Interval Evaluated	30 Mo. (24 Mo. + 25%)	3.2		

### 4.3. Loop Device Data

Form 3: Instrument Accuracy Data Sheet Calc. Device Number 1 General Electric JVM			
Description	Data	Reference	
Reference Accuracy (RA <sub>T</sub> )	0.3% of setting 2σ	· 3.9.4, 8.2.1 7.1.2	
Seismic Effects (SE <sub>T</sub> )	N/A	7.1.4	
Temperature Effects (TE <sub>T</sub> )	N/A	7.1.12	
Insulation Resistance Effects (IR <sub>T</sub> )	N/A	7.1.10	
Temperature Drift Effect (TD <sub>T</sub> )	N/A	7.1.13	
Drift (DR <sub>T</sub> )	N/A	7.1.14	



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 12 OF 22

Form 3: Instrument Accuracy Data Sheet Calc. Device Number 2 General Electric NGV			
Description	Data	Reference	
Reference Accuracy (RA <sub>R</sub> )	$\pm 1\%$ of setting $2\sigma$	3.14, Attachment 1 7.1.2	
Seismic Effects (SE <sub>R</sub> )	0	7.1.4	
Temperature Effects (TE <sub>R</sub> )	2% of setting (68°F – 104°F)	7.1.12	
Insulation Resistance Effects (IR <sub>R</sub> )	N/A	7.1.10	
Temperature Drift Effect (TD <sub>R</sub> )	N/A	7.1.13	
Drift (DR <sub>R</sub> )	± 5.823 VAC 2σ	3.15	
Power Supply Effect (PS <sub>R</sub> )	N/A	7.1.6	
Reset Differential	10% of Setting 2σ	3.9.1 3.11.1, 7.1.2	

#### 4.4. Environmental Information

Form 4: Environmental Conditions Data Sheet				
Zone: CB-116-2				
Description	Data	Reference		
Location				
Building/Elevation	CB-116	3.4		
Room/Area	Switchgear Room	3.4		
Normal				
Temperature Range, °F	40 - 104	3.6, 7.1.12		
Humidity Range, %RH	20 - 90	3.6, 7.1.9		
Radiation 40 Year Total Integrated Dose, Rads	800	3.6		
Pressure Range	Atmos	3.6		
Accident (Loss of Offsite Power)				
Temperature Range, °F	Same as Normal	3.6		
Humidity Range, %RH	Same as Normal	3.6		
Radiation, Total Integrated Dose, Rads	Same as Normal	3.6		
Pressure Range	Same as Normal	3.6		
Seismic				
Accelerations, g	< 3	3.5		



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 13 OF 22

#### 5.0 <u>Nomenclature</u>

The terms and abbreviations that are not defined in this section are defined in Reference 3.3, Reference 3.2 or within the text of this calculation.



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 14 OF 22

#### 6.0 Calculation Methodology

This calculation is prepared in accordance with the EN-IC-S-007-R, "Instrument Loop Uncertainty & Setpoint Calculations" (Reference 3.2), EN-DC-126, "Engineering Calculation Process" (Reference 3.1) and 7224.300-000-001B, "General Electric Instrument Setpoint Methodology" (Reference 3.3).



1

#### 7.0 Assumptions

#### 7.1. Assumptions that do not require confirmation

#### 7.1.1. Miscellaneous Allowance (ML)

A miscellaneous allowance has not been applied to the uncertainty of the devices evaluated by this calculation. By assuming all vendor supplied data is a  $2\sigma$  value and with intermediate rounding of values, sufficient conservatism has been introduced.

#### 7.1.2. Vendor 2σ Data

For conservatism, all uncertainties given in vendor data specifications are assumed to be  $2\sigma$  unless otherwise specified.

#### 7.1.3. Zero Effect

Not applicable

#### 7.1.4. Seismic Effects (SE)

Seismic effects are assumed to be negligible for the NGV relay, per Reference 3.9.5. Seismic effects are not applicable to potential transformers.

#### 7.1.5. Radiation Effects (RE) & Radiation Drift Effect (RD)

Are not applicable to the relays and transformers evaluated by this calculation, as they are located in a mild environment (Reference 3.6).

#### 7.1.6. Power Supply Effects (PS)

Power supply effects are not applicable to type NGV relays as the relay does not utilize a control power source separate from the sensed voltage.

Power supply effects are not applicable to transformers.

#### 7.1.7. Process Measurement Uncertainty (PM)

Not Applicable

7.1.8. <u>Static Pressure Effects (SP)</u>

Not Applicable

#### 7.1.9. Humidity Effects (HE)

The relays were specified by the HPCS manufacturer and are assumed to be designed to with stand the environmental effects in the mounting location. The HPCS Design Specification, Section 4.6.1 (reference 3.9.5) states that the design conditions for the switchgear and its sub-components are 20-90% Relative Humidity. Per Reference 3.6, the humidity range for environmental zone CB-116-2 is 20 to 90% RH. Reference 3.6 also



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 16 OF 22

identifies that 1% of the calendar year (30 hours) the humidity could be 5 % higher. This is considered negligible. Therefore, it is assumed that Humidity Effects are negligible.

7.1.10. Insulation Resistance Effects (IR)

(IR) effects, which may result in degradation of circuit insulation, are not applicable to the devices and circuits addressed by this calculation.

#### 7.1.11. Voltage Drop

Voltage drop due to long wiring lengths between source and load are assumed to be negligible as the potential transformers and the under-voltage relays evaluated by this calculation are located in the same switch gear compartment.

7.1.12. Temperature Effects (TE)

There is no temperature effect data available from the manufacturer for the Type NGV relay. Therefore for conservatism, temperature effects are assumed to be equal to the repeatability value ( $\pm$  2% of setting) given in Attachment 1. Reference 3.6 also identifies that 1% of the calendar year (30 hours) the temperature could be 5°F higher. This is considered negligible.

Temperature effects are not applicable to transformers. Temperatures above the rated value would tend to produce total failure of the transformer, rather than an error in output.

7.1.13. Temperature Drift Effects (TD)

The drift analysis performed in Reference 3.15 is assumed to encompass all components of drift and drift effects except for temperature drift effects which are assumed to be included in the Reference Accuracy of the device.

Temperature drift effects are not applicable to transformers.

7.1.14. Instrument Drift

The drift analysis can be found in Reference 3.15.

Drift is not applicable to transformers.

#### 7.2. Assumptions that require confirmation

None



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 17 OF 22

.....

#### 8.0 Calculation

This section includes the following subsections used in performance of this calculation:

- 8.1) Calculation of Miscellaneous Uncertainties
- 8.2) Calculation of Individual Device Reference Accuracy (RA) and Determination of Appropriate Device Uncertainty
- 8.3) Calculation of Individual Device Uncertainties
- 8.4) Calculation of Loop Calibration Accuracy (C<sub>L</sub>)
- 8.5) Calculation of Insulation Resistance Effects (IR)
- 8.6) Calculation of Loop Uncertainty (LU)
- 8.7) Calculation of the Loop Drift  $(D_L)$
- 8.8) Calculation of Total Loop Uncertainty (TLU)
- 8.9) Calculation of Reset Differential (RD)

#### 8.1. Calculation of Miscellaneous Uncertainties

8.1.1. Calculation of Transformer Burden and Determination of Reference Accuracy

Per Reference 3.9.4, page 5-10, section 5.3, the Type JVM potential transformer has a 1.2% ratio error for a combined relaying and metering burden of greater than 75 VA. However, a burden below 75VA yields a transformer accuracy of  $\pm$  0.3% of setting. As shown below, the devices fed by the PT Line transformer do not meet the 75 VA burden threshold.

2 Model NGV Undervoltage Relays @ 4.2 VA each	=	8.4
2 Model 27N Undervoltage Relays @ 0.5 VA each	=	1.0
1 Synchronizing Relay @ 2.0 VA	=	2.0
2 Volt Meter, GE AB40 @ 0.32 VA each	=	0.64
1 Synchronizing Scope @ 5.2 VA	=	5.2
Control Relays/Meters not listed, Assumed Value	=	<u>10.0</u>
		25.24 VA

Therefore, PT Reference Accuracy shall be 0.3% of setting (87 VAC per Ref. 3.11.1) or 0.261 VAC for this calculation.

- 8.1.2. Calculation of Relay Temperature Effects (TE<sub>R</sub>) (Assumption 7.1.12)
  - $TE_{R} = \pm 1\% \text{ Setting}$ =  $\pm 0.01 \times 87 \text{ VAC}$ =  $\pm 0.87 \text{ VAC}$



### SETPOINT CALCULATION ENGINEERING DEPARTMENT

CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 18 OF 22

### **RIVER BEND STATION**

# 8.2. Calculation of Individual Device Reference Accuracy (RA) & Determination of Appropriate Device Uncertainty

- 8.2.1. Transformer Reference Accuracy (RAT)
  - $RA_{T} = \pm 0.3\%$  of Setting =  $\pm 0.003 * 87 VAC$ =  $\pm 0.261 VAC$

(2 Value)

 $(2\sigma \text{ Value})$ 

#### 8.2.2. Undervoltage Relay Reference Accuracy for Voltage Setting (RA<sub>R</sub>)

- $RA_{R} = \pm 1\% \text{ of Setting}$ = \pm 0.01 \* 87 VAC = \pm 0.87 VAC
- 8.2.3. <u>Loop Reference Accuracy (RA<sub>I</sub>)</u> (Reference 3.2)

$$RA_{L} = \pm [(RA_{T})^{2} + (RA_{R})^{2}]^{1/2}$$
  
= \pm [(0.261)^{2} \* (0.87)^{2}]^{1/2}  
= \pm 0.908 VAC

 $(2\sigma \text{ Value})$ 

Per Reference 3.11.1 the Loop Calibration Tolerance ( $CT_L$  – Procedural As Left Band) for Loss of Voltage is ± 2.61 VAC. As the  $CT_L$  value is greater than the associated Loop Reference Accuracy, the individual device Reference Accuracies are set to zero for the remainder of this calculation (Reference 3.2).

#### 8.3. Calculation of Individual Device Uncertainties (Reference 3.2)

- 8.3.1. <u>Device Uncertainty Transformer  $(A_T)$  (Sections 4.3 and 8.2.1)</u>
  - $A_{T} = \pm [(RA_{T})^{2}]^{1/2}$  $= \pm [(0)^{2}]1/2$  $= \pm 0 VAC$

#### 8.3.2. <u>Device Uncertainty Relay Voltage Setting (A<sub>R</sub>)</u>

 $A_{R} = \pm [(RA_{R})^{2} + (PS_{R})^{2} + (TE_{R})^{2}]^{1/2}$ = \pm [(0)^{2} + (0)^{2} + (0.87)^{2}]^{1/2} = \pm 0.87 VAC

(2o Value)

 $(2\sigma Value)$ 

#### 8.4. Calculation of Loop Calibration Accuracy $(C_L)$ Per reference 3.2 and 3.3 Loop Calibration uncertainty $(C_L)$ is defined

Per reference 3.2 and 3.3 Loop Calibration uncertainty ( $C_L$ ) is defined as:

 $C_{L} = \pm [(MTE_{L})^{2} + (CT_{L})^{2}]^{1/2}$ = \pm [0.375^{2} + 2.61^{2}]^{1/2} VAC = \pm 2.64 VAC

(2o Value)



8.4.1. Measuring and Test Equipment Effects – Relay (MTE<sub>L</sub>)

Measurement & Test Equipment (MTE<sub>L</sub>) effects are defined from Reference 3.2 as:

$$MTE_{L} = \pm [(MTE_{RAT})^{2} + (MTE_{RIT})^{2} + (MTE_{TET})^{2} + (MTE_{CST})^{2}]^{1/2}$$

Where:

- $MTE_{RAT} = Reference accuracy of the M&TE used for calibration. Assumed equal to the Reference Accuracy of the primary element in the loop, 0.261 VAC (Reference 3.2).$
- $MTE_{RIT}$  = Readability of the M&TE used, assumed to be 0 as all M&TE used are digital with at least 2 digits of resolution. (Reference 3.2)
- $MTE_{TET} = Effects$  of temperature changes on the M&TE between the calibration laboratory and the area where the M&TE is used, Assumed equal to the Reference accuracy of the primary element in the loop, 0.261 VAC (Reference 3.2).
- $MTE_{CST}$  = The accuracy of the calibration standard used to calibrate the M&TE, assumed equal to 1/4 the Reference accuracy of the primary element in the loop, 0.065 VAC (Reference 3.2).
- $MTE_{L} = \pm [(MTE_{RAT})^{2} + (MTE_{RIT})^{2} + (MTE_{TET})^{2} + (MTE_{CST})^{2}]^{1/2}$ =  $\pm [(0.261)^{2} + (0)^{2} + (0.261)^{2} + (0.065)^{2}]^{1/2}$ =  $\pm 0.375 \text{ VAC}$  (2 $\sigma$  Value)
- 8.4.2. Calculation of Calibration Effects (CT) Calibration Effects (CT<sub>L</sub>) are defined from Reference 3.2 as:
  - $CT_L$  = Square Root Sum of the Squares (SRSS) of the calibration effects which are uncertainties due to "as Left" loop accuracy.

 $CT_L = \pm 2.61 \text{ VAC}$  (2 $\sigma$  value)

#### 8.5. Calculation of Insulation Resistance Effects (IR)

0 per Assumption 7.1.10

- 8.6. Calculation of Loop Uncertainty (LU)
  - $LU = \pm (m/n)[(A_T)^2 + (A_R)^2 + (C_L)^2]^{1/2} \pm M \text{ (margin)}$ = \pm (1.645/2)[(0)^2 + (0.87)^2 + (2.64)^2]^{1/2} \pm 1.392 = \pm 3.678 VAC

Adjusted to reflect primary voltage to the PT

= ± 3.678 x PT Ratio (Primary Voltage/Secondary Voltage)

= ± 3.678 x 35 VAC

$$= \pm 128.73$$
 VAC



#### 8.7. Calculation of Loop Drift (DL)

8.7.1. <u>Transformer Temperature Drift Effects (TD<sub>T</sub>)</u>

0 for per Assumption 7.1.13

8.7.2. Relay Temperature Drift Effects (TDR)

0 per assumption 7.1.13

8.7.3. <u>Relay Drift (DR<sub>R</sub>):</u>

Assumption 7.1.14

 $DR_R = \pm 5.823 \text{ VAC}$ 

 $(2\sigma \text{ Value})$ 

As the only component of loop drift is the relay drift determined in reference 3.15, Loop Drift  $(DR_L)$  is equal to Relay Drift  $(DR_R)$ .

$$D_{L} = \pm 5.823 \text{ VAC}$$

(2 $\sigma$  Value)

#### 8.8. Calculation of Total Loop Uncertainty (TLU) Calculation:

TLU =  $\pm (m/n)[(A_T)^2 + (A_R)^2 + (C_L)^2 + (DR_L)^2]^{1/2}$ =  $\pm (1.645/2)[(0)^2 + (0.87)^2 + (2.64) + (5.823)^2]^{1/2}$ =  $\pm 5.31 \text{ VAC}$ 

Adjusted to reflect primary voltage to the PT:

 $= \pm 5.31 \text{ x PT}$  Ratio (Primary Voltage/Secondary Voltage) =  $\pm 5.31 \text{ x } 35 \text{ VAC}$ =  $\pm 185.85 \text{ VAC}$ 

#### 8.9. Calculation of Reset Differential

The reset differential is applied to the voltage setting and is specified to be  $\pm 10\%$  of setting per References 3.9.1 and 3.11.1. This value will be used in the calculation.

 $RR = \pm 0.1 * setting VAC$ =  $\pm 0.1*87$ =  $\pm 8.70 VAC$ 

Adjusted to reflected primary (bus) voltage at the PT:

- = RR x PT Ratio (primary voltage/secondary voltage)
- $= \pm 8.7 \text{ x } 35 \text{ VAC}$
- $= \pm 304.5$  VAC

Calculated uncertainties are applicable to reset.



1

## SETPOINT CALCULATION ENGINEERING DEPARTMENT RIVER BEND STATION

CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 21 OF 22

Summary of Calculation Data							
	Trans Dev	Undervoltage Relay Device 2					
	Values	σ	Ref	Values	σ	Ref	
Input Range	0 – 42 kV	-	3.13	0 - 120	-	3.13	
Process Units	VAC	-	3.13	VAC	-	3.13	
Reference Accuracy (RA)	0.3% of Setting	2	8.2.1	1% of Setting	2	8.2.2	
Temperature Effect (TE)	· N/A		7.1.12	± 0.87	2	7.1.12	
Seismic Effects (SE)	N/A	_	7.1.4	N/A	-	7.1.4	
Radiation Effect (RE)	N/A	_	7.1.5	N/A	-	7.1.5	
Instrument Drift (DR)	· N/A		7.1.14	± 5.823	2	3.15	
Temperature Drift Effect (TD)	N/A	_	7.1.13	N/A	-	7.1.13	
Radiation Drift Effect (RD)	N/A	_	7.1.5	N/A	-	7.1.5	
Power Supply Effect (PS)	N/A	-	7.1.6	N/A	_	7.1.6	
Humidity Effects (HE)	N/A	_	7.1.9	N/A	-	7.1.9	
Static Pressure Effect (SP)	N/A	_	7.1.8	N/A	-	7.1.8	
Process Measurement Effect (PM)	N/A	_	7.1.7	N/A	_	7.1.7	
Insulation Resistance Effect (IR)	N/A	_	7.1.10	N/A		7.1.10	
Zero Effect (ZE)	N/A		7.1.3	N/A	-	7.1.3	



CALC. NO. – REV. ADDENDUM G13.18.6.2-ENS\*004 Rev. 1 PAGE 22 OF 22

### 9.0 Simplified Block Diagram





### CALC. NO. - REV. ADDENDUM

G13.18.6.2-ENS\*004 Rev. 1

PAGE 1 OF 1

ATTACHMENT NO.: 1

From: "EmailClerk (IndSys, IM) " <emailclerk@indsys.ge.com> To: <georgeboles@dpengineering.com> Subject: Email out for Case C01-39202 Date: Thursday, April 19, 2001 7:14 AM

Please use Reply to respond to this e-mail. Any changes made to the Original Message content will not be transferred. Please do not modify the subject line or processing of this e-mail may be delayed.

Case C01-39202 Subject NGV Dropout Range

George,

The dropout range for the NGV11 relay is "Once the voltage dropout level has been adjusted to a value within the range of Dropout Adjustment as in Table C of the Instruction Book then on any dropout operation, the voltage range from the beginning of the action to its completion is about one percent of rated voltage"

g GE Power Management

Technical Support General Electric Power Management Info.pm@Indsys.ge.com Phone: 800-547-8629 (North America) +34-94-485-8854 (Europe and Middle East) 905-294-6222 (International) Fax: (905) 201-2098

ATTACHMENT 9.1	 DESIGN VERIFICATION COVER PA				PAGE	
Sheet 1 of 1			······································			
	DESIGN VE	RIFICATION	N COVER PA	GE		
· ·	 _					

	ANO-2 VY	☐ IP-2 ☐ GGNS			
. G13.18.6.2.ENS*0	04		Revision No. 1	Page 1	of 4
Uncertainty Determ rvoltage Relay	ination for	r Div III Loss o	f Voltage Rela	ays – GE Mode	I NGV
Quality Related		Augmented Qua	lity Related		
🛛 Design Review	, 🗆 A	Alternate Calcul	ation	Qualification Te	esting
	<ul> <li>ANO-1</li> <li>PNPS</li> <li>G13.18.6.2.ENS*0</li> <li>Uncertainty Determ rvoltage Relay</li> <li>Quality Related</li> <li>☑ Design Review</li> </ul>	ANO-1 ANO-2     PNPS VY . G13.18.6.2.ENS*004 Uncertainty Determination fo rvoltage Relay     Quality Related	ANO-1 ANO-2 PNPS GGNS      G13.18.6.2.ENS*004  Uncertainty Determination for Div III Loss o rvoltage Relay      Quality Related Augmented Qua      Design Review Alternate Calcul	□ ANO-1       □ ANO-2       □ IP-2       □ IP-3         □ PNPS       □ VY       □ GGNS       ⊠ RBS         . G13.18.6.2.ENS*004       Revision No. 1         Uncertainty Determination for Div III Loss of Voltage Relay         ☑ Quality Related       □ Augmented Quality Related         ☑ Design Review       □ Alternate Calculation       □	□ ANO-1       □ ANO-2       □ IP-2       □ IP-3       □ JA-         □ PNPS       □ VY       □ GGNS       ⊠ RBS       □ W3         . G13.18.6.2.ENS*004       Revision No. 1       Page 1         Uncertainty Determination for Div III Loss of Voltage Relays – GE Mode rvoltage Relay         ☑ Quality Related       □ Augmented Quality Related         ☑ Design Review       □ Alternate Calculation       □ Qualification Te

VERIFICA	TION REQUIRED	DISCIPLINE	VERIFICATION COMPLETE AND COMMENTS RESOLVED (DV print, sign, and date)		
		Electrical			
		Mechanical			
	$\boxtimes$	Instrument and Control	Justin Waters Just hut 2/24/09		
		Civil/Structural			
		Nuclear			
Originator:	nator: <u>Charles Mohr</u> <u>Charles Mohn</u> 2/24/09 Print/Sign/Date After Comments Have Been Resolved				

ATTACHMENT 9.6

#### **DESIGN VERIFICATION CHECKLIST**

#### Sheet 1 of 3

IDENTIFICATION:					DISCIPLINE:
Document Title: Loop Relay	☐Ċivil/Structural ☐Electrical				
Doc. No.:	G13.18.6.2.ENS*0	04	. Rev. 1	QA Cat.: SR	⊠I & C
Verifier:	<u>Justin Waters</u> Print	Ju	Sign	<u>2/24/0</u> Date	9⊡Mechanical ────⊡Nuclear
Manager authorization for supervisor performing Verification.					□Other
	Print		Sign	Date	
METHOD OF VERIFICATION:					
Design Review	P	liternate		Q	ualification Test

The following basic questions are addressed as applicable, during the performance of any design verification. [ANSI N45.2.11 – 1974] [NP] [QAPD, Part II, Section 3] [ NQA-1-1994, Part II, BR 3, Supplement 3s-1].

- NOTE The reviewer can use the "Comments/Continuation sheet" at the end for entering any comment/resolution along with the appropriate question number. Additional items with new question numbers can also be entered.
- 1. Design Inputs Were the inputs correctly selected and incorporated into the design?

(Design inputs include design bases, plant operational conditions, performance requirements, regulatory requirements and commitments, codes, standards, field data, etc. All information used as design inputs should have been reviewed and approved by the responsible design organization, as applicable.

All inputs need to be retrievable or excerpts of documents used should be attached. See site specific design input procedures for guidance in identifying inputs.) Yes  $\boxtimes$  No  $\square$  N/A  $\square$ 

- 2. Assumptions Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are assumptions identified for subsequent re-verification when the detailed activities are completed? Are the latest applicable revisions of design documents utilized? Yes X No N/A
- 3. Quality Assurance Are the appropriate quality and quality assurance requirements specified? Yes ⊠ No □ N/A □

ATTACHMENT 9.6	DESIGN VERIFICATION CHECKLIST
Sheet 2 of 3	

- Codes, Standards and Regulatory Requirements Are the applicable codes, standards and regulatory 4. requirements, including issue and addenda properly identified and are their requirements for design met? Yes 🖾 No 🗖 N/A П 5. Construction and Operating Experience - Have applicable construction and operating experience been considered? Yes □ No 🗔 N/A 🖾 Interfaces - Have the design interface requirements been satisfied and documented? 6. Yes 🗆 No 🗆 N/A 🖾 7. Methods - Was an appropriate design or analytical (for calculations) method used? N/A Yes 🛛 No 🗆 8. Design Outputs - Is the output reasonable compared to the inputs? No 🗖 N/A 🗆 Yes 🖾 Parts, Equipment and Processes - Are the specified parts, equipment, and processes suitable for the 9. required application? Yes 🗆 No 🗆 N/A 🖾 Materials Compatibility - Are the specified materials compatible with each other and the design 10. environmental conditions to which the material will be exposed? Yes 🗆 No 🗆 N/A 🖾 11. Maintenance requirements - Have adequate maintenance features and requirements been specified? Yes 🗖 No 🗖 N/A 🖾 12. Accessibility for Maintenance - Are accessibility and other design provisions adequate for performance of needed maintenance and repair? N/A 🖾 Yes 🗖 No 🗖 13. Accessibility for In-service Inspection - Has adequate accessibility been provided to perform the inservice inspection expected to be required during the plant life? Yes 🗆 No 🗖 N/A 🖾 Radiation Exposure - Has the design properly considered radiation exposure to the public and plant 14. personnel? Yes 🗆 N/A 🖾 No 🗆 Acceptance Criteria - Are the acceptance criteria incorporated in the design documents sufficient to 15.
- Acceptance Criteria Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?
   Yes ⊠ No □ N/A □
- Test Requirements Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?
   Yes □ No □ N/A ⊠

ATTAC	HMENT 9.6		DESIGN VERIFICATION CHECKLIST
Sheet	3 of 3		
17.	Handling, Sto requirements s Yes □	brage, Cleaning specified? No ⊡	g and Shipping – Are adequate handling, storage, cleaning and shipping
18.	Identification Yes 🗆	_ Requirements No □	<ul> <li>Are adequate identification requirements specified?</li> <li>N/A ⊠</li> </ul>
19.	Records and etc., adequate other document Yes ⊠	Documentation ly specified? Ar ation storage me No 🗌	n – Are requirements for record preparation, review, approval, retention, re all documents prepared in a clear legible manner suitable for microfilming and/or thod? Have all impacted documents been identified for update as necessary? N/A
20.	Software Qua GOTHIC, SYM site SQA Prog ENS sites: Thi the calculation Yes □	ality Assurance ICORD), was it ram? s is an EN-IT-1 ? No ⊡	<ul> <li>ENN sites: For a calculation that utilized software applications (e.g., t properly verified and validated in accordance with EN- IT-104 or previous 04 task. However, per ENS-DC-126, for exempt software, was it verified in N/A IX</li> </ul>
21.	Has adverse being verified, Yes □	impact on perip been considen No ⊡	oheral components and systems, outside the boundary of the document ed? N/A ⊠

-

1 )

ATTACHMENT 9.7

Sheet 1 of 1

DESIGN VERIFICATION COMMENT SHEET

### **Comments / Continuation Sheet**

Question #	Comments	Resolution	Initial/Date
1	Comments provided by markup for calculation G.13.18.6.2-ENS*004.	Comments resolved to the satisfaction of the reviewer.	Ju 2/24/09
			· · · · · · · · · · · · · · · · · · ·
		· · · · · · · · · · · · · · · · · · ·	
		· · · · · · · · · · · · · · · · · · ·	
	······································		

### SHEET 1 OF 1

### Calculation G13.18.6.2-ENS\*004, Rev. 001 (EOI Review Comments)

### Comments / Continuation Sheet

Question #	Comments	Resolution	Initial/Date
1	Calc number should be G13.18.6.2- ENS*004	Corrected	
2	Calc ref sheet does list the following references from the original calc. Should they be listed in Section VI of the form as being removed? 0221.415-000-122 3221.418-000-003U STP-302-0102	Agreed, those are not used.	
3	Should a reference be added to show where the Setting value of 87 VAC is derived in Section 8.1.1?	I think that's a good idea – the setting doesn't appear to be referenced anywhere. Added reference to STP in Section 8.1.1	
4	Use Ref. 3.11.1 for the STP in Section 8.9 instead of directly referring to it like was done in Section 8.2.3.	Agreed, although this paragraph will be removed per comment below.	
5	Your change in the first paragraph to Section 8.9 now references the STP As-Left reset tolerance. However, the original paragraph pertained to the reset differential value itself, not its tolerance. The current STP revision shows the Reset Differential as 95.70 VAC or 10% of setting. This is stated in the second paragraph of Section 8.9. Based on this I don't believe the first paragraph is required anymore since the rest is now the same whether the relay is calibrated or not calibrated during performance of the STP.	Agreed – first paragraph serves no purpose. Removed. (changes page count)	
		Note: Per discussion, margin was added to the LU to bring it up to previous value. No margin added to TLU. See Section 8.6 and 2.1.	