

1 ENERGY FACILITY SITE EVALUATION COUNCIL
2 P.O. BOX 43172
3 OLYMPIA, WASHINGTON 98504-3172
4

5
6 **IN THE MATTER OF:** | **NO. EFSEC/2001-01 Amendment 1**
7 **Satsop Combustion Turbine Project** | **FINAL DETERMINATION**
8 **Electrical Generating Facility** | **NOTICE OF CONSTRUCTION**
9 **Elma, Washington** | **AND PREVENTION OF**
10 | **SIGNIFICANT DETERIORATION**
11 |
12
13

14 Pursuant to the Energy Facility Site Evaluation Council (EFSEC) Permit Regulations for Air Pollution
15 Sources, Chapter 463-39 Washington Administrative Code (WAC), regulation for air permit applications
16 WAC 463-42-385, the Washington Department of Ecology (Ecology) regulations for new source review
17 WAC 173-400-110 and Chapter 174-460 WAC), the federal Prevention of Significant Deterioration
18 regulations, Code of Federal Regulations (CFR), Title 40 Subpart 52.21, and based upon the Notice of
19 Construction Application (NOC), submitted by Duke Energy Grays Harbor, L.L.C., and Energy
20 Northwest on December 24, 2001, the Administrative Order on Consent, Docket No. CAA-10-2001-
21 0097, between the Satsop Combustion Turbine (Satsop CT) Project and the U.S. Environmental Protection
22 Agency, Region 10, dated March 30, 2001, and the technical analysis performed by Ecology for EFSEC,
23 EFSEC now finds the following:
24

25 **FINDINGS**

26
27 **1** Duke Energy Grays Harbor, L.L.C., and Energy Northwest (jointly "Duke Energy") applied to construct
28 the Satsop Combustion Turbine Project located near Elma, Washington. EFSEC has previously approved
29 the construction of this project (also known as Satsop Phase I) which is designed to produce a maximum
30 of 650 megawatts (MW) of electrical power. This project received final approval on November 2, 2001
31 (No. EFSEC/2001-01).
32

33 This Amendment 1 is to modify the operating requirements and emission limitations in the current
34 approval. Duke Energy has also requested the inclusion of additional equipment to the project and to
35 remove the operational restrictions in the current approval.
36

37 As currently requested the total project is proposed to consist of the following major components:

- 38
39 a) Two General Electric gas combustion turbines (GE 7FA); each turbine having a maximum rating of
40 1,671 million British thermal units per hour (mmBtu/hr), and each turbine will have a
41 supplementary duct burner with a maximum rating of 505 mmBtu/hr.;
- 42 b) Two heat recovery steam generators (HRSG);
43 c) One steam turbine generator (STG) rated 300 MW each;
44 d) One auxiliary boiler;
45 e) One forced draft cooling tower system;
46 f) One emergency backup diesel generator (new); and
47 g) One diesel engine-driven fire water pump (new).
48

49 These components are configured in a "power island" comprised of 2 gas turbine/duct burner/HRSG
50 units, one steam turbine, one cooling tower, one auxiliary boiler, one emergency generator, and one

- 1 emergency fire water pump. Each gas turbine/duct burner/HRSO unit is known as a combined cycle
 2 gas turbine (CGT). Each CGT has its own exhaust stack.
 3
- 4 **2** Duke Energy's NOC/PSD application to amend PSD No. EFSEC/2001-01 was filed on December 24,
 5 2001. After submittal of additional information on January 30, 2002, and in March, April and May, 2002,
 6 the application for the amendment was determined to be complete on May 12, 2002.
 7
- 8 **3** The original request to amend the PSD approval included a Phase II project which would have doubled
 9 the capacity of the facility. During the public comment period, Duke Energy requested that EFSEC stop
 10 processing of the Phase II project request. This final determination deletes all references to emissions
 11 limitations and criteria applicable to the Phase II project and instead makes the minor changes requested
 12 to the Phase I project.
- 13 **4** The project is subject to permitting requirements under the federal requirements of 40 CFR 52.21 as a
 14 fossil fuel fired steam electric generator, one of 28 listed industries that becomes a "major source," when
 15 emitting more than 100 tons per year (tpy) of any regulated pollutant. The Satsop CT Project has the
 16 potential to emit PSD significant quantities of nitrogen oxides (NO_x), carbon monoxide (CO), sulfur dioxide
 17 (SO₂), sulfuric acid mist (H₂SO₄), particulate matter (PM), particulate matter less than 10 micrometers
 18 (PM₁₀), and volatile organic compounds (VOC).
- 19 **5** The project is subject to permitting under the requirements of WAC 463-39-005(1) and 005(4) (adopting
 20 Chapters 173-400 and 173-460 WAC respectively) for ammonia (NH₃). NH₃ emissions are limited in this
 21 permit in its role in controlling emissions of NO_x.
 22
- 23 **6** The combustion turbines, duct burners and auxiliary boilers will only use natural gas received from the
 24 Northwest Pipeline. The fuel for the diesel engines powering the emergency generators and emergency
 25 fire water pumps is to be on-road specification diesel fuel.
 26
- 27 **7** The site of the proposed project is within an area that is in attainment with regard to all pollutants
 28 regulated by the National Ambient Air Quality Standards (NAAQS) and state air quality standards. The
 29 site is approximately 60 kilometers from the nearest Class I Area, Olympic National Park.
 30
- 31 **8** The project is subject to new source review requirements under Chapter 463-39 WAC, which adopts by
 32 reference Chapter 173-400 WAC, Chapter 173-460 WAC, and 40 CFR 52.21. The facility is also subject
 33 to emission limitation, monitoring and reporting requirements in 40 CFR 60 Subpart Db, 40 CFR 60
 34 Subpart GG, Chapter 173-400 WAC, 40 CFR 60 Appendices A, B, and F, and 40 CFR 75; and to gas fuel
 35 monitoring requirements under 40 CFR 60.334(b)(2) and 40 CFR Part 75 Appendix D.
 36
- 37 **9** Best available control technology (BACT) as required under 40 CFR 52.21(j) and WAC 173-113(2), and
 38 toxic best available control technology (T-BACT) as required under WAC 173-460-040(4) will be used
 39 for the control of all air pollutants which will be emitted by the proposed project. The following table lists
 40 the plant wide, allowable emissions and BACT control technologies.
 41
 42
 43
 44
 45

Pollutant	Plant-wide Potential to Emit, kg/yr (tpy)	Control Technology
-----------	--	--------------------

Pollutant	Plant-wide Potential to Emit, kg/yr (tpy)	Control Technology
Nitrogen oxides (NOx)	223,617 (246)	Selective Catalytic Reduction plus dry low NOx turbine burners and low NOx duct burners
Carbon monoxide (CO)	394,224 (434)	Oxidation catalyst plus dry low NOx turbine burners and low NOx duct burners
Sulfur dioxide (SO ₂)	26,420 (29) ¹	Natural gas fuel
Sulfuric acid mist (H ₂ SO ₄)	17,246 (19)	Natural gas fuel
Volatile organic compounds (VOC)	84,702 (93.2)	Oxidation catalyst
Particulate matter (PM) and Particulate matter = 10 micrometers (PM ₁₀)	192,044 (211.2)	Natural gas fuel
Ammonia (NH ₃)	128,214 (141)	5 ppm ammonia slip limitation

1
2 **10** Allowable emissions, from the new emissions units, will not cause or contribute to air pollution in
3 violation of:

4
5 **10.1** Any state or national ambient air quality standard;

6 **10.2** Any applicable PSD increment.

7
8 The following Table indicates the maximum Class I and Class II increment consumed by this project.
9

POLLUTANT	Maximum ambient Class II area impact concentration (µg/m ³)	Class II area allowable increment (µg/m ³)	Maximum ambient Class I Area impact concentration (µg/m ³)	Class I area allowable increment (µg/m ³)
Particulate (PM ₁₀)*				
Annual	0.27	17	0.00476	4
24-Hour	2.41	30	0.166	8
Nitrogen dioxide*				
Annual	0.35	25	0.00391	2.5
Sulfur dioxide				
Annual	0.17	20	0.00051	2
24-Hour	2.10	91	0.0159	5
3-Hour	4.80	512	0.1281	25
1-Hour	12.18	-	-	-

10 *Evaluated at a higher emission rate than proposed to be permitted see fact sheet and application materials
11 for details.

12
13 **10.3** Ammonia is the significant toxic air pollutant emitted by this facility. The emissions of ammonia and
14 all other toxic air pollutants from this facility will not exceed an acceptable source impact level established
15 under WAC 173-460-150 and 160.

16
17 **11** Ambient Impact Analysis indicates that there will be no significant impacts resulting from pollutant

¹ Based on an annual average natural gas total sulfur content of 0.5 grains/100 scf.

1 deposition on soils and vegetation in either of the closest Class I areas, Olympic and Mt. Rainier National
2 Parks. The deposition of nitrogen within Olympic National Park for the 4 turbine proposal was modeled
3 to be slightly above the level established by the National Park Service for concern. The National Park
4 Service has informed EFSEC that the predicted deposition from the 4 turbine project was acceptable.
5 The current 2 turbine project will have deposition levels significantly below the National Park Service's
6 level of concern.

7
8 **12** Ambient air quality analysis indicates that there will be no adverse impacts resulting from pollutant
9 deposition in the Class II areas surrounding the project site.

10
11 **13** Ambient Impact Analysis indicates that degradation of regional visibility or vistas from Olympic
12 National Park due to the Satsop project is acceptable to the National Park Service.

13
14 **14** No significant effect on industrial, commercial, or residential growth in the Elma area is anticipated due
15 to the project.

16
17 **15** EFSEC finds that all requirements for new source review (NSR) and PSD are satisfied and that as
18 approved below, the new emissions units comply with all applicable federal new source performance
19 standards. Approval of the NOC application is granted subject to the following conditions:

20
21
22 **APPROVAL CONDITIONS**

23
24 **1** This Amendment supercedes air quality PSD approval EFSEC 2001-03, dated November 2, 2001.

25
26 **2** The CGTs and auxiliary boiler shall use only natural gas.

27
28 **3** The diesel emergency generator shall:

29 **3.1** Use only on-road specification diesel oil with a sulfur content of 0.05% by weight or less.

30 **3.2** Not exceed 500 hours per engine per year of operating time.

31
32 **4** Nitrogen oxide emissions limitations

33 **4.1** Each CGT exhaust stack shall not exceed the following:

34 **4.1.1** 9.86 kilograms/hour (kg/hr) (21.7 pounds/hour (lb/hr)), 1-hour (1-hr.)average when duct firing,

35 **4.1.2** 7.89 kg/hr (17.4 lb/hr), 24-hour moving average

36 **4.1.3** 2.5 parts per million by volume, dry (ppm), 1-hr average, corrected to 15.0% oxygen (O₂)

37 **4.1.4** 2.0 ppm, 24-hour moving average, corrected to 15% O₂

38 **4.1.5** Initial compliance shall be determined in accordance with 40 CFR Subpart GG and EPA
39 Reference Method 20, except that the instrument span shall be set between zero and 25 ppm, and

40 **4.1.6** Routine compliance will be indicated by continuous emission monitors for NO_x and O₂. The
41 continuous emission monitoring system (CEMS) must meet the requirements of Approval Condition
42 20.1.

43
44 **4.2** Each auxiliary boiler exhaust stack shall not exceed the following:

45 **4.2.1** 0.468 kg/hr (1.03 lb/hr), 1-hr. average,

46 **4.2.2** 30 ppm at 3% O₂, 1-hr. average,

47 **4.2.3** Initial compliance shall be determined in accordance with 40 CFR Subpart GG and EPA

48 Reference Method 20, except that the instrument span shall be set between zero and 75 ppm, and

1 **4.2.4** Routine compliance will be indicated through

2 **4.2.4.1** Boiler operating records indicating hours of operation and fuel flow and the application of an
3 emission factor derived from stack testing of the installed boilers, and

4 **4.2.4.2** Periodic stack tests taken at 5 year intervals after the initial compliance test.
5

6 **5** Nitrogen oxides plus nonmethane hydrocarbons emissions

7 **5.1** Each diesel generator exhaust stack shall not exceed:

8 **5.1.1** 3.2 kg/hr (7.04 lb/hr) or 6.4 grams per kilowatt-hour,

9 **5.1.2** Initial compliance shall be determined and certified by the engine manufacturer in accordance
10 with the methods in 40 CFR Part 89, and

11 **5.1.3** Routine compliance will be indicated through diesel generator operating hour, maintenance, and
12 fuel records and certification of the engine meeting the applicable new engine standards for engines
13 sold in 2002.
14

15 **5.2** Each emergency fire water pump engine shall meet the emission standard requirements in 40 CFR
16 89 applicable to a new engine of its engine size for 2002.

17 **5.2.1** Initial and routine compliance shall be demonstrated by demonstration/certification by the engine
18 manufacturer that the engine meets the applicable emission standard in 40 CFR 89.
19

20 **6** Ammonia (free NH₃ and combined measured as NH₃) emissions

21 **6.1** Each CGT exhaust stack shall not exceed the following:

22 **6.1.1** 5.0 ppm, 24-hour average corrected to 15.0 percent O₂,

23 **6.1.2** 7.3 kg/hr (16.1 lb/hr), 24-hour average,

24 **6.1.3** Initial compliance for each CGT shall be determined by Bay Area Air Quality Management
25 District Source Test Procedure ST-1B, "Ammonia, Integrated Sampling," EPA Conditional Test
26 Method 027, or an equivalent method approved in advance by EFSEC, and

27 **6.1.4** Routine compliance determinations will be determined through use of a CEMS which meets the
28 requirements of Approval Condition 20.2 or Duke Energy may propose alternative means for
29 continuous assessment and reporting of NH₃ emissions for approval by EFSEC. Any proposed
30 alternative NH₃ reporting shall be at a minimum equivalent to a CEMS which meets the requirements
31 of Approval Condition 20.2.
32

33 **6.2** The SCR catalyst treating the exhaust from one CGT shall be repaired or replaced at the next
34 scheduled outage, following a time period when ammonia slip can no longer be maintained at or below 4.5
35 ppm corrected to 15.0 percent oxygen. The outage shall be no later than 12 months after ammonia slip
36 exceeds 4.5 ppm corrected to 15.0 percent oxygen.
37

38 **6.3** The permit limitations outlined in this section shall not apply to startup, shutdown and scheduled
39 maintenance conditions.
40

41 **7** Carbon monoxide emissions

42 **7.1** Each CGT exhaust stack shall not exceed the following:

43 **7.1.1** 2 ppm corrected to 15.0 percent oxygen, 3-hr. average

44 **7.1.2** 4.81 kg/hr (10.6 lb/hr) at 100% load, 3-hr. average

45 **7.1.3** Initial compliance for each CGT shall be determined by EPA Reference Method 10 or an
46 equivalent method agreed to in advance by EFSEC. The span and linearity calibration gas
47 concentrations in Method 10 shall be appropriate to the CO concentration limits specified in this
48 condition, and

1 **7.1.4** Routine compliance determinations will be determined through use of a continuous emission
2 monitor which meets the requirements of Approval Condition 16.3.

3
4 **7.2** Each auxiliary boiler exhaust stack shall not exceed the following:

5 **7.2.1** 50.0 ppm, 1- hour average corrected to 3.0% O₂, 3-hr. average

6 **7.2.2** 0.485 kg/hr (1.07 lb/hr) at 100% load, 3-hr. average

7 **7.2.3** Initial compliance for each auxiliary boiler shall be determined by EPA Reference Method 10 or
8 an equivalent method agreed to in advance by the EFSEC. The span and linearity calibration gas
9 concentrations in Method 10 shall be appropriate to the CO concentration limits specified in this
10 condition, and

11 **7.2.4** Routine compliance will be indicated through:

12 **7.2.4.1** Boiler operating records indicating

13 **7.2.4.1.1** Hours of operation and

14 **7.2.4.1.2** Fuel flow

15 **7.2.4.2** The application of an emission factor derived from stack testing of the installed boilers, and

16 **7.2.4.3** Periodic stack tests taken at 5 year intervals after the initial compliance test.

17
18 **7.3** Each diesel generator exhaust stack shall not exceed the following:

19 **7.3.1** 1.75 kg/hr (3.86 lb/hr) or 3.5 grams per kilowatt-hour,

20 **7.3.2** Initial compliance shall be determined and certified by the engine manufacturer in accordance
21 with the methods in 40 CFR Part 89, and

22 Routine compliance will be indicated through diesel generator operating hour records and certification of
23 the engine meeting the applicable new engine standards for engines sold in 2002.

24
25 **7.4** Each emergency fire water pump engine shall meet the emission standard requirements in 40 CFR
26 89 applicable to a new engine of its engine size for 2002.

27 **7.4.1** Initial and routine compliance shall be demonstrated by demonstration/certification by the engine
28 manufacturer that the engine meets the applicable emission standard in 40 CFR 89.

29
30 **8** Sulfur dioxide emissions

31 **8.1** Each CGT exhaust stack shall not exceed the following:

32 **8.1.1** 1.5 kg/hr (3.3 lb /hr), rolling annual-average calculated monthly,

33 **8.1.2** 9.0 kg/hr (19.8 lb/hr), 1-hr. average,

34 **8.1.3** Initial compliance for each CGT shall be determined by EPA Reference Method 8, or an
35 equivalent method approved in advance by EFSEC. Duke Energy shall conduct source testing for
36 sulfur dioxide once per month for the first year of operation at each CGT exhaust stack,

37 **8.1.4** Routine compliance shall be determined through:

38 **8.1.4.1** Annual stack test on each CGT stack using the above Reference Method. The timing of the
39 annual stack test will coincide with the annual RATA testing for the installed CEM systems,

40 **8.1.5** Routine compliance shall be indicated through:

41 **8.1.5.1** Monthly calculation of the SO₂ emissions based on

42 **8.1.5.1.1** The quantity of natural gas used by each turbine

43 **8.1.5.1.2** The total sulfur content of the natural gas consumed

44 **8.1.5.1.3** Subtracting the quantity of potential SO₂ converted to H₂SO₄. The conversion rate of
45 potential SO₂ to H₂SO₄ is determined through the information provided by the Method 8 stack
46 tests required in Approval Conditions 8.1 and 9.1.

47 **8.1.5.2** Duke Energy shall report to EFSEC on a monthly basis the quantity and average sulfur content
48 of the natural gas burned by the CGT units at the facility. Total sulfur content on the natural gas

1 shall be substantiated by purchase records and vendor's reports or total sulfur content monitoring
2 performed by Duke Energy on the gas used at this facility.

3 **8.1.6** Fuel sulfur determination shall follow the more stringent of the procedures in 40 CFR 60.335(d)
4 and (e) and 40 CFR Part 75, Appendix D.

5
6 **8.2** Each auxiliary boiler exhaust stack shall not exceed:

7 **8.2.1** 0.032 kg/yr (0.07 lb/hr) annual average, calculated monthly,

8 **8.2.2** 1 ppm at 3% O₂, 3- hr. average

9 **8.2.3** Initial compliance for each auxiliary boiler shall be determined by EPA Reference Method 8, or
10 an equivalent method approved in advance by EFSEC,

11 **8.2.4** Routine compliance shall be determined by

12 **8.2.4.1** Fuel consumption records for each auxiliary boiler and

13 **8.2.4.2** Total sulfur content of the natural gas consumed in the boilers, and

14 **8.2.5** Natural gas sulfur content shall be measured and reported through the methods defined in
15 Approval Condition 8.1.

16
17 **8.3** Each diesel generator exhaust stack shall not exceed:

18 **8.3.1** 2.93 kg/day (6.56 lb/day), 1-day. average,

19 **8.3.2** Initial compliance shall be determined and certified by the engine manufacturer in accordance
20 with the methods in 40 CFR Part 89, and

21 **8.3.3** Routine compliance will be indicated by calculating the sulfur dioxide emissions based on

22 **8.3.3.1** Generator fuel usage, and

23 **8.3.3.2** Fuel sulfur content records.

24
25 **9** Sulfuric acid mist emissions

26 **9.1** Each CGT exhaust stack shall not exceed the following:

27 **9.1.1** 0.984 kg/hr (2.17 lb H₂SO₄/hr), rolling annual average calculated monthly,

28 **9.1.2** Initial compliance with the sulfuric acid emissions limits shall be determined by EPA Reference
29 Method 8, or an equivalent method approved by EFSEC. Duke Energy shall conduct source testing
30 for sulfuric acid mist once per month for the first year of operation at each exhaust stack.

31 **9.1.3** Routine compliance shall be indicated through:

32 **9.1.3.1** Annual stack testing for sulfuric acid mist using EPA Reference Method 8.

33 **9.1.3.2** Monthly calculation of the sulfuric acid mist emissions based on

34 **9.1.3.2.1** The quantity of natural gas used by each turbine

35 **9.1.3.2.2** The total sulfur content of the natural gas consumed

36 **9.1.3.2.3** Subtracting the quantity of potential SO₂ converted to H₂SO₄. The conversion rate of
37 potential SO₂ to H₂SO₄ determined through the Method 8 stack tests required in Approval
38 Conditions 8.1 and 9.1 and updated annually.

39 **9.1.4** Fuel sulfur determination shall follow procedures outlined in Approval Condition 8.1.

40
41 **10** Volatile organic compound emissions

42 **10.1** Each CGT exhaust stack shall not exceed the following:

43 **10.1.1** 12.86 kg/hr (6.3 lb /hr), 1-hr average, reported as carbon equivalent,

44 **10.1.2** 8 ppm, 1-hr average, reported as carbon equivalent

45 **10.1.3** Initial compliance for each CGT shall be determined by EPA Reference Method 25A or 25B, or
46 an equivalent method agreed to in advance by EFSEC, and

47 **10.1.4** Routine compliance will be indicated through boiler operating records indicating

48 **10.1.4.1** Hours of operation,

- 1 **10.1.4.2** Fuel flow,
2 **10.1.4.3** Application of an emission factor derived from stack testing of the installed boilers, and
3 **10.1.4.4** Annual stack testing using one of the above referenced methods.
4
- 5 **10.2** Each auxiliary boiler exhaust stack shall not exceed the following:
6 **10.2.1** 213 kg/hour (0.469 lb /hr), 1-hour average, reported as carbon equivalent,
7 **10.2.2** Initial compliance for each auxiliary boiler shall be determined by EPA Reference Method 25A
8 or 25B, or an equivalent method agreed to in advance by EFSEC, and
9 **10.2.3** Routine compliance will be indicated through boiler operating records indicating
10 **10.2.3.1** Hours of operation,
11 **10.2.3.2** Fuel flow,
12 **10.2.3.3** Application of an emission factor derived from stack testing of the installed boilers, and
13 **10.2.3.4** Periodic stack tests, using one of the above referenced methods, taken at 5 year intervals
14 after the initial compliance test.
15
- 16 **11** Particulate Matter and Particulate Matter less than or equal to 10 micrometer (PM₁₀) emissions
17 **11.1** Each CGT exhaust stack shall not exceed the following:
18 **11.1.1** 246.0 kg/24 hours (542.4 lb/24 hours), filterable plus condensable PM,
19 **11.1.2** 0.003 grains/dry standard cubic foot(gr/dscf), filterable plus condensable PM at 15% O₂,
20 **11.1.3** Initial compliance for each CGT exhaust stack shall be determined by use of EPA Reference
21 Methods 5, 201, or 201A, plus Reference Method 202, or an equivalent method agreed to in advance
22 by EFSEC. Use of EPA Reference Method 5 assumes all filterable particulate is PM₁₀. Use of
23 EPA Reference Method 201 or 201A assumes that the mass of filterable PM is equal to the mass of
24 filterable PM₁₀. If Method 201 or 201A is used, the mass of particulate retained in the cyclone shall
25 be determined and reported.
26 **11.1.4** The results of the filterable and condensable particulate analyses shall be reported as total
27 particulate, filterable particulate and condensable particulate.
28 **11.2** Routine compliance shall be the following:
29 **11.2.1** An annual emissions test on each CGT exhaust stack using the methods indicated above. After
30 the initial 3 years of tests on each CGT stack have been completed, each CGT stack shall be tested
31 once every 5 years unless the initial 3 years of testing indicates noncompliance with the limitations,
32 then the testing frequency remains annual until 3 consecutive years of testing indicating compliance is
33 achieved. The timing of these annual emissions tests shall coincide with the annual RATA testing,
34 and
35 **11.2.2** When PM₁₀ stack test data is not available, routine compliance shall be indicated by the use of
36 natural gas for fuel and through operating records and the application of a source test derived
37 emission factor.
38
- 39 **11.3** Each auxiliary boiler exhaust stack shall not exceed:
40 **11.3.1** 13.175 kg/day (7.0 lb/day), annual average, filterable plus condensable PM₁₀,
41 **11.3.2** 0.005 gr/dscf, filterable plus condensable PM at 15% O₂.
42 **11.3.3** Initial compliance for each auxiliary boiler exhaust stack shall be determined by either EPA
43 Reference Methods 5, 201, or 201A, or an equivalent method agreed to in advance by EFSEC. Use
44 of EPA Reference Method 5 assumes all particulate is in the form of PM₁₀. Use of EPA Reference
45 Method 201 or 201A assumes that the mass of filterable PM is equal to the mass of filterable PM₁₀.
46 **11.3.4** The results of the filterable and condensable particulate analyses shall be reported as total
47 particulate, filterable particulate and condensable particulate.
48

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48

11.3.5 Routine compliance will be indicated through:

11.3.5.1 Boiler operating records indicating

11.3.5.1.1 Hours of operation,

11.3.5.1.2 Fuel flow, and

11.3.5.1.3 Application of an emission factor derived from stack testing of the installed boilers.

11.3.5.2 Periodic stack tests, using the above specified methods, taken at 5 year intervals after the initial compliance test.

11.4 Each diesel generator exhaust stack shall not exceed:

11.4.1 2.4 g/day (5.28 lb/day) or 0.20 grams particulate per kilowatt-hour,

11.4.2 Initial compliance shall be determined and certified by the engine manufacturer in accordance with the methods in 40 CFR Part 89, and

Routine compliance will be indicated through diesel generator operating hour records and certification of the engine meeting the applicable new engine standards for engines sold in 2002.

11.5 Each emergency fire water pump engine shall meet the emission standard requirements in 40 CFR 89 applicable to a new engine of its engine size for 2002.

11.5.1 Initial and routine compliance shall be demonstrated by demonstration/certification by the engine manufacturer that the engine meets the applicable emission standard in 40 CFR 89.

11.6 Each cooling tower shall not exceed:

11.6.1 11.11 kg/day (24.5 lb/day), annual average,

11.6.2 4062 kg/yr (4.5 tpy), rolling total, calculated monthly,

11.6.3 Initial compliance shall be determined by:

11.6.3.1 A total solids mass balance across each cooling tower. The analysis shall incorporate factors involving the :

11.6.3.1.1 Cooling tower recirculation rate,

11.6.3.1.2 Cooling tower total dissolved solids (TDS),

11.6.3.1.3 Fan operation effects, and

11.6.3.1.4 Manufacturer's information on drift losses

11.6.3.1.5 The methodology shall be submitted to and accepted by EFSEC prior to the first operation of any cooling tower.

11.6.3.2 An affirmative report by the cooling tower drift eliminator manufacturer, based on an onsite inspection of the completed installation, that its product has been installed in accordance with its specifications accompanied by the results of a test or analysis of the cooling tower drift eliminator material indicating that the material has a drift loss of less than 0.001% of the recirculating water flow rate. The required test could be performed on a full size mist eliminator module under laboratory conditions that match the worst case operations scenario of the actual cooling tower,

11.6.4 Routine compliance using the same calculation methodology used for the initial compliance test, once each quarter estimate the PM emissions from each cooling tower.

11.6.5 Prior to operation of the cooling tower, Duke shall submit to EFSEC, a report describing the manufacturer's recommendations for installing, operating and testing the drift eliminators.

12 Opacity

12.1 Each CGT exhaust stack shall not exceed a six minute average of 5 percent,

12.2 Each auxiliary boiler exhaust stack shall not exceed a six minute average of 5 percent,

12.3 Each diesel generator exhaust stack shall not exceed a six minute average of 10 percent,

1 **12.4** Opacity shall be determined by use of EPA Reference Method 9, or an equivalent method approved
 2 in advanced by EFSEC. A certified opacity reader shall read and record the opacity of each operating
 3 unit once per day, and

4 **12.5** Installation of a Continuous Opacity Monitoring system on each CGT can be substituted for use of
 5 EPA Reference Method 9 readings for the CGTs. If installed, the continuous opacity monitor must meet
 6 the requirements of Approval Condition 20.

7
 8 **13** Annual emissions shall not exceed the limits in the following table. The annual limits are 12 month
 9 rolling totals.

Pollutant	Each CGT kg/year (tons/vr)	Auxiliary boiler kg/year(tons/vr)	Cooling tower kg/year (tons/vr)	Diesel emergency generator kg/year(tons/vr)
NO _x	110,625.5 (121.7)**	1,170 (1.3)	--	1,195 (1.35)*
CO	196,065.5 (215.7)**	1,216 (1.3)	--	877.3 (1.0)
SO ₂	13,140 (14.5)	79.5 (0.088)	--	61.1 (0.1)
H ₂ SO ₄	8623 (9.5)	--	--	--
PM/PM ₁₀ ***	89,989.1 (99.0)	7954 (8.8)	4061 (4.5)	50 (0.1)
VOC	41,916.4 (46.1)**	533 (0.6)	--	Included in generator NO _x
NH ₃	64,107 (70.5)	--	--	--

11 *Limit for diesel generators is Nonmethane hydrocarbons plus NO_x. In this presentation the
 12 assumption is that all of the emissions are as NO_x.

13 **Includes the emissions from startup and shutdown events of the CGTs and diesel generators. CGT
 14 start up emissions are equally apportioned among the 2 turbines.

15 ***PM and PM₁₀, conservatively assumed to be equal.

16
 17 **14** Routine equipment startup and shut down

18 **14.1** Each CGT is limited to 130 startup and shutdown events per calendar year,

19 **14.2** Each CGT is limited to 2 startup and shutdown events per calendar day. This limitation does not
 20 apply during the period between initial firing of a combustion turbine for testing purposes and the start-up
 21 condition specified in Approval Condition 16.

22 **14.3** The startup period begins when fuel is first fired in the combustion turbine,

23 **14.4** The startup period ends when the earlier of these two operating events occurs:

24 **14.4.1** The proper operating temperature of the oxidation and SCR catalysts serving one CGT has been
 25 achieved and all dry-low-NO_x burners for each combustion turbine are operational, or

26 **14.4.2** 24 hours maximum for both turbines in a single power island have elapsed since fuel was first
 27 combusted in the first turbine.

28 **14.5** The proper operating temperature of the oxidation and SCR catalysts and the point at which all dry-
 29 low-NO_x burners for each combustion turbine are operational shall be determined from the
 30 manufacturer's design specifications and must be reported in writing to EFSEC before commercial
 31 operation of the combustion turbines,

32 **14.6** Compliance with short-term emission limits (during startup and shutdown periods) shall be
 33 determined using manufacturer's emission factors or source test data using the EPA Reference Methods
 34 noted above. Where source test data and manufacturer's emission factors conflict, source test data shall

1 be used to determine compliance,

2 **14.7** Emissions resulting from these startup and shutdown events shall be included in the quarterly
 3 emissions reporting of Approval Condition 21.

4
 5 **14.8** The following emission factors may be used for calculating the emissions generated during startup
 6 and shutdown periods for the CGTs in a single power island until source test data is developed by Duke
 7 Energy, submitted to and approved by EFSEC that demonstrates a different value is appropriate:
 8

Pollutant	Emission Factor (per pair turbines in one power island)
Nitrogen oxides	1536 lb/4-hr
Carbon monoxide	5288 lb/4-hr
Volatile organic compounds	354 lb/4-hr

9
 10 **15** Within 180 days after formal, initial start-up of each combustion turbine, auxiliary boiler, and installation
 11 of the diesel generators, Duke shall conduct the initial performance tests for NO_x, ammonia, SO₂,
 12 opacity, VOC, CO, PM₁₀ and H₂SO₄ noted above. The initial performance testing shall be performed by
 13 an independent testing firm. A test plan shall be submitted to EFSEC for approval at least 30 days prior
 14 to the testing. The initial compliance tests and all subsequent compliance tests shall be made at
 15 maximum load.
 16

17 **16** Initial start-up for determining when the initial compliance testing, CEM system performance testing,
 18 and other, non acid rain program purposes is the earlier of the following dates:

19 **16.1** The earliest date that electrical power is offered for sale (not test generation) from a CGT and its
 20 associated steam turbine, or

21 **16.2** 180 days after the first CGT in the power island has been synchronized to the electrical distribution
 22 grid.
 23

24 **17** Duke Energy shall notify EFSEC in writing at least thirty days prior to

25 **17.1** Initial start-up of any permitted emissions unit for operational testing and manufacturer's
 26 certification purposes.

27 **17.2** Formal, initial start-up defined in Approval Condition 16.

28 **17.3** The date any emissions testing required by this permit will be performed when the time between
 29 tests is specified to be longer than 30 days.

30 **17.4** The date(s) CEMS performance testing or Relative Accuracy Test Audits will be performed.
 31

32 **18** Sampling ports and platforms shall be provided on each CGT stack, after the final pollution control
 33 device. The ports shall meet the requirements of 40 CFR, Part 60, Appendix A, Method 20. Sampling
 34 ports and platforms for each auxiliary boiler and diesel engine shall meet the requirements of 40 CFR
 35 Part 60, Appendix A, Method 1.
 36

37 **19** Adequate permanent and safe access to the test ports shall be provided. Other arrangements may be
 38 acceptable if approved by EFSEC prior to installation.
 39

40 **20** Operating Records for Emitting Equipment.

41 **20.1** Unless otherwise specified above, operating records shall be information necessary to determine the
 42 operational status of the equipment. Specific parameters and acceptable ranges of those parameters shall
 43 be specified in the Operation and Maintenance Manual.

- 1 **20.1.1** Example operating record information includes, but is not limited to:
- 2 **20.1.1.1** Fuel quality.
- 3 **20.1.1.2** Fuel consumption during the period (hourly, monthly, etc.).
- 4 **20.1.1.3** Unit operating parameters such as
- 5 **20.1.1.3.1** Exhaust temperature,
- 6 **20.1.1.3.2** Percent excess air,
- 7 **20.1.1.3.3** Output rate (pounds of steam/hour, kW output, etc.),
- 8 **20.1.1.3.4** Operating hours during the reporting period and cumulative for the year.
- 9
- 10 **21** Continuous Emission Monitoring Systems (CEMS)
- 11 **21.1** CEMS for NO_x and O₂ compliance shall meet the requirements contained in 40 CFR 75, Emissions
- 12 Monitoring.
- 13 **21.2** CEMS for ammonia shall meet the requirements contained in 40 CFR, Part 63, Appendix A,
- 14 Reference Method 301, Validation Protocol, and 40 CFR, Part 60, Appendix F, Quality Assurance
- 15 Procedures, or other EFSEC- approved performance specifications and quality assurance procedures.
- 16 **21.3** CEMS for CO shall meet the requirements contained in 40 CFR, Part 60, Appendix B, Performance
- 17 Specification 4 or 4A, and in 40 CFR, Part 60, Appendix F, Quality Assurance Procedures.
- 18 **21.4** CEMS for opacity shall meet the requirements contained in 40 CFR Part 60, Appendix B,
- 19 Performance Specification 1 and in 40 CFR, Part 60, Appendix F, Quality Assurance Procedures.
- 20
- 21 **22** CEMS and process data shall be submitted quarterly, in written form (or electronic if permitted by the
- 22 EFSEC) monthly within thirty days of the end of each calendar quarter to EFSEC, its authorized
- 23 representative (if any), and to the EPA Region X Office of Air Quality.
- 24
- 25 **23** The format of the reporting described in Approval Condition 21 shall match that required by EPA for
- 26 demonstrating compliance with the Title IV Acid Rain program reporting requirements. Pollutants not
- 27 covered by that format shall be reported in a format approved by EFSEC that shall include at least the
- 28 following:
- 29 **23.1** Process or control equipment operating parameters,
- 30 **23.2** The hourly maximum and average concentration, in the units of the standards, for each pollutant
- 31 monitored,
- 32 **23.3** The duration and nature of any monitor down-time,
- 33 **23.4** Results of any monitor audits or accuracy checks,
- 34 **23.5** Results of any required stack tests,
- 35 **23.6** Results of any other stack tests performed after the initial performance test.
- 36 **23.7** The above data shall be retained at the Satsop CT Project site for a period of at least five years.
- 37
- 38 **24** For each occurrence of monitored emissions in excess of the standard, the quarterly emissions report
- 39 (per Approval Conditions 21 and 22) shall include the following:
- 40 **24.1** For parameters subject to monitoring and reporting under the Title IV, Acid Rain program, the
- 41 reporting requirements in that program shall govern excess emissions report content.
- 42 **24.2** For all other pollutants:
- 43 **24.2.1** The time of the occurrence,
- 44 **24.2.2** Magnitude of the emission or process parameters excess,
- 45 **24.2.3** The duration of the excess,
- 46 **24.2.4** The probable cause,
- 47 **24.2.5** Corrective actions taken or planned,
- 48 **24.2.6** Any other agency contacted.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48

25 Duke Energy shall have on site, and shall follow, an Operating and Maintenance manual, and an equipment Start-up, Shut-down, and Malfunction Procedures manual for all equipment that has the potential to affect emissions to the atmosphere. Copies of the manuals shall be available to EFSEC or the authorized representative of EFSEC at the facility. Emissions that result from a failure to follow the requirements of the manuals may be considered evidence that emission violations have occurred. The above manuals must be reviewed annually and updated as needed. EFSEC shall be notified whenever the manual is updated.

25.1 The Operating and Maintenance manual should contain equipment specific operating parameter and maintenance information. Examples of the operational information to include are:

25.1.1 Control equipment normal operating ranges such as:

25.1.1.1 Normal operating temperature range.

25.1.1.2 Normal pressure drop and acceptable range of pressure drops.

25.1.1.3 Fan speed range.

25.1.1.4 Reagent feed rate.

25.1.1.5 Scrubber liquor pH range.

25.1.1.6 Scrubber liquor feed rate and pressure.

25.1.2 Boiler operating parameters such as:

25.1.2.1 Fuel feed rate.

25.1.2.2 Steam pressure.

25.1.2.3 Combustion air flow rate.

25.1.3 Combustion turbine operating parameters such as:

25.1.3.1 Temperature ranges at inlet, combustors, turbine exhaust.

25.1.3.2 Allowable vibration range.

25.1.3.3 Inlet humidity.

25.1.3.4 Operating speed (rpm) range.

25.1.3.5 Turbine fuel feed rate.

25.1.4 Similar type operational measures for other emitting equipment, such as diesel generators and cooling towers.

25.2 The Start-up, Shut-down, and the Malfunction manual shall contain information on the proper procedures, and sequencing of actions for plant operations staff to follow in order to safely and efficiently start and stop the various equipment at the station under all reasonably ascertainable normal and abnormal start-up and shut-down situations.

26 Construction time

26.1 Construction of this project began under terms of Administrative Order on Consent, Docket No. CAA-10-2001-0097, dated March 30, 2001, and has continued under air quality approval EFSEC 2001-01, dated November 2, 2001.

26.2 This superceding approval shall become void for the construction of this project if construction is discontinued for a period of 18 months or more. Duke Energy may request and EFSEC may extend the 18 month period upon a satisfactory showing that an extension is justified pursuant to 40 CFR 52.1 (r) (2) and applicable EPA guidance.

27 Any activity which is undertaken by Duke Energy, or others, in a manner which is inconsistent with the application and this determination, shall be subject to EFSEC enforcement under applicable regulations. Nothing in this determination shall be construed so as to relieve Duke Energy of its obligations under any state, local, or federal laws or regulations.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42

28 Access to the source by EFSEC, the authorized representative of EFSEC, or the U.S. Environmental Protection Agency (EPA), shall be permitted upon request for the purpose of compliance assurance inspections. Failure to allow access is grounds for action under the Federal Clean Air Act or the Washington Clean Air Act.

Prepared by:

Alan Newman, P.E
Engineering and Technical Services
Air Quality Program
Washington Department of Ecology

Date

Approved by:

James O. Luce
Energy Facility Site Evaluation Council

Date

Approved by:

Barbara McAllister
Director
Office of Air Quality
U.S. Environmental Protection Agency
Region 10

Date