



City of Puyallup Development Services

Fire Division
333 S. Meridian
Puyallup, WA 98371
Tel. (253) 864-4165 Fax: (253) 840-6678

Fire Alarm Application

REQUI RED MASTER/ORIGINAL BUILDING PERMIT NUMBER	Complete page 2 of the application for permit acceptance		
Parcel # :	Site Address:		
Owner:	Owner Phone:		
Owner Address:	City:	Zip:	
Contractor Name:	Contractor Phone:		
Contractor Address:	City:	Zip:	
WA State License # :	Exp. Date:	City Business License No.	
Contact Person:	Contact Phone	Fax	
Designer:	Certification Number:	NI CET LEVEL 2 or Lic. FPE REQUI RED	
Designer Contact Information:			
REQUI RED UL LISTED FIRE ALARM COMPANY NAME:		UL LISTING NO.	
CONTACT			
Description of Project			
<hr/> <hr/> <hr/> <hr/> <hr/>			

I HEREBY CERTIFY THAT I HAVE READ AND EXAMINED THIS APPLICATION AND KNOW THE SAME TO BE TRUE AND CORRECT. ALL PROVISIONS OF LAWS AND ORDINANCES GOVERNING THIS TYPE OF WORK WILL BE COMPLIED WITH WHETHER SPECIFIED HEREIN OR NOT.

** BY LEAVING THE CONTRACTOR INFORMATION SECTION BLANK, I HEREBY CERTIFY FURTHER THAT CONTRACTORS (GENERAL OR SUBCONTRACTORS) WILL NOT BE HIRED TO PERFORM ANY WORK IN ASSOCIATION WITH THIS PERMIT.

SIGNATURE OWNER / AUTHORIZED AGENT

DATE: ____/____/____

PLEASE PRINT NAME

FIRE ALARM Permit Information

System Serves Multiple Buildings	YES / NO	Type of Construction	
Occupancy Group and Division		Area of Evacuation Assistance Communications	YES / NO
Number of Dwelling Units		Total Square Footage	
Occupant Load			
Underwriters Laboratory System Listing Certificate # _____		Hazardous Materials Storage Include details	YES / NO
Change of Use (Occupancy)	YES / NO	Exceptions Requested	YES / NO
Modification or New System		High Piled Storage	YES / NO
Total Number of New / Relocated Devices		New System Is Addressable	YES / NO
Number of Zones			

FIRE ALARM SYSTEM SUBMITTAL REQUIREMENTS	INDICATE YES OR NO
1) Three (3) complete sets of plans and specs. NICET 2 or Fire-Protection Engineer stamps on all sheets. Three sets of voltage calculations. Plans shall be on standard 24" to 30" by 36" to 42" paper and shall be clearly legible regarding all pertinent information. Include dimensions, scale, and north arrow	
2) The Fire Alarm System shall be designed as "Total Coverage" in accordance with NFPA 72.	
3) Include a riser diagram and wiring diagram (per floor).	
4) Clearly indicated the use of all areas on the plans. All areas shall be shown and labeled	
5) Note on the face of the plans the contractually responsible parties for Monitoring, Installation and Testing, and Maintenance	
6) Provide a plan view schematic for each floor, showing all zones (including existing zones shown on an existing control panel, if applicable). All zones must be labeled with a unique and individual letter or number, and identified clearly as to their respective areas of coverage. The schematic shall indicate which zones are to be transmitted individually and which zones are to be grouped for transmission to the central station.	
7) Plans shall indicate the location of the FACP and remote annunciator located on the exterior of the building with the type of weather resistant cover.	
8) All system components shall be identified on a component schedule. Provide cut sheets for each component.	
9) Provide a zone map detail. This zone map will be required to be mounted next to the remote annunciator in a weather resistant manner. (example-Engraved plastic laminate). NOTE: ALL NEW FIRE ALARM SYSTEMS MUST BE ADDRESSABLE-7/ 21/ 2004 (CITY OF PUYALLUP POLI CY)	
10) Proof of review and acceptance by the Designer of Record shall be provided on all plan sheets	
11) Calculations shall be included with plans that document ANY deviations from listed spacing, such as reductions for ceiling height or airflow, corridor spacing, or similar; or when otherwise called for in NFPA 72.	
12) ALL FIRE ALARM SYSTEMS SHALL BE CERTIFIED BY UNDERWRITERS LABORATORY. Prior to final approval for the installation of any fire alarm system, the installer or owner shall provide the City with a copy of a completed application for Underwriters Laboratory Fire Alarm Certification.	

Failure to provide any of the above requested information may result in a delay of the review process and the rejection of your application