



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M/ECOM Manual

Doc OM-5	Rev. No. 6
Revision Date: 3/1/14	
Reviewed Date: 3/1/14	

### ATTACHMENT 5-3

## COMBINED ASH SAMPLING LOG

DATE: \_\_\_\_\_

SAMPLE COLLECTION								
SHIFT SAMPLE	SAMPLE TIME	FLYASH ON / OFF		BOTTOM ASH ON / OFF		Any By-Pass Ash NO YES		OPERATOR
1.								
2.								
3.								
4.								
5.								
6.								
7.								
8.								
9.								
10.								
11.								
12.								
13.								
14.								
15.								
16.								
17.								
18.								
19.								
20.								
21.								
22.								
23.								
24.								

**COLLECT A MAXIMUM OF 24 SAMPLES AND A MINIMUM OF 18. IF A SAMPLE TIME IS MISSED, JUST CONTINUE AT THE NEXT SAMPLING TIME.**

*Printed copies are not document controlled, refer to "S" drive, ISO 14001 Environmental Management Systems file for latest approved version*



**COVANTA NIAGARA**  
**O&M Manual/ECOM**

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## **SECTION 6**

**COVANTA NIAGARA, L.P.**

**NIAGARA RESOURCE RECOVERY FACILITY**

**OPERATIONS AND FACILITY INSPECTION PLAN**

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## SECTION 6

### COVANTA NIAGARA

#### OPERATIONS AND FACILITY INSPECTION PLAN

- 6.1 INTRODUCTION
- 6.2 DAILY MONITORING AND INSPECTION
- 6.3 OPERATIONS WATCH STATIONS
  - 6.3.1 SHIFT SUPERVISOR
  - 6.3.2 CONTROL ROOM OPERATOR
  - 6.3.3 ASSISTANT CONTROL ROOM OPERATOR
  - 6.3.4 BACKEND OPERATOR
  - 6.3.5 REFUSE CRANE OPERATOR
  - 6.3.6 TIPPING FLOOR OPERATOR
  - 6.3.7 FERROUS/NONFERROUS OPERATOR
  - 6.3.8 WATER TENDER
  - 6.3.9 ALTERNATE FUELS BOILER OPERATOR
  - 6.3.10 LIQUID WASTE OPERATOR
  - 6.3.11 RTIF LEAD OPERATOR
  - 6.3.12 CONTAINER HANDLER OPERATOR
  - 6.3.13 UTILITY OPERATOR
  - 6.3.14 DRIVERS
- 6.4 OPERATION MONITORING LOGS
- 6.5 OPERATIONS GROUP CHEMICAL/FUEL OIL STORAGE INSPECTIONS



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

6.6 OPERATIONS GROUP PERIODIC EQUIPMENT INSPECTIONS

6.7 MAJOR REVISIONS TO THE OPERATIONS AND FACILITY INSPECTION PLAN

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## SECTION 6

### OPERATIONS AND FACILITY INSPECTION PLAN

#### LIST OF ATTACHMENTS

- 6-1 COVANTA NIAGARA PRODUCTION REPORT
- 6-2 SHIFT SUPERVISOR LOG
- 6-3 CONTROL ROOM OPERATOR'S LOGBOOK
- 6-4 CONTROL ROOM OPERATOR'S LOG
- 6-5 ASSISTANT CONTROL ROOM OPERATOR'S LOG
- 6-6 BACKEND OPERATOR'S LOG
- 6-7 REFUSE CRANE OPERATOR'S LOG
- 6-8 FERROUS/NON FERROUS RECOVERY OPERATOR'S LOG
- 6-9 WATER TENDER OPERATOR'S LOG
- 6-10 ALTERNATE FUELS OPERATOR'S LOG
- 6-11 LIQUID WASTE OPERATOR'S LOG
- 6-12 CHEMICAL AND FUEL STORAGE TANK INSPECTIONS
- 6-13 RTIF LEAD OPERATOR'S LOG

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## OPERATIONS MONITORING AND FACILITY INSPECTION PLAN

### 6.1 INTRODUCTION

The purpose of this plan is to overview the operations and facility inspection monitoring and inspection procedures undertaken by Covanta Niagara facility personnel as required by 6 NYCRR Part 360 3.3(h).

### 6.2 DAILY MONITORING AND INSPECTION

In order to discover and correct any equipment malfunctions/deteriorations, operator errors, or emissions that may threaten the environment or human health, the facility has an on-going daily monitoring and inspection program. The baseline equipment evaluation is done through operator logs which are filled out by operating personnel on a daily basis. Inspections conducted per EMIS should be submitted to the plant environmental engineer upon completion.

### 6.3 OPERATIONS WATCHSTATIONS

#### 6.3.1 SHIFT SUPERVISOR

The shift supervisor is responsible for operating the facility in a safe, environmentally correct, and efficient manner on a day to day basis through the activities of the personnel on his shift. These activities include: waste receipts, waste combustion, steam generation, electric power generation, steam distribution, air pollution control system operations, ash residue handling/processing/loadout, and ferrous and nonferrous metals recovery. All of the shift supervisors are required to obtain the full qualified refuse operator (QRO) certification from the American Society of Mechanical Engineers.

The shift supervisor monitors the operation of the facility through verbal reports and written logs received from the control room and field operating technicians, as well as his own inspections of the process equipment. If a piece of equipment is reported to be in need of repair, the shift supervisor is responsible for ensuring that a work order request gets submitted on the Maximo maintenance control computer system.

When a piece of equipment requires maintenance, it is the responsibility of the shift supervisor to ensure that the equipment is properly prepared for maintenance personnel. This usually requires locking out (ensuring that the equipment is isolated

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

and can be safely worked on) the equipment and may further require that the shift supervisor reviews piping and instrument drawings to ensure a proper lockout.

The shift supervisor reports directly to the operations superintendent and prepares the production report (Attachment 6-1) at the end of the shift which contains a summary of production related information and shows the facility's upper management the status of the plant. In addition to the shift report, the shift supervisor maintains a log (Attachment 6-2) during the shift that is intended to contain notes of operational and maintenance events that occurred during the shift. For example, if production were interrupted due to equipment malfunction, the log would describe the events (what time, what happened, what corrective actions were taken, how long it took to correct, etc.). At shift change the log is reviewed by the outgoing and oncoming shift supervisors.

### **6.3.2 CONTROL ROOM OPERATOR**

The control room operator (CRO) is the senior operator on shift, and is directly responsible for the safe, efficient and environmentally acceptable operation of the boilers, turbine generators, electrical distribution and a majority of the plant auxiliary equipment. At Covanta Niagara, all CROs must hold a valid fireman's class license issued by the City of Niagara Falls. This license indicates that the CRO has successfully completed testing in basic design, construction, and operation of boilers, turbines and associated equipment. In addition, all the Covanta Niagara CROs are required to obtain, at a minimum, the provisional QRO certification from the American Society of Mechanical Engineers. Several of the CROs have completed the full certification.

The CRO monitors and controls equipment using a state of the art Bailey controls system. From the Bailey control system the CRO can monitor parameters, adjust setpoints on control equipment, and start and stop most equipment associated with the boilers, the air pollution control system, and the facility's auxiliary support equipment. The CRO will also be able to monitor the stack emissions from the continuous emission monitoring system's PC that is in the control room. The CRO will be able to call up screens that will indicate instantaneous parameter concentrations and mass emissions, as well as various averaging mass emissions. The PC will also alarm to warn the CRO if a parameter is approaching a permit limit. The CRO can then take appropriate action to reduce the emission. The CRO has the support of field operators who make reports to the CRO based on field observations. The CRO reports directly to the shift supervisor and completes a daily log book (Attachment 6-3) that is used as a communications tool between the CRO, shift supervisor, and management personnel. Some of the comments that may be included in the CRO's log are:

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

- Plant operation, status - steam production
- Changes in operating procedures
- Unusual events
- Equipment malfunctions - type, time, cause, corrective actions
- Permit excursions - type, time, cause, corrective actions

In addition, the CRO completes equipment status log sheets (Attachment 6-4) for the equipment under his direct control.

### 6.3.3 ASSISTANT CONTROL ROOM OPERATION

The assistant control room operator (ACRO) is responsible for monitoring the operation of boiler support equipment such as the combustion fans, gas burners, refuse feed and ash extractor hydraulics, the boiler water and steam systems including the boiler drum, deaerator, and feed pumps, the turbine generator and generator support equipment and various plant auxiliary equipment including fire protection sanitary sewer, plant air and electrical distribution equipment. The ACRO maintains a log (Attachment 6-5) that indicates the operating status of the equipment he is responsible for.

The ACRO makes reports to the control room operator and the shift supervisor regarding operating of plant equipment, particularly noting any discrepancies in the operation of any plant components. The ACRO is usually, but not in all cases, a qualified control room operator and relieves the control room operator as needed during the shift operation. The Covanta Niagara CROs are required to obtain the provisional QRO certification.

### 6.3.4 BACKEND OPERATOR

The backend operators (BEO) are responsible for monitoring the operation of the environmental controls equipment including the Urea injection (DENOX) system, the lime slaking system, the acid gas removal scrubber, the reverse air fabric filter baghouse, and the flyash conveyance system up to the ash processing building. Like the CRO and ACRO, the BEO maintains a log (Attachment 6-6) that indicates the operating status of the air pollution control equipment and auxiliary support equipment. The backend operator makes reports directly to the CRO and the shift supervisor.

The backend operator has the ability to control the operation of most of the environmental equipment, however, under normal operating conditions, the equipment is placed into service and the controls transferred to the CRO or field operated programmable logic controllers which control equipment to maintain plant parameters within desired specifications. If the CRO receives an alarm on the control room



Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

personnel computer screen, the BEO is immediately notified to inspect the equipment to determine if there is an equipment malfunction.

### **6.3.5 REFUSE CRANE OPERATOR**

The refuse crane operators operate two 14 cubic yard electro-hydraulic operated orange peel grapples that are used to mix and stockpile the solid waste in the refuse bunker and to lift the solid waste into the furnace's refuse feed hoppers.

Using the cranes, the refuse crane operator maintains an empty trench area in the refuse bunker in front of the truck bays so that the refuse truck flow can continue uninterrupted. The refuse crane operator is responsible for feeding both refuse feed hoppers which must have an adequate amount of refuse at all times to ensure a constant supply of refuse to the furnace and to maintain the air seal on the furnace. Because of the responsibility to maintain adequate MSW feed to the furnaces, the refuse crane operator reports directly to the control room operator.

The refuse crane operator makes periodic inspections of the refuse cranes to check for any deficiencies in the crane, bridge and trolley equipment. The refuse crane operators also perform periodic preventative maintenance on the cranes, such as greasing the equipment etc. Like the other operators, the refuse crane operator maintains a log (Attachment 6-7).

### **6.3.6 TIPPING FLOOR OPERATOR**

The tipping floor operators (TFO) are responsible for managing the unloading of all the trucks (approximately 250 per day) delivering solid waste and alternate fuels to the facility – ensuring that it is done safely and efficiently.

Trucks such as walking floor transport trailers and dump trailers are positioned to unload their solid waste directly into the refuse bunker, while the small curb side packers and front end loaders unload onto the tipping floor in front of the refuse bunker. A payloader is then used to push that waste into the refuse bunker. Trucks delivering alternate fuels are positioned for unloading at the alternate fuels' tipping floor hole. Nonhazardous industrial waste that is transported to the facility in van trailers is normally palletized in those trailers. The TFO use a forklift to remove the pallets from the van and then use a payloader to push the palletized waste into the refuse bunker.

In addition the TFO do inspections of the incoming waste loads. A minimum of two (2) solid waste delivery trucks are inspected each day, while nearly all the van trailer loads

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

are inspected. With the solid waste loads the TFO is observing for unacceptable (tree trunks, large pieces of steel, concrete, etc.) and hazardous wastes.

The TFO have no daily logs to maintain.

### **6.3.7 FERROUS/NONFERROUS OPERATOR**

The ferrous/nonferrous operators are responsible for operating and monitoring the ash processing equipment including the ferrous and nonferrous recovery systems, the flyash conditioning system, and the ash loadout system. The ash processing/loadout and ferrous metal recovery system are continuous operations, whereas the nonferrous metal recovery is a batch process operated 5 days (Monday thru Friday) per week, eight (8) hours per day.

During the day shift, both a ferrous and nonferrous operator monitor and operate the equipment. On the night shift and weekends there is only a ferrous operator assigned to work. The ferrous operator is primarily responsible for the ferrous recovery and ash loadout process, while the nonferrous operator is primarily responsible for the nonferrous metal recovery system. The logs maintained by both operators are shown in Attachment 6-8.

### **6.3.8 WATER TENDER**

Water used in the Covanta Niagara DBA boilers is from the Niagara River. Because of the high pressure steam produced in the boilers, the boiler feed water must be of very high quality and contain essentially no minerals. Covanta Niagara has an extensive water treatment process that the water tender must operate. The process includes:

- lime softening
- clarification
- mixed media filtration
- cation ion exchange
- anion exchange
- condensate return system
- mixed cation/anion exchange (polishers)
- chemical addition to the boiler feed water

The Covanta Niagara water tender is also responsible for facility's cooling tower system as well as several auxiliary systems such as

- bulk chemical unloading and storage

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

- sanitary sewer discharge system
- cooling tower chemical feed system

The water tender monitors the various systems through boiler and cooling tower water chemistry sampling/analyses. Many of the parameters have operating range limits, which, if outside the range, require the water tender to take corrective actions. Corrective actions may include regenerating the ion exchange resin, modifying the chemical addition rate, etc.

The water tender documents the inspections and testings on the water tender log (Attachment 6-9). The water tender reports directly to the shift supervisor and operations manager regarding the operation of the water treatment process and physical condition of the equipment.

### **6.3.9 ALTERNATE FUELS OPERATOR**

The alternate fuels (Alt Fuels) operators are responsible for the operation of the alternate fuel (waste wood, photographic paper and film) shredding system and associated equipment. The associated equipment includes the multirams that push the alternate fuels into the shredders, the conveyors that transport the alternate fuels to the "C" building storage area, and the magnet that removes ferrous metal from the alternate fuel. In addition the Alt Fuels operators are responsible for assisting the CRO in the operation and monitoring of the Alt Fuels fire boiler. The Alt Fuels boiler operates primarily in October through March and then on an as needed basis the remainder of the year. The Alt Fuels operators are responsible for operating the alternate fuels feed system, the lime injection system, the grate system, and the ash handling system.

The Alt Fuels operators report directly to the shift supervisor, but also take direction from the CRO. Two (2) logs are shown in Attachment 6-10. One is maintained while the Alt Fuels boiler is on line and the other is maintained while the Alts Fuels boiler is offline.

- Prestart checklist
- Day operator checklist
- Emission log
- Ash level checklist
- Parascrew/ash tender log
- Grates/surge bin log
- Lime usage log

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

### 6.3.10 LIQUID WASTE OPERATOR

The liquid waste operator (LWO) is responsible for the operation of the liquid waste injection system. The LWO unloads the tank trucks, delivering the liquid waste, into the storage tanks. The LWO operates the pumps and maintains the strainers and injection nozzles. The log maintained by the LWO is shown in Attachment 6-11.

### 6.3.11 RTIF LEAD OPERATOR

The RTIF Lead Operator reports to the RTIF Superintendent will be located at, and have dedicated responsibility for the safe, efficient, and reliable functioning of the RTIF. The RTIF Lead Operator will manage and direct the daily operational activities of the RTIF on behalf of and at the direction of the RTIF Superintendent through direct supervision of members of the Operating Group. The RTIF Lead Operator, or his designee, will act as the Certified Track Inspector at the RTIF. The log maintained by the RTIF Lead Operator is shown in Attachment 6-13 (TO BE PROVIDED).

### 6.3.12 CONTAINER HANDLER OPERATOR

The RTIF operator is responsible for the operation of RTIF loading and unloading of intermodal containers. The RTIF operation's logs will include data captured by the RFID system for the operation of the RTIF. The data fields required (but not limited to) are as follows:

Railcar ID  
Railcar Location  
Railcar Estimated Arrival Date  
Railcar Estimated Arrival Time  
Railcar Actual Arrival Date  
Railcar Actual Arrival Time  
Railcar Estimated Departure Date  
Railcar Estimated Departure Time  
Railcar Actual Departure Date  
Railcar Actual Departure Time  
Railcar Origin  
Railcar Destination  
Container Number  
Inbound Date  
Inbound Time  
Outbound Date  
Outbound Time  
Gross Weight

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

Tare Weight  
Net Weight  
Radiation Reading  
Maintenance/Inspection Date  
Maintenance/Inspection Performed  
Destination

Example log(s) will be included in Section 6-4 when available.

#### **6.4 OPERATION MONITORING LOGS**

Operation of the facility is monitored continuously by operations personnel and documented through the use of watchstation logs and computer generated printouts.

The logs provide the primary mechanism to ensure that the plant's equipment is in proper running condition. Equipment that is operating outside of the normal ranges can either be identified by operator inspections or from alarm set points in the Bailey control system.

The continuous emission monitoring system (CEMS) continuously samples and analyzes the stack gas. The CEMS' data acquisition system takes the monitors outputs, makes calculations, as necessary, and compares the monitor's outputs with permit limitations. When an out-of-range value occurs, the alarm function alerts the control room operator of the out-of-range value via the control room's CEMS' personnel computer's alarm function. Corrective actions would then be taken.

In addition to the alarm functions, each shift is independently evaluated for process upsets and excess emissions that occurred during that particular shift. The CEMS has the ability to provide reports on demand and automatically prints shift specific reports. The Bailey provides graphs of the combustion and steam conditions for each shift. These system printouts are then reviewed each shift and the operators held accountable for performance - both acceptable as well as unacceptable.

#### **6.5 OPERATIONS GROUP CHEMICAL/FUEL OIL STORAGE INSPECTIONS**

The operations group is responsible for completing monthly inspections of the chemical and fuel storage tanks. The technician, usually the water tender, inspects the tanks and secondary containment dikes and then indicates the findings on the inspection sheet (example shown in Attachment 6-12). The tank/secondary containment inspections are kept on file. Any noted deficiencies are corrected.

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## 6.6 OPERATIONS GROUP PERIODIC EQUIPMENT INSPECTIONS

In addition to logs that are kept by operations personnel, various pieces of equipment are inspected on a weekly or monthly basis. For example, installed spare pumps and compressors are on a weekly rotation check sheet. The pumps, compressors, etc. are started up and operated for several hours to ensure that they are functioning properly and will be ready, if needed. During these weekly or monthly inspections lubrication is done, drive belts are inspected, inventory of consumables is done, etc. The operations group is also responsible for periodic inspections of safety equipment (i.e. fire extinguishers, scott air paks, etc. The operation's Equipment Inspection Schedule is shown in Attachment 6-13.

## 6.7 MAJOR REVISIONS TO THE OPERATIONS AND FACILITY INSPECTION PLAN

### February 2006

Name changed to Covanta from American Ref-Fuel Company.

### March 2008

Operations logs updated to current logs.

### March 2011

Several operations' logs updated to current logs.

### March 2012

Several operations' logs updated to current logs.

### May 2013

Several operations' logs updated to current logs.

### November 2013

Language added to direct personnel to submit any inspections conducted as a result of EMIS to the plant environmental engineer.



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

March 2014

Updated to include RTIF operation

April 2014

Change employee title in section 6.3.11.

May 2014

Addition of RTIF Lead Operator's Log.



**COVANTA NIAGARA**  
**O&M Manual/ECOM**

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

# **ATTACHMENT 6-1**

## **PRODUCTION REPORT**



# Covanta Niagara Production Report

1/19/2014 04:59:00 AM				HILLMAN/JOSEPH				1/19/2014 04:59:00 PM											
<b>STEAM PRODUCTION</b>				<b>GAS</b>				<b>STEAM PRODUCTION</b>				<b>GAS</b>							
Boiler 1	1656	klbs	138	avg/klb	NFG North	0	mscf			Boiler 1	1416	klb	118	avg/klb	NFG North	0	mscf		
Boiler 2	0	klbs	0	avg/klb	NFG Center	0	mscf			Boiler 2	0	klb	0	avg/klb	NFG Center	0	mscf		
Boiler 3	3648	klbs	304	avg/klb	NFG South	0	mscf			Boiler 3	3648	klb	304	avg/klb	NFG South	0	mscf		
Boiler 4	3584	klbs	299	avg/klb	Total Gas	0	mscf			Boiler 4	3840	klb	320	avg/klb	Total Gas	0	mscf		
DBA Warm Up Vent	20	klbs	2	avg/klb	Warm up Gas	0	mscf			DBA Warm Up Vent	49	klb	4	avg/klb	Warm up Gas	0	mscf		
Total Steam	8908	klbs	742	avg/klb						Total Steam	8953	klb	746	avg/klb					
<b>POWER</b>				<b>MSW</b>				<b>POWER</b>				<b>MSW</b>							
Gross Power	3520	mwh	293	avgmw	MSW Received	0	tons			Gross Power	3680	mwh	307	avgmw	MSW Received	0	tons		
Net Power	9792	mwh	816	avgmw	MSW processed (calc)	1113	tons			Net Power	9792	mwh	816	avgmw	MSW Processed (calc)	1152	tons		
Internal Power	-6272	mwh	-523	avgmw	Ferrous Shipped	0	tons			Internal Power	-6112	mwh	-509	avgmw	Ferrous Shipped	0	tons		
Turbine 1 Condensate	125	klb	10	avg/klb	Non-ferrous Shipped	0	tons			Turbine 1 Condensate	188	klbs	16	avg/klb	Non-ferrous Shipped	0	tons		
Turbine 2 Condensate	438	klb	36	avg/klb						Turbine 2 Condensate	625	klbs	52	avg/klb					
<b>EXPORTED STEAM</b>				<b>WATER TREATMENT</b>				<b>EXPORTED STEAM</b>				<b>WATER TREATMENT</b>							
HCPC Steam	2984	klbs	249	avg/klb	Make-up Water	462000	gal			HCPC Steam	2566	klbs	214	avg/klb	Make-up Water	462000	gal		
Praxair Steam	846	klbs	71	avg/klb	Sanitary Sewer Flow	675000	gpm			Praxair Steam	837	klbs	70	avg/klb	Sanitary Sewer Flow	675000	gpm		
Aux Steam	0	klbs	0	avg/klb	pH < 5 time	0	min			Aux Steam	0	klbs	0	avg/klb	pH < 5 time	0	min		
180Psi Vented steam	0.0	klbs	0	avg/klb	pH > 10 time	0	min			180Psi Vented steam	0.0	klbs	0	avg/klb	pH > 10 time	0	min		
<b>NATURAL GAS</b>				<b>LIME</b>				<b>NATURAL GAS</b>				<b>LIME</b>							
#1 Blr StartUpGas	0	mscf			Lime Silo 1 level	25	%			#1 Blr StartUpGas	0	mscf			Lime Silo 1 level	22	%		
#1 Blr Env Gas	2696	mscf			Lime Silo 2 level	13	%			#1 Blr Env Gas	2328	mscf			Lime Silo 2 level	11	%		
#2 Blr Env Gas	0	mscf			Lime Received	0	tons			#2 Blr Env Gas	0	mscf			Lime Received	0	tons		
#2 Blr StartUp Gas	0	mscf			#3 Blr lime used	15.62	klbs			#2 Blr StartUp Gas	0	mscf			#3 Blr lime used	18.75	klbs		
#3 Blr Env Gas	472	mscf			#3 Blr slurry avg	0.00	gpm			#3 Blr Env Gas	82	mscf			#3 Blr slurry avg	0.00	gpm		
#3 Blr Start-Up Gas	0	mscf			#4 Blr lime used	18.75	klbs			#3 Blr Start-Up Gas	0	mscf			#4 Blr lime used	18.75	klbs		
#4 Blr Env Gas	380	mscf			#4 Blr slurry avg	0.00	gpm			#4 Blr Env Gas	24	mscf			#4 Blr slurry avg	0.00	gpm		
#4 Blr Start-Up Gas	0	mscf			Total Lime	34.37	klbs			#4 Blr Start-Up Gas	0	mscf			Total Lime	37.50	klbs		
<b>MISC</b>				<b>DENOX</b>				<b>MISC</b>				<b>DENOX</b>							
Turbine 1 hrs	12	hrs			Denox tank	42.43	%			Turbine 1 hrs	12	hrs			Denox tank	71.96	%		
Turbine 2 hrs	12	hrs			Denox Received	0.00	gal			Turbine 2 hrs	12	hrs			Denox Received	0.00	gal		
Shredder 1 hrs	0	hrs			#3 Blr chem flow	0.00	avg gal/hr			Shredder 1 hrs	0	hrs			#3 Blr chem flow	0.00	avg gal/hr		
Shredder 2 hrs	0	hrs			#4 Blr chem flow	0.00	avg gal/hr			Shredder 2 hrs	0	hrs			#4 Blr chem flow	0.00	avg gal/hr		
Shredder3 hrs	0	hrs			#3 Blr Nox	0.00	avg ppm			Shredder3 hrs	0	hrs			#3 Blr Nox	0.00	avg ppm		
					#4 Blr Nox	0.00	avg ppm								#4 Blr Nox	0.00	avg ppm		
					Total Denox	0.00	gal								Total Denox	0.00	gal		
<b>COMMENTS</b>				<b>ALTERNATIVE FUEL</b>				<b>COMMENTS</b>				<b>ALTERNATIVE FUEL</b>							
ALL CUSTOMERS PULLING TO THE MAX!!!!				Total Steam	0	klbs			ALL CUSTOMERS PULLING TO THE MAX!!!!				Total Steam	0	klbs				
<b>WEATHER</b>				Wood Received	0	tons			<b>WEATHER</b>				Wood Received	0	tons				
NICE				Wood Burned	0	tons			NICE				Wood Burned	0	tons				
					Gas used									Gas used					
					Total Fly Ash	0.00	tons								Total Fly Ash	0.00	tons		

## DAILY TOTALS

#1 Blr on Line			Boiler 1			ALTERNATIVE FUEL			INTEGRATORS		
#1 Blr on Line	24	hrs	Boiler 1	3072	klbs	Total Steam	0	Klbs	Boiler 1	306168	
#2 Blr on Line	0	hrs	Boiler 2	0	klbs	Net Power			Boiler 2	17105	
#3 Blr on Line	24	hrs	Boiler 3	7296	klbs	Wood Received	0	tons	NFG North	647616	
#4 Blr on Line	24	hrs	Boiler 4	7424	klbs	Wood Burned	0		NFG Center	1	
Turbine 1	24	hrs	DBA Warm up Vent	69	klbs	Gas used			NFG South	107812	
Turbine 2	24	hrs	Total Vented Steam	0.0	klbs	Internal Power			Boiler 3	4152128	
Shredder 1	0	hrs	Gross Power	7200	mw	ash			Boiler 4	5534336	
Shredder 2	0	hrs	Net Power	19584	mw	Lime			TG1 COND	525812	
Shredder 3	0	hrs	Internal Power	-12384	mw	Peak power			TG2 COND	737124	
<b>Total Gas(pay Meters)</b>	<b>26560</b>	<b>mscf</b>	<b>Total Steam to Turbine</b>	<b>17723</b>	<b>klbs</b>	Off Peak power			HCPC	42242900	
			<b>Total Steam</b>	<b>17792</b>	<b>klbs</b>	TG low press power			PRAX	15104478	
			Lime Rate	1.59	%	Vented power			AUX	10946027	
			Total MSW Rec'd	0	tons				NMP4	573024	
			Total MSW processed	2264.6	tons				brkr130	400032	
			<b>Inventory</b>	<b>4735</b>	<b>tons</b>				brkr180	326240	







3/19/2013



#1 BOILER

#2 BOILER

	Avg	Std Dev %	Max	Min			Avg	Std Dev %	Max	Min		
Steam Flow	18.009	#B1910!	0.00	0.00	Kpph		Steam	0.00	0.00	180062	00007	Kpph
Steam Flow SP	0.00	0.00	0.00	0.00	Kpph		Steam	0.00	0.00	0.00	0.00	Kpph
Feedwater Flow	0.00	0.00	0.00	0.00	Klb/hr		Feedw	0.00	0.00	0.00	0.00	Klb/hr
Furnace Draft	0.00	0.00	0.00	0.00	inwc		Furna	0.00	0.00	0.00	0.00	inwc
ID Fan %	0.00	0.00	0.00	0.00	%		ID Fan	0.00	0.00	0.00	0.00	%



3/13/2013		#1 BOILER				#2 BOILER					
	Avg	Std Dev %	Max	Min		Avg	Std Dev %	Max	Min		
Steam Flow	#DIV/0!	#DIV/0!	0.00	0.00	Kpph	Steam	#DIV/0!	#DIV/0!	0.00	0.00	Kpph
Steam Flow SP	0.00	0.00	0.00	0.00	Kpph	Steam	0.00	0.00	0.00	0.00	Kpph
Feedwater Flow	0.00	0.00	0.00	0.00	Klb/hr	Feedw	0.00	0.00	0.00	0.00	Klb/hr
Furnace Draft	0.00	0.00	0.00	0.00	inwc	Furna	0.00	0.00	0.00	0.00	inwc
ID Fan %	0.00	0.00	0.00	0.00	%	ID Fan	0.00	0.00	0.00	0.00	%





1/19/2014

### #3 BOILER

### #4 BOILER

	Avg	Std Dev %	Max	Min	
Steam Flow	306.70	1.36	339.51	243.35	Kpph
Steam Flow SP	314.66	0.70	315.00	299.00	Kpph
Feedwater Flow	319.19	11.05	392.60	176.93	klb/hr
PA Flow	63.59	12.91	79.17	31.11	Kscfm
SA Flow	21.99	53.85	49.71	0.00	Kscfm
Total Air Flow	85.58	33.38	128.88	31.11	Kscfm
Furnace Draft	-0.30	-71.66	0.35	-1.35	inwc
ID Fan %	62.98	19.49	98.33	33.93	%
Ram Feeder	32.96	58.32	100.00	0.00	%
O2 Blr Out	4.75	23.11	21.00	2.21	%
ID Fan O2	7.68	16.37	20.74	2.06	%
CO ID Fan	5.02	130.11	166.03	0.95	ppm
Blr Out Press	-4.52	-7.67	-3.16	-5.58	inwc
Blr Out Temp	562.90	1.72	590.91	542.44	degF
Trash Factor	3.74	4.62	4.00	3.60	u

	Avg	Std Dev %	Max	Min	
Steam Flow	308.03	1.19	335.35	260.83	Kpph
Steam Flow SP	314.35	0.87	315.00	300.00	Kpph
Feedwater Flow	328.81	4.36	387.22	247.62	klb/hr
PA Flow	68.23	12.60	84.20	32.80	Kscfm
SA Flow	13.83	66.54	35.18	0.00	Kscfm
Total Air Flow	82.06	39.57	119.38	32.80	Kscfm
Furnace Draft	-0.22	-97.70	0.52	-0.99	inwc
ID Fan %	78.59	16.18	91.97	40.60	%
Ram Feeder	35.91	46.23	99.96	0.66	%
O2 Blr Out	5.01	18.22	20.71	1.87	%
ID Fan O2	7.11	18.05	21.20	2.06	%
CO ID Fan	5.83	129.77	231.79	2.59	ppm
Blr Out Press	-2.72	-9.27	-1.75	-3.43	inwc
Blr Out Temp	550.47	2.06	574.39	521.83	degF
Trash Factor	3.58	6.95	4.00	3.40	u





Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## ATTACHMENT 6-2

### SHIFT SUPERVISOR'S LOG



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA, L.P.  
SHIFT SUPERVISOR LOG

Doc. OL-9	Rev.22 No.
Date:3/12/2013	

PLANT / EQUIPMENT STATUS			
SAFETY / ENVIRONMENTAL TAILGATE ISSUES			
EQUIPMENT OUT OF COMMISSION			
LIMITED USE EQUIPMENT			
MAINTENANCE PERFORMED			
WORK ORDER ISSUES	EOS TANK LEVELS		
	#1 SILO _____%		
	#2 SILO _____%		
	CARBON _____ft		
	UREA _____%		
	Power Forecast __ MW		
TURNOVER ISSUES			
AIR MONITOR CAL. DATE: NF10 _____ NF11 _____ NF12 _____			
Ferrous Down Time =	Non Ferrous Down Time =		
N-pac Daily Numbers Sent	Initial:	Covanta Daily Report Sent	Initial:

R:\ENV\ISO 14001 ENVIRONMENTAL MANAGEMENT SYSTEMS\OPERATION'S LOGS\SHIFT SUP LOGBOOK

OFF GOING QRO SUPV \_\_\_\_\_ ONCOMING QRO SUPV \_\_\_\_\_





Powering Today. Protecting Tomorrow.

COVANTA NIAGARA, L.P.  
SHIFT SUPERVISOR LOG

Doc. OL-9	Rev.22 No.
Date:3/12/2013	

### NIAGARA SHIFT SUPERVISOR'S LOG

DATE: \_\_\_\_\_ SHIFT: \_\_\_\_\_ NAME: \_\_\_\_\_

**END OF SHIFT STATUS:**

**STEAM: Shift Averages**

Load: Blr. #3 _____ kpph	Blr #4 _____ kpph	Blr #2 _____ kpph
O <sub>2</sub> : Blr. #3 _____ %	Blr #4 _____ %	Blr #1 _____ kpph
Wtr/Stm Deviation _____ kpph	Wtr/Stm Deviation _____ kpph	

**Comments:**

**TG's:** LSPC @ \_\_\_\_\_ on 1 / 2 Ext Stpt \_\_\_\_\_ psi      1 / 2 TG Inlet Vlv Pos \_\_\_\_\_ % Ext Stpt \_\_\_\_\_ psi

**Electric Lineup:**

	140	150	170	
<b>Closed: /</b>	52A	52T	52B	
<b>Open: O</b>	1000	100/200	1400	100/200
	1200	100/200	1600	100/200

**Steam Sales**

Oxy Hdr Press Excursions: Y / N  
Lowest Pressure \_\_\_\_\_ # Time below 150 # \_\_\_\_\_

**SHORTFALLS**

GreenPac---Y / N    OXY ---- Y / N    Norampac ---- Y / N

**Equipment Last Cleaned**

#3 Blr Furnace _____ On / Off-Line	#4 Blr Furnace _____ On / Off-Line
#3 PA Fan _____	#4 PA Fan _____
#3 Ash Extractor _____ On / Off-Line	#4 Ash Extractor _____ On / Off-Line
#3 Blr 3 <sup>rd</sup> Pass _____ On / Off-Line	#4 Blr 3 <sup>rd</sup> Pass _____ On / Off-Line

**Crane Status:**

North Crane: In Use / Avail / OOC-Grapple 935 / 1329 / 1425 / 1214  
South Crane: In Use / Avail / OOC-Grapple 935 / 1329 / 1425 / 1214  
Spare: Grapple 935 / 1329 / 1425 / 1214 Avail / OOC Deck: N / S

**Significant Problems/Events:**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Log Review Complete Reviews:	<u>CRO</u>	<u>ACRO</u>	<u>BE</u>	<u>ALO</u>	<u>ALT FUEL</u>	<u>CRANE</u>	<u>LW</u>	Weekend/Holiday CEMS Cal	Initial:
	Breniser	Thiel	Kemsley	Joseph	Curry				



COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## ATTACHMENT 6-3

### CONTROL ROOM OPERATOR'S LOGBOOK





Powering Today. Protecting Tomorrow.

COVANTA NIAGARA, L.P.
OPERATIONS LOGS
CONTROL ROOM OPERATOR LOG BOOK

Table with 2 columns: Doc. OL-7, Rev. 10 No. and Date: 3/12/14

PLANT / EQUIPMENT STATUS
EQUIPMENT LINEUP at SHIFT START
North Crane I/S O/S Slaker I/S 1 / 2 Alt Fuels Y/N #3 AE Delay on / off
South Crane I/S O/S EFW Pac I/S 1 / 2 Ferrous Y/N #4 AE Delay on / off
East Slipstick I/S O/S DBA Pac I/S A / B Non-Ferrous Y/N
West Slipstick I/S O/S FWP's I/S 1 / 2 / 3 Receiving Condensate Y / N Flow
Furnace Temp Exemption in Effect: #3 Y / N Date Cleaned: #4 Y / N Date Cleaned:
TEST: Electric Panel Breaker Indicating Lights Sat / Unsat All Panel Annunciator Lights Sat / Unsat
All Boiler Cameras operating properly Sat / Unsat BgHs Cleaning- #3 BgHs Y/N #4 BgHs Y/N
PCU STATUS on i90 screen-note errors here : TEST CRO Control of BgHs inlets SAT /Unsat
EQUIPMENT OUT OF COMMISSION (restart Auto clean)
LIMITED USE EQUIPMENT / JUMPER INSTALLED
STEAM CUSTOMER CUTS/HEADER EXCURSIONS
TIME Customer Order Rate Cut To Time Stm Restored Lowest Press
TURNOVER ISSUES

OFF GOING CRO ONCOMING CRO
R:\ENVISO 14001 ENVIRONMENTAL MANAGEMENT SYSTEMS\OPERATION'S LOGS\CONTROL LOGBOOK



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## ATTACHMENT 6-4

### CONTROL ROOM OPERATOR'S LOG



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
CONTROL ROOM OPERATOR LOG**

Doc. OL-6	Rev. 12 No.
Date: 3/12/14	

Current Date: \_\_\_\_\_

BOILER NUMBER 3 OPERATING CONDITIONS							
DESCRIPTION	PARAMETER	0400	0800	1200	1600	2000	0000
STEAM FLOW (citect)	KLB/HR						
STEAM FLOW SET POINT	KLB/HR						
FURNACE OXYGEN	% V wet						
PRIMARY AIR FLOW	KSCFM						
SECONDARY AIR FLOW	KSCFM						
RAM FEEDER SPEED	%						
TRASH FACTOR	1 - 5						
FURNACE DRAFT	-.4" H2O						
FEEDWATER FLOW	KLB/HR						
DRUM LEVEL NORTH	INCHES						
DRUM LEVEL SOUTH	INCHES						
DRUM PRESSURE	PSIG						
STEAM OUTLET PRESSURE	1250 PSIG						
STEAM OUTLET TEMP.	750 ° F						
FIRST PASS TEMP.	>1800 ° F						
SDA OUTLET TEMP	341 ° F						
SDA SLURRY FLOWRATE	GPM						
FABRIC FILER D/P	4-7" H2O						
BURNERS IN YES/NO		Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
ID FAN VIBES INBRD	< 13.0 MILS						
ID FAN VIBES OUTBRD	< 13.0 MILS						
ID FAN BRNG TEMP INBRD	< 195°F TRIP						
ID FAN BRNG TEMP OUTBRD	< 195°F TRIP						
AVG STM/FEED FLOW DEVIATION	0						
Stack Oxygen (O2)	%						

R:\ENVISO 14001 ENVIRONMENTAL MANAGEMENT SYSTEMS\OPERATION'S LOGS\CRO LOG



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
CONTROL ROOM OPERATOR LOG**

Doc. OL-6	Rev. 12 No.
Date: 3/12/14	

Current Date: \_\_\_\_\_

<b>BOILER NUMBER 4 OPERATING CONDITIONS</b>							
<b>DESCRIPTION</b>	<b>PARAMETER</b>	<b>0400</b>	<b>0800</b>	<b>1200</b>	<b>1600</b>	<b>2000</b>	<b>0000</b>
STEAM FLOW (citect)	KLB/HR						
STEAM FLOW SET POINT	KLB/HR						
FURNACE OXYGEN	% V wet						
PRIMARY AIR FLOW	KSCFM						
SECONDARY AIR FLOW	KSCFM						
RAM FEEDER SPEED	%						
TRASH FACTOR	1 - 5						
FURNACE DRAFT	-.4" H2O						
FEEDWATER FLOW	KLB/HR						
DRUM LEVEL NORTH	INCHES						
DRUM LEVEL SOUTH	INCHES						
DRUM PRESSURE	PSIG						
STEAM OUTLET PRESSURE	1250 PSIG						
STEAM OUTLET TEMP.	750 ° F						
FIRST PASS TEMP.	>1800 ° F						
SDA OUTLET TEMP	346 ° F						
SDA SLURRY FLOWRATE	GPM						
FABRIC FILER D/P	4-7" H2O						
BURNERS IN YES/NO		Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
ID FAN VIBES INBRD	< 13.0 MILS						
ID FAN VIBES OUTBRD	< 13.0 MILS						
ID FAN BRNG TEMP INBRD	< 195°F TRIP						
ID FAN BRNG TEMP OUTBRD	< 195°F TRIP						
AVG STM/FEED FLOW DEVIATION	0						
Stack Oxygen (O2)	%						

R:\ENVIISO 14001 ENVIRONMENTAL MANAGEMENT SYSTEMS\OPERATION'S LOGS\CRO LOG



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
CONTROL ROOM OPERATOR LOG**

Doc. OL-6	Rev. 12 No.
Date: 3/12/14	

Current Date: \_\_\_\_\_

BOILER NUMBER 3 CEMS							
DESCRIPTION	PARAMETER	0400	0800	1200	1600	2000	0000
BAGHOUSE PRESSURE DROP	<"H2O						
SDA TEMP (4 hr block avg)	< 341 ° F						
STEAM FLOW (4hr block avg)	<340 kpph						
SO2 ppmc (60min)	< 29 ppmc						
SO2 ppmc (24hr avg)	< 29 ppmc	>>>>>>	>>>>>>	>>>>>>	>>>>>>	>>>>>>	
SO2 LBS/HR (60min)	< 104.4 lbs/hr						
SO2 LBS/HR (3hr roll avg)	< 104.4 lbs/hr						
NOx ppmc (60 min)	< 150 ppmc						
NOx ppmc (24 hr avg)	< 150 ppmc	>>>>>>	>>>>>>	>>>>>>	>>>>>>	>>>>>>	
CO ppmc (60min)	< 100 ppmc						
CO ppmc (4 hr block avg)	< 100 ppmc						
OPACITY (6 min)	< 10%						
FURNACE TEMP (30 min roll)	> 1800 ° F						
BOILER NUMBER 4 CEMS							
BAGHOUSE PRESSURE DROP	<"H2O						
SDA TEMP (4 hr block avg)	< 338 ° F						
STEAM FLOW (4hr block avg)	<346 kpph						
SO2 ppmc (60min)	< 29 ppmc						
SO2 ppmc (24hr avg)	< 29 ppmc	>>>>>>	>>>>>>	>>>>>>	>>>>>>	>>>>>>	
SO2 LBS/HR (60min)	< 104.4 lbs/hr						
SO2 LBS/HR (3hr roll avg)	< 104.4 lbs/hr						
NOx ppmc (60 min)	< 150 ppmc						
NOx ppmc (24 hr avg)	< 150 ppmc	>>>>>>	>>>>>>	>>>>>>	>>>>>>	>>>>>>	
CO ppmc (60min)	< 100 ppmc						
CO ppmc (4 hr block avg)	< 100 ppmc						
OPACITY (6 min)	< 10%						
FURNACE TEMP (30 min roll)	> 1800 ° F						

R:\ENVI50 14001 ENVIRONMENTAL MANAGEMENT SYSTEMS\OPERATION'S LOGS\CRO LOG





Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
CONTROL ROOM OPERATOR LOG**

Doc. OL-6	Rev. 12 No.
Date: 3/12/14	

Current Date: \_\_\_\_\_

NUMBER 1 BOILER CONTROL ROOM LOG								
DESCRIPTION	Units	0400		0800	1600		2000	Limits
Main Steam Flow	kpph							280
Main Steam Temp.	deg F							700-720
Desuperheater Valve Loading	%							
Windbox Air Flow	in. WC							
Total Air Flow	in. WC							
Undergrate Air Flow	in. WC							
Undergrate Controller Setting	%	/		/	/		/	
Overfire Air Flow	in. WC							
Overfire Air Fan Controller Setting	%							
ID Fan Motor Current	Amps							
FD Fan Motor Current	Amps							
OFA Fan Motor Current	Amps							
ID Damper Loading	%							
Air Heater Air Inlet Temp (1)	deg F							
Air Heater Air Outlet Temp (2)	deg F							
Highest Grate Temp/punch # (8-28)	deg F	/		/	/		/	< 450 F
Highest Grate Brng Temp. (30-32)	deg F							
Superheater Inlet Temp (cont)	deg F							<1600 F
Boiler Outlet Temperature (7)	deg F							<900F
Air Heater Gas Inlet Temp. (3)	deg F							
Air Heater Gas Outlet Temp. (4)	deg F							
FD Fan Discharge Pressure	in. WC							
Air Heater Air Inlet Pressure	in. WC							
Air Heater Outlet Pressure	in. WC							
Left Side Stoker Pressure	in. WC							
Right Side Stoker Pressure	in. WC							
Furnace Draft Pressure	in. WC							
Superheater Outlet Pressure	in. WC							
Boiler Outlet Pressure	in. WC							
Economizer Outlet Pressure	in. WC							
Precipitator Outlet Pressure	in. WC							
Air Heater Gas Outlet Pressure	in. WC							
ID Fan Outlet Pressure	in. WC							
Stack Gas Pressure	in. WC							
Stack Oxygen (O2)	%							



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
CONTROL ROOM OPERATOR LOG**

Doc. OL-6	Rev. 12 No.
Date: 3/12/14	

Current Date: \_\_\_\_\_

NUMBER 2 BOILER CONTROL ROOM LOG								
DESCRIPTION	Units	0400		0800	1600		2000	Limits
Main Steam Flow	kpph							280
Main Steam Temp.	deg F							700-720
Desuperheater Valve Loading	%							
Windbox Air Flow	in. WC							
Total Air Flow	in. WC							
Undergrate Air Flow	in. WC							
Undergrate Controller Setting	%	/		/	/		/	
Overfire Air Flow	in. WC							
Overfire Air Fan Controller Setting	%							
ID Fan Motor Current	Amps							
FD Fan Motor Current	Amps							
OFA Fan Motor Current	Amps							
ID Damper Loading	%							
FD Damper Position	%							
Air Heater Air Inlet Temp (1)	deg F							
Air Heater Air Outlet Temp (2)	deg F							
Highest Grate Temp. & punch # (8-28)	deg F	/		/	/		/	<500 F
Superheater Inlet Temperature (cont)	deg F							<1600 F
Boiler Outlet Temperature (7)	deg F							<900 F
Air Heater Gas Inlet Temp. (3)	deg F							
Air Heater Gas Outlet Temp. (4)	deg F							
FD Fan Discharge Pressure	in. WC							
Air Heater Air Inlet Pressure	in. WC							
Air Heater Outlet Pressure	in. WC							
Left Side Stoker Pressure	in. WC							
Right Side Stoker Pressure	in. WC							
Furnace Draft Pressure	in. WC							
Superheater Outlet Pressure	in. WC							
Boiler Outlet Pressure	in. WC							
Economizer Outlet Pressure	in. WC							
Precipitator Outlet Pressure	in. WC							
Air Heater Gas Outlet Pressure	in. WC							
ID Fan Outlet Pressure	in. WC							
Stack Gas Pressure	in. WC							



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
CONTROL ROOM OPERATOR LOG**

Doc. OL-6	Rev. 12 No.
Date: 3/12/14	

Current Date: \_\_\_\_\_

NUMBER 1 TURBINE-GENERATOR CONTROL ROOM LOG								
DESCRIPTION	Units	0400		0800	1600		2000	Limits
Generator Load	MW							
Generator Voltage	Volts							13.7 KV- 14.0 KV
Excitation Voltage	Volts							
Excitation Current	Amps							
Reactive Power	MVars							+2
Generator Current	Amps							
Turbine Condensate Flow Rate	Kpph							
Turbine Vacuum	In. Hg	/		/	/		/	
Atmospheric Pressure	In. Hg							
Absolute Press. (Atmospheric-Vacuum)	In. Hg							<3

NUMBER 2 TURBINE-GENERATOR CONTROL ROOM LOG								
DESCRIPTION	Units	0400		0800	1600		2000	Limits
Generator Load	MW							
Generator Voltage	Volts							13.7 KV- 14.0KV
Excitation Voltage	Volts							
Excitation Current	Amps							
Reactive Power	MVars							+2
Generator Current	Amps							
Turbine Condensate Flow Rate	Kpph							
Turbine Vacuum	In. Hg	/		/	/		/	
Atmospheric Pressure	In. Hg							
Absolute Press. (Atmospheric-Vacuum)	In. Hg							<3

AUXILIARIES CONTROL ROOM LOG								
DESCRIPTION	Units	0400		0800	1600		2000	Limits
HCPC Temperature	deg.F							370 – 420
HCPC Pressure	psig							180-210
HCPC Flow Rate	kpph							
NORAMPAC Steam Flow	kpph							
Auxiliary Steam Flow Rate	kpph							

SHIFT	OPERATOR
DAY	
NIGHT	/



Powering Today. Protecting Tomorrow.

COVANTA ENERGY NIAGARA  
 OPERATIONS LOGS  
 CONTROL ROOM OPERATOR LOG

Doc. OL-6	Rev. 12 No.
Date: 3/12/14	

Current Date: \_\_\_\_\_

## ALTERNATE FUELS EMISSION LOG

DATE: \_\_\_ / \_\_\_ / \_\_\_

TIME	STEAM FLOW	SO2 1 hr Lb/hr	SO2 3 hr ROLLING AVG	NOX 1 hr Lb/hr	NOX 1 hr lbs/MMBtu	CO 1 hr Lb/hr	CO 4 hr BLOCK AVG	AHGI TEMP
limits	<181KPP H		<30 Lb/hr	<95 Lb/hr	<0.33 lbs/MMBtu		<50 Lb/hr	<400° F
0100								
0200								
0300								
0400								
0500								
0600								
0700								
0800								
0900								
1000								
1100								
1200								
1300								
1400								
1500								
1600								
1700								
1800								
1900								
2000								
2100								
2200								
2300								
0000								

NOx 24 hr avg



Powering Today. Protecting Tomorrow.

COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
CONTROL ROOM OPERATOR LOG

Doc. OL-6	Rev. 12 No.
Date: 3/12/14	

Current Date: \_\_\_\_\_

OPS LOGS \ CRO LOG

**NUMBER 2 BOILER PRECIPITATOR LOG - DAY SHIFT**

	2A1	2A2	2B1	2B2	2C1	2C2	2D1	2D2
Primary Amps								
Primary Voltage								
Field Load (mA)								
A Field Load (KV1)								
B Field Load (KV2)								

**NUMBER 2 BOILER PRECIPITATOR LOG - NIGHT SHIFT**

	2A1	2A2	2B1	2B2	2C1	2C2	2D1	2D2
Primary Amps								
Primary Voltage								
Field Load (mA)								
A Field Load (KV1)								
B Field Load (KV2)								

SHIFT	OPERATOR
DAY	
NIGHT	/



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## ATTACHMENT 6-5

### ASSISTANT CONTROL ROOM OPERATOR'S LOG





Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
ASSISTANT CONTROL ROOM OPERATOR LOG**

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

**ASSISTANT CONTROL ROOM OPERATOR LOG**

Date: \_\_\_\_/\_\_\_\_/\_\_\_\_

720' ELEVATION					
CONDITION	SAT/UNSAT				
BOILER #3 DRUM PRESS.	1275 PSIG				
BOILER #3 (S) DRUM LVL.	3-5 BULLS				
#3 FEEDWATER PRESS.	1275 PSIG				
BOILER #3 (N) DRUM LVL.	3-5 BULLS				
BOILER #4 DRUM PRESS.	1275 PSIG				
BOILER #4 (S) DRUM LVL.	3-5 BULLS				
#4 FEEDWATER PRESS.	1275 PSIG				
BOILER #4(N) DRUM LVL.	3-5 BULLS				
707' ELEVATION					
Check condition of continuous blowdown tank and lineup.					
CONDITION	SAT/UNSAT				
698' ELEVATION					
CONDITION	SAT/UNSAT				
689' ELEVATION					
CONDITION	SAT/UNSAT				
679' ELEVATION					
CONDITION	SAT/UNSAT				
671' ELEVATION					
CONDITION	SAT/UNSAT				
663' ELEVATION					
Check main steam and startup steam lineups, verify proper attemperator station lineups.					
CONDITION	SAT/UNSAT				
652' ELEVATION					
Check condition/lineup of the startup steam valve.					
CONDITION	SAT/UNSAT				
642' ELEVATION					
CONDITION	SAT/UNSAT				
#4 BLR WASTE WATER INJECTION SYSTEM PRESS	PSIG				
REFUSE PIT CONDITIONS ONCE PER SHIFT		FEED AREA _____%FULL_____		FEED AREA _____%FULL_____	
		CONDITIONS (CIRCLE ONE)		CONDITIONS (CIRCLE ONE)	
		WET DRY MIXED		WET DRY MIXED	





Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
ASSISTANT CONTROL ROOM OPERATOR LOG**

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

**ASSISTANT CONTROL ROOM OPERATOR LOG**

Date: \_\_\_\_/\_\_\_\_/\_\_\_\_

632' ELEVATION					
Check general condition of the Ignition Burners / GUARDS					
CONDITION	SAT/UNSAT				
#3 BLR IGN BURNERS cooling fans, running	IN SERVICE	ON / OFF	ON / OFF	ON / OFF	ON / OFF
#4 BLR IGN BURNERS cooling fans, running	IN SERVICE	ON / OFF	ON / OFF	ON / OFF	ON / OFF

\*\*\*\*\*

CHECK A/C UNITS IN EFW / DBA  
NO FREON PRESENT

DAYSHIFT \_\_\_\_\_ NIGHTSHIFT \_\_\_\_\_

UPS ROOM, T/F SHACK, CEMS ROOMS, ETC.

\*\*\*\*\*

DESCRIPTION	PARAMETER	DAY SHIFT ROUND 1	DAY SHIFT ROUND 2	NIGHT SHIFT ROUND 1	NIGHT SHIFT ROUND 2
615' ELEVATION					
Check general condition of the Auxiliary Burners / GUARDS					
CONDITION	SAT/UNSAT				
BLR #3 2ND/3RD DFV'S	SAT/UNSAT				
#3 2ND AIR FAN DAMPER	DAMPER %				
	OIL LEVEL	SAT/UNSAT	SAT/UNSAT	SAT/UNSAT	SAT/UNSAT
BLR #4 2ND/3RD DFV'S	SAT/UNSAT				
#4 2ND AIR FAN DAMPER	DAMPER %				
	OIL LEVEL	SAT/UNSAT	SAT/UNSAT	SAT/UNSAT	SAT/UNSAT
#4 RAM FEEDER TABLE	SAT/UNSAT				
#3 RAM FEEDER TABLE	SAT/UNSAT				
#3 RAM TABLE TIES(TIGHT)	NORTH/SOUTH	/	/	/	/
#4 RAM TABLE TIES(TIGHT)	NORTH/SOUTH	/	/	/	/



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
ASSISTANT CONTROL ROOM OPERATOR LOG**

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

**ASSISTANT CONTROL ROOM OPERATOR LOG**

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

DESCRIPTION	PARAMETER	DAY SHIFT ROUND 1		DAY SHIFT ROUND 2		NIGHT SHIFT ROUND 1		NIGHT SHIFT ROUND 2	
<b>595' ELEVATION</b>									
Check condition of the boiler water/steam sample room									
CONDITION	SAT/UNSAT								
#3 2ND/3RD DIVERTER	AE OR SLIPSTICK								
#4 2ND/3RD DIVERTER	AE OR SLIPSTICK								
ROLLER GRATE INSPECTION		BLR #3	BLR #4	BLR #3	BLR #4	BLR #3	BLR #4	BLR #3	BLR #4
ROLLER GRATE #1	SAT/UNSAT								
ROLLER GRATE #2	SAT/UNSAT								
ROLLER GRATE #3	SAT/UNSAT								
ROLLER GRATE #4	SAT/UNSAT								
ROLLER GRATE #5	SAT/UNSAT								
ROLLER GRATE #6	SAT/UNSAT								
AE HYD. PUMP DISCH	PSIG								
RF HYD. PUMP DISCH	PSIG								
HYD. RESERVOIR LVL									
HYD. RESERVOIR TEMP.	°F								
FILTER CONDITION	SAT/UNSAT								
A/E CYCLE TIME	SEC								
BOTTOM ASH SAFETY LOCKER	SAT/UNSAT	SAT/UNSAT				SAT/UNSAT			
<b>572' ELEVATION</b>									
(IF WW INJ FLOW IS LESS THAN 7 GPM – REMOVE NOZZLES)									
CONDITION	SAT/UNSAT								
BLR #3 WW INJ PUMP AIR PRESS	60-80 PSI								
BLR #3 WW INJ FLOW	> 7 GPM								
BLR #4 WW INJ PUMP AIR PRESS	60-80 PSI								
BLR #4 WW INJ FLOW	> 7 GPM								
DBA RIVER WATER FLOW METER									



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
ASSISTANT CONTROL ROOM OPERATOR LOG**

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

**ASSISTANT CONTROL ROOM OPERATOR LOG**

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

DESCRIPTION	PARAMETER	DAY SHIFT ROUND 1		DAY SHIFT ROUND 2		NIGHT SHIFT ROUND 1		NIGHT SHIFT ROUND 2	
		#3	#4	#3	#4	#3	#4	#3	#4
<b>572' ELEVATION</b>									
<b>BOILER</b>		#3	#4	#3	#4	#3	#4	#3	#4
"A" SIDE SIFTING HOPPERS	SAT/UNSAT								
"A" SIDE SIFTING CONV. Drive Covers in Place	SAT/UNSAT								
ASH EXTRACTOR LVL.	SAT/UNSAT								
ASH EXTRACTOR OPER.	SAT/UNSAT								
GREASE ASH EXTRACTOR (4 SHOTS)	Y / N								
BIFURCATED CHUTE POS.	"A" OR "B"								
SHEARWALL POS.	OPEN/CLOSED								
STROKE SHEARWALL	Y / N								
"B" SIDE SIFTING HOPPERS	SAT/UNSAT								
"B" SIDE SIFTING CONV. Drive Covers in Place	SAT/UNSAT								
PA FAN DAMPER POS.	%								
A/E OVERFLOW BOXES	CLEAR								
		A	B	A	B	A	B	A	B
SECONDARY SUMP PUMP AIR PRESS.	30 PSIG								
GRIT SCREEN FEED PUMP AIR PRESS	15 PSIG								
B/D WATER RECYCLE TANK PUMP DISCH PRESS.	100 PSIG								
		#3	#4	#3	#4	#3	#4	#3	#4
ID FAN OIL LEVEL (MOBILE DTE LIGHT)	SAT/UNSAT								
ID FAN DAMPER POSITION	%								
		DAYS	1ST	DAYS	2ND	NITE	1ST	NITE	2ND
COOLING TOWER BASIN LEVEL	INCHES FROM TOP								
COOLING TOWER WATER VALVED IN/OUT	VALVED IN / OUT								



**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
ASSISTANT CONTROL ROOM OPERATOR LOG**

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

**ASSISTANT CONTROL ROOM OPERATOR LOG**

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

DESCRIPTION	PARAMETER	DAY SHIFT ROUND 1		DAY SHIFT ROUND 2		NIGHT SHIFT ROUND 1		NIGHT SHIFT ROUND 2	
		A	B	A	B	A	B	A	B
<b>PLANT AIR COMPRESSORS</b>									
<b>AIR COMPRESSOR</b>		<b>A</b>	<b>B</b>	<b>A</b>	<b>B</b>	<b>A</b>	<b>B</b>	<b>A</b>	<b>B</b>
AIR TEMP. LP OUT	°C								
AIR TEMP HP OUT	°C								
AIR TEMP HP IN	°C								
OIL TEMP.	°C								
OIL PRESS.	PSIG								
DISCHARGE PRESS	PSIG								
INTERCOOLER PRESS.	PSIG								
FILTER PRESS	H2O								
WATER TEMP COMP.	°C								
WATER TEMP. A.C.	°C								
AIR OUT TEMP OUT	°C								
OIL FILTER DP	PSID								
LOADED TIME	HRS								
INLET COOLING PRESS	PSIG								
INLET COOLING TEMP	F								
OUTLET COOLING PRESS	PSIG								
OIL LEVEL	SAT								
<b>AIR DRYER</b>		<b>A</b>	<b>B</b>	<b>A</b>	<b>B</b>	<b>A</b>	<b>B</b>	<b>A</b>	<b>B</b>
INLET PRESS.	PSIG								
OUTLET PRESS.	PSIG								
LEFT CHAMBER PRESS.	PSIG								
RIGHT CHAMBER PRESS.	PSIG								
CYCLES LEFT TOWER	KHZ								
CYCLES RIGHT TOWER	KHZ								
MOISTURE INDICATOR	WET/DRY								



COVANTA ENERGY NIAGARA  
 OPERATIONS LOGS  
 ASSISTANT CONTROL ROOM OPERATOR LOG

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

## ASSISTANT CONTROL ROOM OPERATOR LOG

Date: \_\_\_\_/\_\_\_\_/\_\_\_\_

### NUMBER 1 TURBINE-GENERATOR LOG

Description	Units	0800		1600	2000		0400	Limits
Turbine Speed	RPM							3600
Turbine Hour Meter	Hours							
Live Steam Pressure Before Main Stop	Psig							1000
Extraction Steam Pressure	psig							200
Control Fluid Pressure	Psig							>1700
Lube Oil Pressure After Filter	Psig							22
HP Wheel Chamber Pressure	psig							
LP Wheel Chamber Pressure	psig							
Eccentricity	Mils							<8
Drain Oil Temp. #1 Bearing Front	Deg F							<158
Drain Oil Temp. #2 Bearing	Deg F							<158
Drain Oil Temp. #3 Bearing	Deg F							<158
Drain Oil Temp. #4 Bearing	Deg F							<158
Drain Oil Temp. #5 Bearing	Deg F							<158
Drain Oil Temp. #1 Bearing Rear	Deg F							<158
Exhaust Steam Temperature	Deg F							<140
Metal Temperature	Deg F							<700
Live Steam Temp. Before Main Stop	Deg F							700 – 720
Live Steam Temp. Before Drain	Deg F							700-720
#1 Bearing V/H Vibration	Mils	/		/	/		/	<3
#2 Bearing V/H Vibration	Mils	/		/	/		/	<3
#3 Bearing V/H Vibration	Mils	/		/	/		/	<3
#4 Bearing V/H Vibration	Mils	/		/	/		/	<3
Shaft position	Mils	/		/	/		/	<16
Casing Expansion	Inches	/		/	/		/	
Accumulator 1 Pressure	psig							1090
Accumulator 2 Pressure	psig							1090
Magnahelic Gauge Reading	Inches							
Generator KWH Meter								
Lube oil Pressure Before Filter	psig							
Lube Oil Filter delta P indicator	rings							
Lube Oil Tank Level (from top of tank)	inches							
Lube Oil Cooler - Oil Inlet Temp.	deg F							



**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
ASSISTANT CONTROL ROOM OPERATOR LOG**

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

**ASSISTANT CONTROL ROOM OPERATOR LOG**

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

Description	Units	0800		1600	2000		0400	Limits
Lube Oil Cooler - Oil Outlet Temp.	deg F							
Lube Oil Cooler – Water Outlet Temp.	deg F							<95
Lube Oil Cooler – Water Inlet Temp.	deg F							100
Control Oil Tank Level								
Control Oil Tank Temperature	deg F							<140
Control Oil Desiccant	color							blue
Regeneration Filter Flow	GPM							.8
Surface Condenser Inlet Water Temp.	deg F							<95 >50
Surface Condenser Outlet Water Temp.	deg F							<110
Surface Condenser Inlet Pressure	psig							33
Surface Condenser delta P	psig							<20
Gen. Air Cooler Inlet Water Temp.	deg F							<95
Gen. Air Cooler N Outlet Water Temp.	deg F							103
Gen. Air Cooler C Outlet Water Temp.	deg F							103
Gen. Air Cooler S Outlet Water Temp.	deg F							103
Hotwell Pump Discharge Pressure	psig							>100
Gland Steam Pressure	In. H <sub>2</sub> O							8
Condensate Pressure Before Eductor	psig							>80
Non-Condensable Flow	pph							<60
<b>DAY SHIFT</b>								
Cooling Tower Fan Speed: North Fan F/S South Fan F/S		Nitrogen Bottle Pressure: _____ (>100psi)						
#1 Turbine Generator Casing Drain Status: Open / Closed								
#2 Turbine Generator Casing Drain Status: Open / Closed								
ULC 1000/1600 protective relay targets and lockout relay supervisory lights clear							SAT / UNSAT	
ULC 1000/1600 ventilation fan I/S O/S								
ULC 1200/1400 protective relay targets and lockout relay supervisory lights clear							SAT / UNSAT	
ULC 1200/1400 ventilation fan I/S O/S								
#1 Turbine Gland Steam Condenser sight glass level							SAT/UNSAT	
#2 Turbine Gland Steam Condenser sight glass level							SAT/UNSAT	
AVR ROOM UPS PANEL note any alarm conditions:							SAT/UNSAT	
COMMENTS:								



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
ASSISTANT CONTROL ROOM OPERATOR LOG**

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

**ASSISTANT CONTROL ROOM OPERATOR LOG**

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

**NUMBER 2 TURBINE-GENERATOR LOG**

Description	Units	0800		1600	2000		0400	Limits
Turbine Speed	RPM							3600
Turbine Hour Meter	Hours							
Live Steam Pressure Before Main Stop	Psig							1000
Extraction Steam Pressure	psig							200
Control Fluid Pressure	Psig							>1700
Lube Oil Pressure After Filter	Psig							22
HP Wheel Chamber Pressure	psig							
LP Wheel Chamber Pressure	psig							
Eccentricity	Mils							<8
Drain Oil Temp. #1 Bearing Front	Deg F							<158
Drain Oil Temp. #2 Bearing	Deg F							<158
Drain Oil Temp. #3 Bearing	Deg F							<158
Drain Oil Temp. #4 Bearing	Deg F							<158
Drain Oil Temp. #5 Bearing	Deg F							<158
Drain Oil Temp. #1 Bearing Rear	Deg F							<158
Exhaust Steam Temperature	Deg F							<140
Metal Temperature	Deg F							<700
Live Steam Temp. Before Main Stop	Deg F							700 – 720
Live Steam Temp. Before Drain	Deg F							700-720
#1 Bearing V/H Vibration	Mils	/		/	/		/	<3
#2 Bearing V/H Vibration	Mils	/		/	/		/	<3
#3 Bearing V/H Vibration	Mils	/		/	/		/	<3
#4 Bearing V/H Vibration	Mils	/		/	/		/	<3
Shaft position	Mils	/		/	/		/	<16
Casing Expansion	Inches	/		/	/		/	
Accumulator 1 Pressure	psig							1090
Accumulator 2 Pressure	psig							1090
Magnahelic Gauge Reading	Inches							
Generator KWH Meter								
Lube oil Pressure Before Filter	psig							
Lube Oil Filter delta P indicator	rings							
Lube Oil Tank Level (from top of tank)	inches							
Lube Oil Cooler - Oil Inlet Temp.	deg F							
Lube Oil Cooler - Oil Outlet Temp.	deg F							

Printed copies are not document controlled.

Refer to "S" drive, ISO 14001 Environmental Management Systems file for latest approved version.



**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
ASSISTANT CONTROL ROOM OPERATOR LOG**

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

**ASSISTANT CONTROL ROOM OPERATOR LOG**

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

Description	Units	0800		1600	2000		0400	Limits
Lube Oil Cooler – Water Outlet Temp.	deg F							<95
Lube Oil Cooler – Water Inlet Temp.	deg F							100
Control Oil Tank Level								
Control Oil Tank Temperature	deg F							<140
Control Oil Desiccant	color							Blue
Regeneration Filter Flow	GPM							.8
Surface Condenser Inlet Water Temp.	deg F							<95 >50
Surface Condenser Outlet Water Temp.	deg F							<110
Surface Condenser Inlet Pressure	psig							33
Surface Condenser delta P	psig							<20
Gen. Air Cooler Inlet Water Temp.	deg F							<95
Gen. Air Cooler N Outlet Water Temp.	deg F							103
Gen. Air Cooler C Outlet Water Temp.	deg F							103
Gen. Air Cooler S Outlet Water Temp.	deg F							103
Hotwell Pump Discharge Pressure	psig							>100
Gland Steam Pressure	In. H <sub>2</sub> O							8
Condensate Pressure Before Eductor	psig							>80
Non-Condensable Flow	pph							<60
<b>NIGHT SHIFT</b>								
Cooling Tower Fan Speed: North Fan F/S South Fan F/S								
#1 Turbine Generator Casing Drain Status: Open / Closed								
#2 Turbine Generator Casing Drain Status: Open / Closed								
ULC 1000/1600 protective relay targets and lockout relay supervisory lights clear							SAT / UNSAT	
ULC 1000/1600 ventilation fan I/S O/S								
ULC 1200/1400 protective relay targets and lockout relay supervisory lights clear							SAT / UNSAT	
ULC 1200/1400 ventilation fan I/S O/S								
#1 Turbine Gland Steam Condenser sight glass level							SAT/UNSAT	
#2 Turbine Gland Steam Condenser sight glass level							SAT/UNSAT	
Filter change done on:		Date	Operator				Days/Nights	
First of the month replace filters on ventilation fans for ULC's 1000/1600 , 1200/1400 and crane load center								
WINTER MONTHS: Verify Power and Lights to HEAT TRACE PANELS							SAT/UNSAT	





Powering Today. Protecting Tomorrow.

COVANTA ENERGY NIAGARA  
 OPERATIONS LOGS  
 ASSISTANT CONTROL ROOM OPERATOR LOG

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

## ASSISTANT CONTROL ROOM OPERATOR LOG

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

### BOILER AUXILIARIES LOG

Description	Units	0800	0800		2000	2000		Limits
Feed Pump In Service	½	#1	#2		#1	#2		
Steam Supply Pressure	Psig							
Governor Oil Level								
Turbine Oil Pump Reservoir Level	>1/2							
Turbine Inboard Bearing Oil Pressure	Psig							5 psi
Turbine Outboard Bearing Oil Pressure	Psig							5 psi
Turbine Speed	Rpm							
Feedpump Discharge Pressure	Psig							
Feedpump Oil Pump Reservoir Level	>1/2							
Feedpump Lube Oil Filter Inlet Pressure	Psig							
Feedpump Lube Oil Filter Outlet Pressure	Psig							
Verify Cooling Flow to all Components								Flow
Electric Driven Feedpump			#3			#3		
Motor Inboard Oil Level	>1/2							
Motor Outboard Oil Level	>1/2							
Gear Increaser Oil Level	>1/2							
Gear Increaser Oil Pressure	Psig							
Electric Feedpump Discharge Pressure	Psig							
Feedpump Oil Pump Reservoir Level	>1/2							
Feedpump Lube Oil Filter Inlet Pressure	Psig							
Feedpump Lube Oil Filter Outlet Pressure	psig							
Verify Cooling Flow to all Components								Flow
All feed pump skids oil free (clean oil and put down new absorbent pads if needed)		Sat / Unsat			Sat / Unsat			
		0800	0800		2000	2000		
Boiler Fans		#1	#2		#1	#2		
OFA Motor Inboard/Outboard Oil Level	>1/2							
OFA Fan Inboard/Outboard Oil Level	>1/2							
OFA Fan Inboard/Outboard Cooling Flow	flow							
Cooling Fan in Service	y/n							
OFA Cooling Fan Differential Pressure								.35
FD Motor Inboard/Outboard Oil Level	>1/2							
FD Fan Inboard/Outboard Oil Level	>1/2							
FD Fan Inboard/Outboard Cooling Flow	flow							



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
ASSISTANT CONTROL ROOM OPERATOR LOG**

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

**ASSISTANT CONTROL ROOM OPERATOR LOG**

Date: \_\_\_/\_\_\_/\_\_\_

Description	Units	0800	0800		2000	2000		Limits
FD Fan Damper Position	%							
East Undergrate Air Damper Operability								Sat
West Undergrate Air Damper Operability								Sat
		#1	#2			#1	#2	
ID Motor Inboard/Outboard Oil Level	>1/2							
ID Fan Inboard/Outboard Oil Level	>1/2							
ID Fan Inboard/Outboard Cooling Flow	flow							
ID Cooling Fan In Service	y/n							
Boiler Air Heater								
Motor Oil Level	>1/2							
Drive Unit Upper Bearing Oil Level	vis.							
Drive Unit Lower Bearing Oil Level	vis.							
Cooling Water Flow	flow							
Ingersoll Rand Air Compressors								
Oil Sump Level	>3/4							
Discharge Air Temperature	deg F							
Sump Air Pressure	psig							
Run Hour Meter	hour							
Verify Proper Dryer Operation								
#1 Circ Water Pump Current	Amp							
#1 Circ Water pump Temp	deg C							
#2 Circ Water Pump Current	Amp							
#2 Circ Water pump Temp	deg C							
<b>DESCRIPTION</b>						<b>0000</b>		<b>LIMITS</b>
DI TANK LEVEL	%							>75%
LIME TANK LEVEL	%							>50%
POLYMER TANK LEVEL	Inches							
FILL LIME AND POLYMER TANKS	Y/N							
Diesel Fire Pump Fuel Tank Levels	1/2/3			///				%
Diesel Fire Pumps In Auto/Off (which)	1/2/3			///				Auto/off
Diesel Fire Pump cooling Water Bypass Open	1/2/3			///				Service
Shift	Operator							
Day								
Night								



COVANTA ENERGY NIAGARA  
 OPERATIONS LOGS  
 ASSISTANT CONTROL ROOM OPERATOR LOG

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

## ASSISTANT CONTROL ROOM OPERATOR LOG

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

# DBA BOILER FLAME LOG

BOILER #3					BOILER #4				
	7th FLOOR	EAST	7 <sup>TH</sup> FLOOR	WEST		7th FLOOR	EAST	7 <sup>TH</sup> FLOOR	WEST
DAY SHIFT 1 <sup>ST</sup> ROUND		SAT/UNSAT		SAT/UNSAT			SAT/UNSAT		SAT/UNSAT
LOAD	TIME _____	CF / IF		CF / IF		TIME _____	CF / IF		CF / IF
DAY SHIFT 2 <sup>ND</sup> ROUND		SAT/UNSAT		SAT/UNSAT			SAT/UNSAT		SAT/UNSAT
LOAD	TIME _____	CF / IF		CF / IF		TIME _____	CF / IF		CF / IF
NIGHT SHIFT 1 <sup>ST</sup> ROUND		SAT/UNSAT		SAT/UNSAT			SAT/UNSAT		SAT/UNSAT
LOAD	TIME _____	CF / IF		CF / IF		TIME _____	CF / IF		CF / IF
NIGHT SHIFT 2 <sup>ND</sup> ROUND		SAT/UNSAT		SAT/UNSAT			SAT/UNSAT		SAT/UNSAT
LOAD	TIME _____	CF / IF		CF / IF		TIME _____	CF / IF		CF / IF

CF-CONTINUOUS FLAME IF- INTERMITTENT FLAME

1. FLAMES SHOULD BE OBSERVED THROUGH THE OBSERVATION DOORS AT LEAST TWO TIMES PER SHIFT.  
NOTE: YOU MAY NEED A TOOL TO CLEAR ASH FROM DOOR OPENING
2. ENSURE PROPER PPE IS IN USE, NOMEX HOOD AND FACESHIELD
3. WHEN OBSERVING FLAMES AT THE 7<sup>TH</sup> LEVEL, YOU MAY SEE INTERMITTENT FLAMES BUT NOTHING CONTINUOUS HITTING THE WALLS DIRECTLY
4. ANY UNUSUAL CONDITIONS SHOULD BE REPORTED TO THE SHIFT SUP AND THE CRO.
5. ALL UNSAT FLAME REPORTS SHOULD BE REINSPECTED AFTER CORRECTIVE ACTION HAS BEEN TAKEN.  
NOTE TIME AND RESULTS BELOW.(FLAMES SAT/UNSAT)



COVANTA ENERGY NIAGARA  
 OPERATIONS LOGS  
 ASSISTANT CONTROL ROOM OPERATOR LOG

Doc: OL-1	Rev. 21 No.
Date: 3/12/14	

## ASSISTANT CONTROL ROOM OPERATOR LOG

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

DBA 5KV BREAKER ROOM				
Verify all protective targets and lock out relay supervisory lights are cleared		SAT / UNSAT		SAT / UNSAT
5KV BUS VOLTS/ AMPS "A"		/		/
5KV BUS VOLTS/ AMPS "B"		/		/
ATLAS COMPRESSOR AMPS A/B		/		/
115 KV SWITCHGEAR ROOM				
Verify all protective flags and alarms area cleared			SAT / UNSAT	
115 / 13.8 KV TRANSFORMER (DAYS)				
Description	Units	Line 185	Line 186	Limits
Liquid Temp	deg C			-20 to 85
Winding Temp	deg C			< 75
Liquid Level		Low / Mid / High	Low / Mid / High	
N2 Bottle Pressure	psi			> 100
Transformer N2 Press	psi			1-5
701A / 701B Press	psi	Days ____ / ____	Days ____ / ____	>78

DBA 5KV BREAKER ROOM				
Verify all protective targets and lock out relay supervisory lights are cleared		SAT / UNSAT		SAT / UNSAT
5KV BUS VOLTS/ AMPS "A"		/		/
5KV BUS VOLTS/ AMPS "B"		/		/
ATLAS COMPRESSOR AMPS A/B		/		/
115 KV SWITCHGEAR ROOM				
Verify all protective flags and alarms area cleared			SAT / UNSAT	
115 / 13.8 KV TRANSFORMER (NIGHTS)				
Description	Units	Line 185	Line 186	Limits
Liquid Temp	deg C			-20 to 85
Winding Temp	deg C			< 75
Liquid Level		Low / Mid / High	Low / Mid / High	
N2 Bottle Pressure	psi			> 100
Transformer N2 Press	psi			1-5
701A / 701B Press	psi	Nights ____ / ____	Nights ____ / ____	>75

COMMENTS: \_\_\_\_\_

\_\_\_\_\_

"S" DRIVE / OPS LOGS / MASTER ACRO LOG



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## ATTACHMENT 6-6

### BACKEND OPERATOR'S LOG



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
BACKEND OPERATORS LOG**

Doc. OL-3	Rev. 17 No.
Date 3/12/14	

Current Date: \_\_\_\_\_

DESCRIPTION	PARAMETER	DAYS				NIGHTS			
		ROUND 1		ROUND 2		ROUND 1		ROUND 2	
SDA'S		#3	#4	#3	#4	#3	#4	#3	#4
SDA INLET TEMP	DEGREES F								
SDA OUTLET TEMP	DEGREES F								
SDA DP	H2O								
SDA SLURRY FLOW	GPM								
SLURRY BACK PRESS	PSI								
Bg/Hs Inlet / Outlet Temp.	DEGREES F								
Bg/Hs Temp. Differential	>20 DEGREES F								
ATOMIZER A		#3	#4	#3	#4	#3	#4	#3	#4
SLURRY FLOW	GPM								
WATER FLOW	GPM								
VIBRATIONS	IN / SEC								
AMPS									
LUBE OIL LEVEL	SAT / UNSAT								
LOWER BRNG TEMP	°F								
UPPER BRNG TEMP	°F								
COOLING WATER TEMP	°F								
PSI TO FOGGER									
FOGGING PSI									
UPPER BRNG SUPPLY	FLOW	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
LOWER BRNG SUPPLY	FLOW	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
VAC PUMP OIL JAR	FULL	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
RETURN OIL VACUUM	INCHES								
COOLING WTR FLOW	SAT / UNSAT								
ATOMIZER B		#3	#4	#3	#4	#3	#4	#3	#4
SLURRY FLOW	GPM								
WATER FLOW	GPM								
VIBRATIONS	IN / SEC								
AMPS									
LUBE OIL LEVEL	SAT / UNSAT								
LOWER BRNG TEMP	°F								
UPPER BRNG TEMP	°F								
COOLING WATER TEMP	°F								
PSI TO FOGGER									
FOGGING PSI									
UPPER BRNG SUPPLY	FLOW	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
LOWER BRNG SUPPLY	FLOW	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
VAC PUMP OIL JAR	FULL	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
RETURN OIL VACUUM	INCHES								
COOLING WTR FLOW	SAT / UNSAT								



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
BACKEND OPERATORS LOG**

Doc. OL-3	Rev. 17 No.
Date 3/12/14	

Current Date: \_\_\_\_\_

DESCRIPTION	PARAMETER	DAYS				NIGHTS			
		ROUND 1		ROUND 2		ROUND 1		ROUND 2	
ATOMIZER C		#3	#4	#3	#4	#3	#4	#3	#4
SLURRY FLOW	GPM								
WATER FLOW	GPM								
VIBRATIONS	IN / SEC								
AMPS									
LUBE OIL LEVEL	SAT / UNSAT								
LOWER BRNG TEMP	°F								
UPPER BRNG TEMP	°F								
COOLING WATER TEMP	°F								
PSI TO FOGGER									
FOGGING PSI									
UPPER BRNG SUPPLY	FLOW	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
LOWER BRNG SUPPLY	FLOW	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
VAC PUMP OIL JAR	FULL	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N	Y / N
RETURN OIL VACUUM	INCHES								
COOLING WTR FLOW	SAT / UNSAT								
<b>ATOMIZER COOLING SYSTEM (VERIFY VALVE LINE UP)</b>		#3	#4	#3	#4	#3	#4	#3	#4
RESERVE TANK LEVEL	25-35"								
SYSTEM AIR PRESS	25 PSIG								
MAKE-UP DRUM LEVEL	MIN HALF FULL	YES / NO				YES / NO			
<b>ATOMZIER BENCH AREA</b>									
ACID TANK-CLEAN PARTS REMOVED	YES	YES / NO				YES / NO			
SPARE ATOMIZER WHEELS W/GOOD NOZZLES	>2								
<b>FLYASH SYSTEM</b>		#3	#4	#3	#4	#3	#4	#3	#4
SDA HOPPER	SAT / UNSAT								
SDA DFV'S									
CVR-500-02									
CVR-500-03									
BAGHOUSE DFV'S									
CVR-500-04A									
CVR-500-04B									
CVR-500-04C									
BAGHOUSE HOPPERS									
CVR-500-05									
BAGHOUSE CLEANING CYCLE									
POPPIT OILER LEVEL									
BGHS D/F OILER LEVEL									
<b>DESCRIPTION</b>	<b>PARAMETER</b>	<b>DAYS</b>				<b>NIGHTS</b>			



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
BACKEND OPERATORS LOG**

Doc. OL-3	Rev. 17 No.
Date 3/12/14	

Current Date: \_\_\_\_\_

		ROUND 1		ROUND 2		ROUND 1		ROUND 2	
BAGHOUSES		#3	#4	#3	#4	#3	#4	#3	#4
BAGHOUSE DP									
MODULES IN SERVICE									
HEATER OPERATION									
CLEANING CYCLE	ON / OFF								
REV AIR FAN INSPECTION	SAT / UNSAT								
AIR SWEEP OPERATION	SAT / UNSAT								

- \*Upper BgHs Platform Levels Clear of Debris. (initials) DAYS \_\_\_\_\_ NIGHTS \_\_\_\_\_
- \*Test Eyewashes every Shift during winter cold. (Initials) DAYS \_\_\_\_\_ NIGHTS \_\_\_\_\_
- \*Fly ash on Concrete Floor #3 BgHs Where? SDA 1 2 3 4 5 6 7 8 (circle) W.O.# \_\_\_\_\_
- \*Fly ash on Concrete Floor #4 BgHs Where? SDA 1 2 3 4 5 6 7 8 (circle) W.O.# \_\_\_\_\_
- \*LIME SILO TRENCH SAT / UNSAT (Action Taken) \_\_\_\_\_ \*
- \*Bag House Trenches SAT / UNSAT (Action Taken) \_\_\_\_\_ \*

SILOS / SLAKERS / PUMPS		#1	#2	#1	#2	#1	#2	#1	#2
LIME LEVEL	%								
TRAIN IN SERVICE	1 OR 2								
SLAKING H2O PRESS	PSIG								
SLAKER TEMP	DEGREES F								
SLAKING H2O VLV	% OPEN								
DILUTION H2O FLOW	GPM								
LIME FEEDER SPEED	%								
LIME CHUTE	SAT / UNSAT								
ASPIRATOR CHECK	SAT / UNSAT								
BIN ACTIVATOR	SAT / UNSAT								
TANK AGITATOR	SAT / UNSAT								
GRIT SCREEN	SAT / UNSAT								
GRIT CONVEYOR	SAT / UNSAT								
SLURRY TANK LEVEL	%								
SLURRY CONC.	%								
PUMPS IN SERVICE	1-2-3								
DISCHARGE PRESS	PSIG								
SEAL WATER FLOW	SAT / UNSAT								
UREA SKID									
TANK LEVEL	20-90%								
TANK TEMPERATURE	MIN 75F								
CIRC PUMP PUMP I/S	A / B	A / B		A / B		A / B		A / B	
TEMP DISC PRESS	30-50 PSIG								
CIRC HEATER I/S	SAT / UNSAT	SAT / UNSAT		SAT / UNSAT		SAT / UNSAT		SAT / UNSAT	
TANK HEATER I/S	SAT / UNSAT	SAT / UNSAT		SAT / UNSAT		SAT / UNSAT		SAT / UNSAT	
SEAL LINE TEMP	MIN 75F								





Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
BACKEND OPERATORS LOG**

Doc. OL-3	Rev. 17 No.
Date 3/12/14	

Current Date: \_\_\_\_\_

DESCRIPTION	PARAMETER	DAYS				NIGHTS			
		ROUND 1		ROUND 2		ROUND 1		ROUND 2	
<b>BOILER #3 METERING MODULE</b>									
MTR PUMP 1 FLOW	4-8 GPM								
BST PUMP 1 FLOW	GPM								
BST PUMP 1 PRESS	60-80 PSIG								
MTR PUMP 2 FLOW	4-8 GPH								
BST PUMP 2 FLOW	GPM								
BST PUMP 2 PRESS	60-80 PSIG								
<b>BOILER #4 METERING MODULE</b>									
MTR PUMP 1 FLOW	4-8 GPH								
BST PUMP 1 FLOW	GPM								
BST PUMP 1 PRESS	60-80 PSIG								
MTR PUMP 2 FLOW	4-8 GPH								
BST PUMP 2 FLOW	GPM								
BST PUMP 2 PRESS	60-80 PSIG								
<b>CARBON FEED SYSTEM</b>		<b>#3</b>	<b>#4</b>	<b>#3</b>	<b>#4</b>	<b>#3</b>	<b>#4</b>	<b>#3</b>	<b>#4</b>
BLOWER DISCHARGE	8 to 12 PSI								
EDUCTOR SUCTION	.5-3" WC (Note #1)								
FEEDER SET POINT	>30								
HOSE CONNECTIONS	SAT								
MAIN AIR PRESSURE	100 PSI								
HOPPER FLUIDIZING AIR	60 PSI								
PANT LEG FLUIDIZING AIR	30 PSI								
SILO LEVEL	FT								
SILO READY TO FILL	NOTIFY SS IF YES	YES / NO				YES / NO			
#3 DIRECTIONAL SLIDEGATE	OPEN=>SDA INLET CLOSED=>SDA OUTLET	OPEN / CLOSED				OPEN / CLOSED			
#4 DIRECTIONAL SLIDEGATE	OPEN=>SDA INLET CLOSED=>SDA OUTLET	OPEN / CLOSED				OPEN / CLOSED			

Note #1: Clean the injection nozzles when the suction pressure is within .2" WC of the low setpoint. The setpoint for #3 carbon system should be at 1" WC and on #4 carbon system at .5" WC.

<b>CALIBRATION CHECK OF CARBON FLOW (LBS/HOUR) TO BE COMPLETED EVERY MONDAY/FRIDAY ON #3 / #4 UNIT</b>		<b>#3 SYSTEM</b> LBS. _____ TOTAL MINUTES OF TEST _____ LBS/HOURS _____	
NAME:	NAME:	<b>#4 SYSTEM</b> LBS. _____ TOTAL MINUTES OF TEST _____ LBS/HOURS _____	
A/C UNITS IN BACK END	NO FREON LEAK	SAT / UNSAT	SAT / UNSAT



Powering Today. Protecting Tomorrow.

**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS  
BACKEND OPERATORS LOG**

Doc. OL-3	Rev. 17 No.
Date 3/12/14	

Current Date: \_\_\_\_\_

DAY SHIFT								
BOILER #3 DENOX MOD #2								
INJECTOR		A	B	C	D	E	F	G
FLOW	GPM							
CHEMICAL PRESS	60-80 PSI							
AIR PRESS	80 PSI							
BOILER #4 DENOX MOD #2								
INJECTOR		A	B	C	D	E	F	G
FLOW	GPM							
CHEMICAL PRESS	60-80 PSI							
AIR PRESS	80 PSI							

NIGHT SHIFT								
BOILER #3 DENOX MOD #2								
INJECTOR		A	B	C	D	E	F	G
FLOW	GPM							
CHEMICAL PRESS	60-80 PSI							
AIR PRESS	80 PSI							
BOILER #4 DENOX MOD #2								
INJECTOR		A	B	C	D	E	F	G
FLOW	GPM							
CHEMICAL PRESS	60-80 PSI							
AIR PRESS	80 PSI							





**COVANTA NIAGARA**  
**O&M Manual/ECOM**

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

**ATTACHMENT 6-7**  
**REFUSE CRANE OPERATOR LOG**



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA, L.P.  
OPERATIONS LOGS  
CRANE OPERATOR LOG

Doc. OL-5	Rev 9 No.
Date: 3/12/14	

Name: \_\_\_\_\_ Date: \_\_\_\_\_ Shift: \_\_\_\_\_

(Conditions at the start of the shift)

**BOILER:**

BLR #3 _____ KPPH	CRANE CAB CLEANLINESS	SAT/ UNSAT
BLR #4 _____ KPPH	MSW FEED AREA	_____

CRANE CAB PRESSURE ("H2O): \_\_\_\_\_ (Change filters at <= .10"H2O)

NORTH CRANE: IN SERVICE / AVAIL / UNAVAIL      LAST CLEANED      \_\_\_/\_\_\_/\_\_\_  
WATER CANNON LAST TESTED (water flow tested monthly April-October)      \_\_\_/\_\_\_/\_\_\_

SOUTH CRANE: IN SERVICE / AVAIL / UNAVAIL      LAST CLEANED      \_\_\_/\_\_\_/\_\_\_  
WATER CANNON LAST TESTED (water flow tested monthly April-October)      \_\_\_/\_\_\_/\_\_\_

**SAFETY LIMITS:** (Shift Supervisor approval required to run if any safety limit does not work properly)

ANTI-COLLISION ALARM	North	SAT / UNSAT	South	SAT / UNSAT
CAB/DECK SLOW DOWN	North	SAT / UNSAT	South	SAT / UNSAT
WALL SLOW DOWN AND STOP:	North	SAT / UNSAT	South	SAT / UNSAT
HOIST UPPER LIMIT:	North	SAT / UNSAT	South	SAT / UNSAT
CHARGING DECK LASER	North	SAT / UNSAT	South	SAT / UNSAT

GRAPPLE LOG (Note oil leaks and other noticed or known issues)			
NORTH # _____	SOUTH # _____	SPARE # _____	DECK _____

TIME	CRANE / BOILER RELATED COMMENTS
Processing coal tar Y / N      Trucks received _____      Processed _____	

OFF GOING OPERATOR: \_\_\_\_\_ ON COMING OPERATOR: \_\_\_\_\_

Doc. OL-5	Rev 9 No.
Date: 3/12/14	

## **CRANE OPERATOR LOG ENTRIES**

THE FOLLOWING IS A BRIEF DESCRIPTION OF WHAT SHOULD BE PLACED ON THE CRANE OPERATOR LOGS BUT IS NOT LIMITED TO ONLY THESE ITEMS. THE LOGBOOK IS AN OFFICIAL RECORD AND SHOULD BE TREATED AS SUCH.

THE TOP PART OF THE LOG IS INTENDED TO HIGHLIGHT PLANT CONDITIONS AND ANY SYSTEM DEFICIENCIES AT SHIFT TURNOVER. THERE IS A SPACE NEXT TO THE CRANE OR GRAPPLE TO LOG ISSUES AND IF NEEDED PLEASE CARRY ON INTO THE COMMENTS SECTION. CRANE CAB CLEANLINESS IS A SUBJECTIVE AREA. PLEASE USE COMMON COURTESY AND KEEP THE AREA CLEAN. THE CRANE CAB IS NOT INTENDED TO BE A BREAK AREA FOR OTHER WATCH STANDERS OR PERSONNEL. THE CRANE OPERATOR HAS THE RIGHT TO EVICT THOSE WHO CAN NOT KEEP THE AREA CLEAN OR THOSE THAT DO NOT BELONG. THE AREA IS A PLACE THAT FOOD AND BEVERAGE CAN BE CONSUMED SO IT MUST STAY CLEAN OR THESE PRIVLEDGES WILL BE REMOVED.

THE CRANE SAFETY LIMITS NEED TO BE TESTED AT THE BEGINNING OF EACH SHIFT. ANY DEFICIENCY SHOULD BE BROUGHT TO THE SHIFT SUPERVISOR'S ATTENTION.

COMMENTS SHOULD LOG ALL JOB RELATED CHANGES SUCH AS LOAD SETPOINTS, CHUTE CONDITIONING WATER,MSW ON/OFF FLOOR, FIRES AND CRANE OR GRAPPLE FAILURES OR DISCREPANCIES THAT OCCUR DURING THE SHIFT. ANY MAINTENANCE THAT MAY OCCUR SHOULD ALSO BE LOGGED ALONG WITH THE STAUS OF THE JOB. THE OPERATOR SHOULD SIGN THE LOG PRIOR TO BEING RELIEVED. THE ON COMING OPERATOR SHOULD SIGN AT THE BOTTOM ACKNOWLEDGING AND ACCEPTING THE EXISTING CONDITIONS AND THE OPERATING PLAN GOING FORWARD.



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## ATTACHMENT 6-8

### FERROUS AND NONFERROUS OPERATOR'S LOG







Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

**ATTACHMENT 6-9**  
**WATER TREATMENT OPERATOR'S LOG**



Covanta Energy Niagara

Doc OL-10 Rev 9  
Rev 9 3/7/2011

Date: \_\_\_\_\_

Demineralizer Runs		Mixed Bed Runs	
1		1	
2		2	
3		3	

**Notes and Asides**

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

pH monitor calibration: \_\_\_\_\_

---

---

Operator: \_\_\_\_\_

**Tank Levels and Integrator Readings**

DI Production				
Condensate Tank disch. FQI 361				
A-1 Condensate FQI 304				
Raw Water FQI 500				
Norampac Cond (to cond tank)				
Norampac Cond (to sewer)				
Acid Tank	Caustic Tank	CL-1432	CT Acid	Bleach

Buffer System		
Pumps	Controller	Ph > 10.0
1	Auto Manual	Sat/Unsat
2	Auto Manual	<b>Tank Full</b> Yes/No

A/C ROOM UNIT INSPECTION NO FREON PRESENT SAT/UNSAT



# Water Treatment Operator Log

Doc OL-10  
Rev. 9 3/7/2011

Date: \_\_\_\_\_

Boilers								
O/L	Cond <100µmho	pH 9.2-9.9	Phos 5-15 ppm	Silica <2 ppm	Phos pump	Pump setting	Phos level	B/D position
1								
2								
3							DBA day tank	
4								

Demineralizers						
O/L	Cond <10 µmho	Anion pH 6.0-10.0	Silica <50 ppb	hardness ppm	resin level	Totalizer flow
1						
2						
3						

Mixed Bed Polishers					RWHX			
O/L	Cond <.2 µmho	Silica <15 ppb	Temp < 135F	Flow rate	Cond <15 µmho	Rcvr level	Stm ctr mode	3 way
								CT TT

Printed copies are not document controlled. Refer to "S" drive, ISO 14001 Environmental Management Systems file for latest approved version.

Dearators					
O/L	Upr Temp 250-270F	Lwr Temp 250-270F	Pressure 20-29psi	pcv-808 5-25%	DA O2
1					
2					

Main Steam		
pH 8.0-9.0	Sodium <15 ppb	Silica <20 ppb

Raw Water / Clarifier										
DI Tk level	pH mtr cal 4,7,10 bfrs	Swr pH <5.0	Swr pH >10.0	RW Cond.	RW hardness	FC 313 Flow	Temp (F) 100-110	Torque <40	Turbine speed	Rake speed

Gravity Filters				Lime Tank						
Cond µmhos	pH 9.4-9.6	Hardness ppm		P Alk	M Alk	2P-M (5-15)	Chem count	Lime timer	Pump online	Bags added

Feedwater								
Cond <10µmho	pH 8.0-9.0	Silica <50 ppb	Mekor	Mekor pumps	Mekor pmp settings	Mekor tank lvl	Morph Pump	Morph tank level
				E / W	/			

Turbines					Steam Exports					
O/L	Cond µmhos	pH 8.0-9.0	Hardness 0 (ppm)	Silica <20 ppb	Customer	Cond	pH	Flow	Silica	Temp
1					Oxy					
2					Norampac					



**COVANTA NIAGARA**  
**O&M Manual/ECOM**

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

**ATTACHMENT 6-10**

**ALTERNATE FUELS OPERATOR'S LOGS**





Powering Today. Protecting Tomorrow.

**COVANTA NIAGARA  
ALTERNATE FUELS OPERATOR**

Doc. OL – 4	Rev.8
Date: 3/8/14	

DESCRIPTION	UNITS	DAYS	DAYS	NIGHTS	NIGHTS	LIMITS
<b>NEW NORTH PARASCREW</b>						
Auger Position	Ft					0 – 240
Walled in	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	No
Oil Level	Level					> 1/2
Oil Temp	Deg F					<180
Oil Leaks	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	No
Equipment Bolts Tight	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	Yes
Auger Interlock	I/B	Yes / No	Yes / No	Yes / No	Yes / No	Yes
Chain Lubricated	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	Yes
Charge Pump Pressure	Psi					200 – 300
Auger Pressure	Psi					<2500
Travel Pressure	Psi					<2200
Suction Pressure	PSI					< -10 HG
Auger Case Flow	GPM					<5 Gpm
Auger Case Pressure	Psi					<15 Psi
Travel Case Flow	GPM					< 2 Gpm
Travel Case Pressure	Psi					< 15 Psi
Tunnel trolley OK	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	Yes
Staffa Coupling Alignment	OK					OK
<b>NEW SOUTH PARASCREW</b>						
Auger Position	Ft					0 – 240
Walled in	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	No
Oil Level	Level					> ½
Oil Temp	Deg F					<180
Oil Leaks	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	No
Equipment Bolts Tight	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	Yes
Auger Interlock	I/B	Yes / No	Yes / No	Yes / No	Yes / No	Yes
Chain Lubricated	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	Yes
Charge Pump Pressure	Psi					200 – 300
Auger Pressure	Psi					<2500
Travel Pressure	Psi					<2200
Suction Pressure	Psi					< -10 HG
Auger Case Flow	GPM					<5 Gpm
Auger Case Pressure	Psi					<5 Gpm
Travel Case Flow	GPM					< 2 GPM
Travel Case Pressure	Psi					< 15 Psi
Tunnel trolley OK	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	Yes
Staffa Coupling Alignment	OK					OK
<b>CONVEYORS</b>						
Inspect Conveyor 4A	sat / unsat	sat / unsat	sat / unsat	sat / unsat	sat / unsat	sat
Inspect Conveyor 4B	Sat / Unsat	sat / unsat	sat / unsat	sat / unsat	sat / unsat	sat
Inspect Conveyor 5A	Sat / Unsat	sat / unsat	sat / unsat	sat / unsat	sat / unsat	sat
Inspect Conveyor 5B	Sat / Unsat	sat / unsat	sat / unsat	sat / unsat	sat / unsat	sat
Inspect Conveyor 6A	Sat / Unsat	sat / unsat	sat / unsat	sat / unsat	sat / unsat	sat
<b>NOTE: All Conveyors should be inspected for rollers, skirting, tracking, bearings, and associated problems</b>						



Powering Today. Protecting Tomorrow.

**COVANTA NIAGARA  
ALTERNATE FUELS OPERATOR**

Doc. OL - 4	Rev.8
Date: 3/8/14	

DESCRIPTION	UNITS	DAYS	DAYS	NIGHTS	NIGHTS	LIMITS
<b>C-BLDG</b>	Add sample to the bulk barrel					
Wood Sample Taken	YES	Y / N		Y / N		Y / N
<b>FLYASH SYSTEM</b>						
Flyash silo level	Ft.					<10feet
Flyash conditioner	Sat/Unsat					Sat
# trucks flyash unloaded						
Cleaned pugmill	Y/N					Y
<b>BOTTOM ASH</b>						
Sifting ash hoppers and chutes	Sat/Unsat					Sat
Quench tank water level	Sat/Unsat					Sat
Quench tank chain	Sat/Unsat					Sat
Quench tank drag bars	Sat/Unsat					Sat
<b>QUENCH TANK HYDRAULICS</b>						
Reservoir Level	Complete					Sat
Reservoir temperature	Complete					Sat
Pump discharge pressure	Complete					Sat
Filter differential pressure	Complete					Sat
Chain drive speed						
Clean flyash room						
<b>Grates</b>						
Grease grates	Sat/Unsat					Sat
Inspect grates	Sat/Unsat					Sat
<b>BLOW SIDEWALLS ONTO GRATES (2X/ SHIFT)</b>	Y/N					Y
Check drive oil level	Sat/Unsat					Sat
Inspect drive coupling	Sat/Unsat					Sat
Drive guards installed	Sat/Unsat					Sat
A side drive speed	Rph					2.0 - 5.0
B side drive speed	Rph					2.0 - 5.0
Clean observation doors	Complete					Sat
Clean fire eye	Complete					Sat
Precipitator Platcos	Sat/Unsat					Sat
2A Flyash drag conveyor	Sat/Unsat					Sat
2B Flyash drag conveyor	Sat/Unsat					Sat
#4 Flyash drag conveyor	Sat/Unsat					Sat
Cinder collection conveyor	Sat/Unsat					Sat
Cinder transfer conveyor	Sat/Unsat					Sun
<b>NOTE: When blowing back sidewalls, follow SOP 78 for opening boiler doors, wear all required ppe, ensure safety pin in air lance being used and blow walls onto center of grates twice per shift.</b>						



**COVANTA NIAGARA  
ALTERNATE FUELS OPERATOR**

<b>Doc.</b> OL - 4	<b>Rev.8</b>
Date: 3/8/14	

<b>ENVIRONMENTAL</b>						
Lime Feeder	Sat/Unsat					Sat
Lime Feeder speed	0 - 1000					Sat
Eductor condition	Sat/Unsat					Sat
Carbon feeder	Sat/Unsat					Sat
Carbon feeder speed	0 - 1000					Sat
Eductor condition	Sat/Unsat					Sun
Carbon flow rate	Lbs/hr					>50lbs/hr
Carbon sample weight	lbs					>1.67lbs
Carbon feeder speed	hz					

DESCRIPTION	UNITS	DAYS	DAYS	NIGHTS	NIGHTS	LIMITS
<b>SURGE BIN</b>						
Reservoir level 2C/2D	OK					1/2 - 2/3
Reservoir temp 2C/2D	Deg F					20 - 35
Charge pump press 2C	Psig					200 - 250
Main pump press 2C	Psig					400 - 2500
Case drain flow 2C	Gpm					< 8
Charge pump press 2D	Psig					200 - 250
Main pump press 2D	Psig					400 - 2500
Case drain flow 2D	Gpm					< 8
Reservoir level 2E/2F	OK					1/3 - 2/3
Reservoir temp 2E/2F	Deg F					20 - 35
Charge pump press 2E	Psig					200 - 250
Main pump press 2E	Psig					400 - 2500
Case drain flow 2E	Gpm					< 8
Charge pump press 2F	Psig					200 - 250
Main pump press 2F	Psig					400 - 2500
Case drain flow 2F	Gpm					< 8
Filter indicators	OK					Not Red
Gearbox oil level	OK					Normal
Inspect power rollers	OK					Sat





Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
ALTERNATE FUELS OPERATOR

Doc. OL - 4	Rev.8
Date: 3/8/14	

### NUMBER 2 BOILER LOG

Description	Units	1200	0000	Limits
Rear Lower OFA Pressure	in. W.C.	/	/	
Rear Intermediate OFA Pressure	in. W.C.	/	/	
Rear Upper OFA Pressure	in. W.C.			
Rotary Air Pressure	in. W.C.	/	/	
Carrier Air Pressure	in. W.C.	/	/	
Front East Intermediate OFA Pressure	in. W.C.			
Front West Intermediate OFA Pressure	in. W.C.			
Front Upper OFA Pressure	in. W.C.	/	/	

### NUMBER 2 BOILER PRECIPITATOR LOG - DAY SHIFT

	2A1	2A2	2B1	2B2	2C1	2C2	2D1	2D2
Primary Amps								
Primary Voltage								
Field Load (mA)								
A Field Load (KV1)								
B Field Load (KV2)								
INSPECT RAPPERS (FILL OILERS)								

### NUMBER 2 BOILER PRECIPITATOR LOG - NIGHT SHIFT

	2A1	2A2	2B1	2B2	2C1	2C2	2D1	2D2
Primary Amps								
Primary Voltage								
Field Load (mA)								
A Field Load (KV1)								
B Field Load (KV2)								



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
ALTERNATE FUELS OPERATOR

Doc. OL - 4	Rev.8
Date: 3/8/14	

**WORK ORDERS SUBMITTED:**

**WORK ORDERS COMPLETED:**

**CARBON SAMPLE TEST DONE \_\_\_\_\_ INT. (50 LBS/HR) RESULT \_\_\_\_\_ LBS/HR**

<b>CARBON SACKS</b>	
<b>LIME PALLETS</b>	

DAY OPERATOR SIGNATURE \_\_\_\_\_

NIGHT OPERATOR SIGNATURE \_\_\_\_\_

Doc. OL - 4	Rev.8
Date: 3/8/14	

## #2 FLYASH SYSTEM OPERATING PROCEDURE

OPERATOR \_\_\_\_\_

DATE \_\_\_\_\_

1. Before startup of the fly ash system, complete the following items below:

Inspection list	DAY SHIFT	NIGHT SHIFT
Inspection of the rotary shoe, remove cover and ensure shoe is snug against rotary feeder. If not, scrape out to get proper clearance.		
Clean mixer paddles, sidewalls and discharge chute. Scrape down thoroughly.		
Ensure spray nozzles are clear and flow water freely		
Grease all mixer bearings and rotary feeder seals		
Oil the rotary drive chain		
Ensure all guards are in place		
Ensure BFI truck is in place		

2. Start up the flyash system, by verifying the mixer, rotary feeder, slidegate, and fluffing air are in automatic and then depress the start button on the control panel.
3. Ensure adequate water supply by opening the water control valve to the desired setting to eliminate dusting but not so much to create mud.
4. Align no more than 4 fluffing air nozzles at a time, too many open nozzles will result in poor air pressure into the silo and little effect on moving ash. Best practices have shown that rotating 1-2 nozzles at a time will move more ash.
5. Sometimes it is necessary to manually bypass the fluffing air solenoid due to poor ash flow, if necessary, do not open the bypass valve for more than 5 seconds as damage to the fluffing stones may occur.
6. keep the flyash silo level below 10 feet
7. After completion of flyash removal, shut the system down by depressing the stop button, the system will go thru a sequence with the mixer to be the last component secured. Once the mixer shuts down, shut the water control valve, and clean the mixer paddles, sidewalls, and discharge chute by scraping to prevent the ash from hardening up.



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

**ATTACHMENT 6-11**  
**LIQUID WASTE OPERATOR'S LOG**



**COVANTA ENERGY NIAGARA  
OPERATIONS LOGS**

10/06/13	Rev. 1

**LIQUID WASTE OPERATOR LOG**

Date: \_\_\_/\_\_\_/\_\_\_

DESCRIPTION	PARAMETER	DAY SHIFT ROUND 1		DAY SHIFT ROUND 2		NIGHT SHIFT ROUND 1		NIGHT SHIFT ROUND 2	
#3 BOILER MOYNO PUMP	PUMP PRESSURE								
#3 BOILER MOYNO PUMP RECIR. VALVE	OPEN / CLOSED								
#4 BOILER MOYNO PUMP	PUMP PRESSURE								
#4 BOILER MOYNO PUMP RECIR. VALVE	OPEN / CLOSED								
TUCK OFF LOADING PUMP	SAT/UNSAT								
SPARE MOYNO PUMP	PUMP PRESSURE								
TRUCK STRAINER	SAT/UNSAT								
#3 BOILER LIQUID LANCES	INSPECTED								
#4 BOILER LIQUID LANCES	INSPECTED								
#3 BOILER FLOW METER	GPM								
#4 BOILER FLOW METER	GPM								
ALL NOZZEL CHICAGO FITTINGS HAVE SAFETY PINS OR CAPS IN PLACE	YES / NO								
FRAC TANK LEVELS	BROWN / CRYSTAL CLEAN	<u>BROWN</u>	<u>CRYSTAL</u>	<u>BROWN</u>	<u>CRYSTAL</u>	<u>BROWN</u>	<u>CRYSTAL</u>	<u>BROWN</u>	<u>CRYSTAL</u>
LIQUID STORAGE TANK LEVEL	DAY SHIFT @ BEGINING	<u>TANK #1</u>	<u>TANK #2</u>	<u>TANK #3</u>	<u>TANK #4</u>	<u>TANK #5</u>	<u>TANK #6</u>		
	DAY SHIFT @ END								
	NIGHT SHIFT @ END								



Powering Today. Protecting Tomorrow.

COVANTA ENERGY NIAGARA OPERATIONS LOGS

10/06/13	Rev. 1

LIQUID WASTE OPERATOR LOG

		TANK #1	TANK #2	TANK #3	TANK #4	TANK #5	TANK #6	
STORAGE TANK STEAM SPARGES		SAT/UNSAT	SAT/UNSAT	SAT/UNSAT	SAT/UNSAT	SAT/UNSAT	SAT/UNSAT	
TANK MIXERS				SAT/UNSAT	SAT/UNSAT	SAT/UNSAT	SAT/UNSAT	
LIQUID WATES STORAGE AREA DIKE SPILL FREE								
CONDITION	SAT / UNSAT							
STORAGE TANK LEVEL PROBES	SAT / UNSAT	TANK #1	TANK #2	TANK #3		TANK #4		TANK #5 TANK #6

Clean up area during your watch, Please list below.

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

DAY OPERATOR: \_\_\_\_\_ NIGHT OPERATOR: \_\_\_\_\_



COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## ATTACHMENT 6-12

### CHEMICAL AND FUEL STORAGE TANK INSPECTIONS



COVANTA NIAGARA

**MONTHLY/ANNUAL INSPECTION: ACID STORAGE TANK**

**TANK 001B**

Doc. TI -1	Revision No. 2
Revision Date: 3/19/12	

**Inspection Date:**

**CHEMICAL BULK STORAGE NO. 9-000239**

**LEVEL OF ACID IN TANK \_\_\_\_\_**

INSPECTION ITEM	WHAT TO INSPECT WHAT TO LOOK FOR	WHAT WAS FOUND BE SPECIFIC	WHAT CORRECTIVE ACTIONS WERE TAKEN/COMMENTS/W.O.'S
DIKE WALL	EROSION, CRACKS, EVIDENCE OF RELEASES, EXCESSIVE SETTLEMENT, STRUCTURAL WEAKNESS, ADEQUACY OF COATINGS OR LINERS (IF APPLICABLE)		
DIKE BASE	EROSION, CRACKS, EVIDENCE OF RELEASES, EXCESSIVE SETTLEMENT, STRUCTURAL WEAKNESS, ADEQUACY OF COATINGS OR LINERS (IF APPLICABLE)		
LIQUID IN DIKE	EVIDENCE OF ANY RELEASE, WHAT IS LIQUID, HOW MUCH LIQUID IS IN DIKE, WHAT IS THE pH OF LIQUID?		
TANK STRUCTURE AND TANK CRADLES	CRACKS, AREAS OF WEAR, CORROSION, POOR MAINTENANCE AND OPERATING PRACTICES, SWELLING, EXCESSIVE SETTLEMENT OF STRUCTURE, SEPARATION OR SWELLING OF TANK INSULATION, ADEQUACY OF EXTERIOR COATINGS, EXTERIOR WELDS, ETC.		
TANK NOZZLES	CORROSION, RUST, EVIDENCE OF ANY RELEASES, CRACKS, BLIND FLANGE OR CAPS MISSING, EXTERIOR WELDS, ETC.		





COVANTA NIAGARA

**MONTHLY/ANNUAL INSPECTION: ACID STORAGE TANK**

Doc. TI -1	Revision No. 2
Revision Date: 3/19/12	

**Inspection Date:**

<b>PLATFORMS AND LADDERS</b>	<b>CRACKS, CORROSION, EXTERIOR WELDS, ETC.</b>		
<b>VALVES</b>	<b>CRACKS, CORROSION, EXTERIOR WELDS, POOR MAINTENANCE AND OPERATING PRACTICES, ETC.</b>		
<b>PIPES INCLUDE: FILL, OVERFLOW, AND COMPLETE PROCESS PIPE TO PUMPS IN SKID ROOM</b>	<b>CRACKS, AREA OF WEAR, CORROSION, POOR MAINTENANCE AND OPERATING PRACTICES, EXTERIOR WELDS, ADEQUACY OF EXTERIOR COATING, ADEQUACY AND STRUCTURAL INTEGRITY OF SUPPORTS, EVIDENCE OF LEAKS, ETC.</b>		
<b>INSTRUMENTATION, IF APPLICABLE</b>	<b>WHAT IS DATE OF MOST RECENT INSTRUMENT CALIBRATION? ARE INSTRUMENT LEADS INTACT? ARE INSTRUMENTS CORRODED, CRACKED, COVERS MISSING?</b>		
<b>LEVEL INDICATOR</b>	<b>IS LEVEL INDICATOR OPERABLE? EVIDENCE OF LEAKS, ETC.</b>		
<b>VENT/OVERFLOW LINE</b>	<b>IS VALVE CORRODED, CRACKED, BLOCKED, ETC?</b>		
<b>LEVEL ALARMS, IF APPLICABLE</b>	<b>ARE ALARMS OPERABLE?</b>		
<b>IS SODIUM BICARBONATE AVAILABLE IN SPILL CONTROL CABINET</b>	<b>IS THERE ADEQUATE SPILL CONTROL EQUIPEMENT? CHECK INVENTORY SHEET</b>		



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

**MONTHLY/ANNUAL INSPECTION: ACID STORAGE TANK**

TANK 001B

Doc. TI-1	Revision No. 2
Revision Date: 3/19/12	

**Inspection Date:**

INSPECTION ITEMS	LOCATION	WHAT TO LOOK FOR	WHAT WAS FOUND (BE SPECIFIC) TAG ITEM	WHAT CORRECTIVE ACTION TAKEN COMMENTS/W.O.
FLANGE GUARDS, FLANGES, SCREWED CONNECTIONS, BOLTS, NUTS, & GASKETS	INCLUDE: FILL, OVERFLOW, COMPLETE PROCESS PIPING TO PUMPS IN SKID ROOM	MISSING OR WORN FLANGE GUARDS AND/OR LEAKS ON THE FLANGES OR THREADS. RUSTED BOLTS/NUTS, ETC.		
FLANGE GUARDS, FLANGES SCREWED CONNECTIONS, BOLTS, NUTS, AND GASKETS	INCLUDES PIPING FROM THE SKID ROOM TO ALL THREE TRAINS, ALL THREE MIXBEDS INCLUDING SAMPLE PIPING	MISSING OR WORN FLANGES GUARDS AND/OR LEAKS ON THE FLANGES OR THREADS. RUSTED BOLTS/NUTS, ETC.		

**NOTE: WHEN CHECKING ALL FLANGE AND SCREWED PIPING, BOLTS, AND NUTS - FACE SHIELD AND CHEMICAL GLOVES ARE TO BE WORN.**

**FOR ITEMS ON THIS NOTE: IF THE INSPECTOR FINDS A PROBLEM, A CORRECTIVE ACTION MUST BE INDICATED**

**I CERTIFY THAT I INSPECTED THIS TANK AND CONTAINMENT FACILITY TO THE BEST OF MY ABILITY INSPECTION SHEET.**

\_\_\_\_\_  
SIGNATURE OF INSPECTOR DATE

**RETURN ORIGINAL TO PLANT ENVIRONMENTAL ENGINEER**

COVANTA NIAGARA, L.P.  
100 ENERGY BLVD. AT 56 ST, NIAGARA FALLS, NY 14304  
ADDRESS OF INSPECTOR



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M Manual/ECOM

Doc OM-6	Rev. No. 8
Revision Date: 5/8/14	
Review Date: 5/8/14	

## ATTACHMENT 6-13

### RTIF LEAD OPERATOR'S INSPECTION LOG

(TO BE PROVIDED)



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date: 7/12/14	

## SECTION 7

COVANTA NIAGARA, L.P.

NIAGARA RESOURCE RECOVERY FACILITY

MAINTENANCE PLAN



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date: 7/12/14	

## SECTION 7

### COVANTA NIAGARA

- 7.1 Introduction
- 7.2 Covanta Niagara Maintenance Department
- 7.3 Covanta Niagara RTIF Maintenance Department
- 7.4 Work Order System
- 7.5 Scheduled Equipment Outages
- 7.6 Spare Parts
- 7.7 Preventative Maintenance
  - 7.7.1 Instrumentation List
- 7.8 Emergency Contractors
- 7.9 Drawing Inventory
- 7.10 Annual Facility Inspection
- 7.11 Effectiveness of Maintenance Program
- 7.12 Major Equipment Maintenance Manuals
- 7.13 Major Revisions to the Maintenance Plan



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date: 7/12/14	

## SECTION 7

### MAINTENANCE PLAN

#### LIST OF ATTACHMENT

7-1

### EMERGENCY REPAIR VENDORS/CONTRACTORS



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date: 7/12/14	

## SECTION 7

### COVANTA NIAGARA

### MAINTENANCE PLAN

#### 7.1 INTRODUCTION

There are two main types of measures required to achieve the high availability of the Covanta Niagara facility and the Covanta Niagara RTIF. These main areas include:

1. General design criteria require "that the entire Facility will not be shut down due to the failure of a single component or discrete piece of equipment".
2. Maintenance procedures

The Covanta Niagara general design criteria enables the overall facility to continue operating in the event of a failure of a single component or discrete piece of equipment. This is an overall design philosophy that is achieved by implementing installed spare equipment, equipment redundancy, auxiliary system spare capacity, surge capacity at key points within various systems, and if necessary mobile or temporary equipment to replicate the function of systems undergoing repair.

Covanta Niagara's maintenance plan outlines the procedures that are used to ensure facility reliability. The activities of the maintenance plan include three general categories: preventative maintenance, scheduled repairs/major overhauls, and unscheduled repairs. In addition, elements of the maintenance plan include a computerized work order system, stocked spares, special arrangements with key suppliers for expedited spares delivery, on-site maintenance equipment, and offsite maintenance equipment. Stocked spare equipment includes normal consumable materials such as grate bars, wear plates, bearings, motors, actuators, cranes, instruments, and dedicated spares for each major system, and some long lead time items. Special expedited service is available from suppliers of key equipment, which includes boiler tubes, distributed control system components, electrical motor starters, cranes, and other critical components.



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date:7/12/14	

In order to accomplish the activities required in the plan, Covanta Niagara has a maintenance department consisting of two groups: instrument/electrical and mechanical. Contract personnel are also used if specialized skills are required or if the required work load exceeds the maintenance department's ability to adequately staff the work.

## 7.2 COVANTA NIAGARA MAINTENANCE DEPARTMENT

The maintenance manager, who reports to the plant manager, is responsible for the overall function of the maintenance department. Reporting to the maintenance manager are the instrument/electrical supervisor and the mechanical supervisors, and the maintenance planner.

The Instrument/Electrical group consists of a supervisor and Tech 1 through Tech 10 electricians and instrument personnel. The primary function of this group is to maintain the plant's electrical equipment, electrical distribution system, and instrument and control equipment. The group, with supplemental manpower from outside contractors, as necessary, is also responsible for the installation of new equipment.

The mechanical group consists of supervisors and Tech 1 through Tech 3 mechanics. The primary function of this group is to maintain all the mechanical equipment. The group also does installation of new equipment and as with the instrument/electrical group obtains supplemental manpower from outside contractors during periods of higher work loads.

The minimum skills required to obtain a position in the maintenance department are determined by the maintenance manager and the maintenance supervisors. The training programs for skill improvement and advancement within the maintenance group are outlined in Covanta Niagara's personnel Training Plan. Depending on the skill level of personnel (Tech 10, being the most skilled, through Tech 1), Covanta Niagara would expect maintenance personnel, working under the guidance of a supervisor, to be able to read maintenance manuals and prints and to take those manuals, prints, etc. into the field and do preventative maintenance, calibrations, repair work, etc. on equipment.

## 7.3 Covanta Niagara RTIF Maintenance Department

The RTIF Maintenance Department, consisting of Maintenance Mechanics and Container Mechanics, will be directed by the RTIF Superintendent and will be responsible for all





Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date:7/12/14	

onsite maintenance, repair and preservation of rolling equipment, railcars, containers, track, buildings, other structures and equipment. The Maintenance Mechanics are responsible for repairing and refurbishing major parts items. The Maintenance Mechanic in conjunction with the RTIF Superintendent, ensure supplies and materials are ordered for major repairs and ongoing period maintenance, thus having all parts and material ready for use. Container Mechanics will be responsible for preventive maintenance and repairs to the RTIF containers. All RTIF vehicle and equipment maintenance will be conducted in the RTIF building.

#### 7.4 WORK ORDER SYSTEM

A computerized work order system is used by both the Covanta Niagara Maintenance and RTIF Maintenance Departments for all repair work and equipment replacement.

Work orders are given three types of classifications, as follows:

- "3" - Scheduled as operations and normal maintenance work allows. This type of work would also include that to be done during the scheduled outages. In addition, this type of work can also be carried on a back log.
- "2" - Work to be done within 24 hours - is not critical to operation or safety.
- "1" - Emergency work must be done immediately because critical operating equipment or safety issues are involved.

Any Covanta Niagara employee can submit a work order when it is determined that equipment repair or replacement is required. The technician or shift supervisor enters the work order into the computer system where it is initially stored on the "work request" list.

Each morning (Monday thru Friday) operations and maintenance supervision attend a "turnover" meeting at shift change. At that meeting the maintenance work schedule is reviewed for the coming day. Operations supervision reviews the work orders submitted during the night shift and changes the schedule if an "1" (emergency) work order has come in. After the meeting, the maintenance supervisor receives all the new work orders and then issues "1" work orders to maintenance personnel to do the required work. It may be necessary to cancel a job(s) because of the need to get new "1" work orders completed. The outstanding work orders are then in two categories - either in "work



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date:7/12/14	

request list" if no action has been taken, or "backlog list" if parts are on order, or work scheduled and canceled because of higher priority jobs. Those lists are reviewed periodically to assure that the work gets completed.

Each afternoon operations and maintenance supervision attend a "scheduling" meeting to review the progress of the ongoing work and to review the work orders on the "backlog" and "work request" lists. Operations supervision then prioritizes the work for maintenance to do the following day. The maintenance planner will then take the operation's prioritized list and schedule the jobs for the following day. The maintenance planner is responsible for maintaining the computerized work order system to assure that completed work orders are so noted, that the backlog list is updated, and that the "work request" list is periodically reviewed for scheduling.

## 7.5 SCHEDULED EQUIPMENT OUTAGES

During each year Covanta Niagara schedules outages for the boilers, pollution control equipment, ash handling and processing equipment, etc. in order to do preventative maintenance (PM), non-critical repairs, and equipment replacement. Normally each year an annual outage will be taken on each boiler, for approximately 5–15 days, depending on work scopes. The outages on the two boilers are staggered. In addition to the annual outages approximately every 3 months each boiler is taken down for a 2 – 4 day outage in order to clean the boiler and do PM work.

The outages described above are primarily used to work on equipment that otherwise operates continuously. Each outage is planned in advance and specific work done. Both from experience and equipment manufacturers' recommendations, it is known what routine work is required during an outage in order to eliminate/minimize unscheduled downtime. Also, inspections, non-destructive testing, etc. of equipment components can be done during the scheduled outages in order to detect conditions which may require additional work. The additional work would either be done immediately or during a future outage.

## 7.6 SPARE PARTS

Covanta Niagara has an on-site warehouse for the storage of spare parts. Covanta Niagara RTIF will store spare parts at the RTIF building.



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date: 7/12/14	

Spare parts are managed on a computerized inventory maintenance system. All the spare parts are listed in the computer and identified by keywords such as:

- Identification number
- Manufacturer
- Manufacturer's part number
- Equipment that the part is used on
- Minimum/maximum quantity
- Specific warehouse location

When the quantity of a spare part drops below the minimum required to be in storage, the computer automatically generates a requisition to purchase additional items. The materials supervisor is then responsible for ensuring that the order is placed.

When a plant technician needs a part, he uses the plant computer system to access the spare parts inventory list. Keywords such as those listed above are used to find the part. The technician then notes the spare part identification number and the warehouse location. The technician then goes to the warehouse, locates the spare part and then completes a Bin card that is with each spare part. The Bin Card is completed with the technician's name, date, quantity taken and work order number. The Bin Card is then put in a holding box for subsequent reconciliation by warehouse personnel.

Warehouse personnel will enter information from the completed Bin Cards into the computer which will then track the quantity in stock and the need to order additional items.

The determination of which spare parts are kept on hand is based on several factors:

- How critical is the equipment to operation?
- Is there installed spare capacity available?
- Delivery time for parts - i.e. off-the-shelf from local supplier, long lead time, etc.
- Type of failure likely:
  - Gradually wear out - allows time to order spares



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date: 7/12/14	

- fail suddenly
- Likelihood of failure

## 7.7 PREVENTATIVE MAINTENANCE

Covanta Niagara's and Covanta Niagara's RTIF preventative maintenance (PM) program includes inspections and maintenance on equipment critical to the operations of the facility, calibrations of instrument/control equipment, and calibration and maintenance of monitoring equipment required by regulations and permits. In most cases, equipment manufacturers will have a suggested preventative maintenance schedule. The PM system is computerized and works as follows:

- Equipment identification, tasks required, and frequency (starting with input date) are put into the computer.
- Every two weeks, the maintenance planner prints out the PM list, as well as a work order to go with the PMs for that week.
- The maintenance planner issues the work orders to the appropriate mechanical or instrument/electrical supervisor.
- The work order "backlog" list which has the open PM jobs is reviewed by the maintenance planner on a periodic basis.
- When a work order is completed, it is marked **completed** and returned to the maintenance planner who inputs a completed status into the computer for that work order.
- Any PM that is not completed will remain on the work order backlog list until completed.

### 7.7.1 INSTRUMENTATION LIST



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date: 7/12/14	

All of the DBA plant instrumentation has been entered into a computer program "Shop Access" that can be accessed through the Covanta Niagara computer network.

With each instrument entered into the computer system, all pertinent information related to the instrument is included, such as, tag number, equipment description, location, P & ID reference, termination locations (field, DCS, PLC, etc.), calibration data, calibration schedule, etc.

After an instrument calibration is completed, a hard copy computer printout with calibration data is placed into the appropriate equipment file.

In addition to the computer system, a hard copy of the instrument manufacturers data sheet is kept in an instrument book.

## 7.8 EMERGENCY CONTRACTORS

Covanta Niagara uses many equipment vendors and service contractors. Many of these vendors/contractors are on 24 hour call and can respond to emergency situations. A list of the emergency repair vendors/contractors with purchase order agreements is shown in Attachment 7-1.

## 7.9 DRAWING INVENTORY

The plant engineering group is responsible for keeping a complete inventory of original design and as-built drawings that pertain to the Covanta Niagara facility. The drawings are kept in the plant's administration building in the drafting room. Engineering drawings are on computer disk. To ensure secure backup of the drawings, periodically the drawings on the computer disks are transferred onto a CD ROM. When an engineering drawing needs to be modified, the appropriate disk is put into the computer, the drawing pulled up on the screen, the changes made, the drawing is given a revision number, and drawing saved. A drawing index is kept both in the computer and as a hard copy in a notebook. Prints of engineering drawings may also be kept in a flat file.

Vendor/subcontractor prints are kept in a flat file. There is also a vendor/subcontractor drawing index.

## 7.10 ANNUAL FACILITY INSPECTION

*Printed copies are not document controlled, refer to "S" drive, ISO 14001 Environmental Management Systems file for latest approved version*  
*Page 10 of 15*



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date:7/12/14	

As required in 6 NYCRR Part 360-3(h) (6), Covanta Niagara completes an annual inspection of the facility by an engineer licensed in New York State. The inspection, completed once each calendar year, is to ensure that the facility is being operated in accordance with all the plans developed to comply with the Part 360 regulations. In addition, the inspection ensures that the facility is in good operating condition to provide worker safety, environmental compliance, and reliability.

### 7.11 EFFECTIVENESS OF MAINTENANCE PROGRAM

The effective maintenance program at Covanta Niagara has resulted in a very reliable facility. Major outages continue to be scheduled each year in order to replace/ repair worn equipment.

### 7.12 MAJOR EQUIPMENT MAINTENANCE MANUALS

A copy of the major equipment manuals will be kept in the drafting room in the plant's administration building and a copy of the RTIF equipment manuals will be kept in the RTIF building.

### 7.13 MAJOR REVISIONS TO THE MAINTENANCE PLAN

May 2006

Name change to Covanta from American Ref-Fuel

March 2014

Removed maintenance attachments. Actual equipment information, operating manuals, work schedules, and preventative maintenance programs are available in the maintenance supervisor, chief engineer's, and plant engineer's office.

May 2014

Add Section 7.3 – Covanta Niagara RTIF Maintenance Department. Revise the section numbers accordingly. Update 7.4 – Work Order System. Update 7.6 – Spare Parts.



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date:7/12/14	

Update 7.7 – Preventative Maintenance. Additions to Attachment 7-1 – Emergency Repair Vendors/Contractors. Update 7.12 – Major Equipment Maintenance Manuals.

July 2014

Minor QA/QC edits. Update to Section 7.3.



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date: 7/12/14	

## ATTACHMENT 7-1

### EMERGENCY REPAIR VENDORS/CONTRACTORS





Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date: 7/12/14	

**VENDOR/CONTRACTOR**

Volland Electric  
Andersen Electric  
Belt Maintenance  
DWC Mechanical  
Airgas East  
OTIS  
Davis-Ulmer Sprinkler  
Gaines Electrical Contractors  
Grainger, W. W.  
Morris Material  
National Vac  
IDS Div/Lake Supply  
Motion Industrial  
NERM / Covanta Field Services  
Zampell Refractories  
Upstate Steel  
Stritt & Priebe  
Tonawanda Machine  
R. B. U'Ren Equipment  
Weber Hydraulic  
Brights Systems / National Maintenance  
North American Industrial Services  
Milton Caterpillar

**ITEM/SERVICE**

Repair/Balance Rotating Equipment  
Electrical Supplies  
Belt Supply and Repair  
HVAC  
Welding Supplies  
Elevator Repair  
Fire System Repair  
Electrical Contractor  
Mill Supplies  
Crane Repair  
Vacuum Trucks and Water Wash  
Pipe, Valves & Fittings  
Power Transmission  
Boiler Repair  
Refractory Repair  
Steel Fabrication & Supply  
Valve Supply and Repair  
Fabrication and machining  
Equipment Rentals  
Hydraulics  
Mechanical Repairs  
Boiler Blasting  
Mobile Service Repairs



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA

O&M/ECOM Manual

Doc OM-7	Rev. No. 5
Revision Date: 7/12/14	
Reviewed Date:7/12/14	

LiftTech Equipment

Valley Tire

CSXT

Forktruck, and Reach Stacker Maintenance

Tire Service

Rail Maintenance and Repairs



Powering Today. Protecting Tomorrow.

COVANTA NIAGARA  
O&M/ECOM Manual

Doc OM-8	Rev. No. 9
Revision Date: 5/22/14	
Review Date: 5/22/14	

## SECTION 8

COVANTA NIAGARA, L.P.

NIAGARA RESOURCE RECOVERY FACILITY

**START-UP, SHUT-DOWN, AND MALFUNCTION PROCEDURES**