

# CATOR, RUMA & ASSOCIATES, Co.

1 of 1

CONSULTING MECHANICAL/ELECTRICAL ENGINEERS  
896 TABOR STREET • LAKEWOOD, COLORADO 80401  
(303) 232-6200 • FAX (303) 233-3701

Construction Shop Drawings Transmittal Date **October 19, 2012**

To: **Davis Partnership Architects**

**Electronic Submittal**

Attn: **Brent Murphy**

Project: **EPMC – MRI CT Addition**

Cator, Ruma & Assoc. Project No.: **2011-233**

Cator, Ruma & Assoc. Tracking No.: **12.2442**

NOTE: The Engineer's review of these shop drawings does not relieve the Contractor of his responsibility to comply with drawings or specifications. Any deviation from specified equipment or material must be called to the Engineer's attention in writing at the time of submission. The Contractor must secure written acceptance for said deviations.

Item & Section Number	Copies *	Manufacturer	No Exception Taken	Make Corrections Noted	Rejected	Revise And Resubmit	Submit Specified Item
<b>233600</b>							
<b>Air Terminals</b>	<b>1</b>	<b>Krueger</b>	<b>X</b>				

Remarks: **No Exception Taken to submitted items.**

\* We have retained one copy of each of the above items for our records.

CATOR, RUMA & ASSOCIATES, Co.

Bob Lazzaro



Davis Partnership Architects | 2301 Blake St. STE 100 Denver, CO 80208-2108 US

**Electronic Submittal**

# Submittal Transmittal

**Transmittal ID:** 00092  
**Date Sent:** 10/16/2012

**Project:** EPMC - MRI CT Addition  
**Number:** 12910.00.000  
**To:** Kelvin Doss  
Cator, Ruma & Associates  
896 Tabor St.  
Lakewood, CO 80401  
303.232.6200 (Phone)  
303.233.3701 (Fax)

Submittal Management  
Cator Ruma & Associates  
896 Tabor Street  
Lakewood, CO 80401-4700  
303-232-6200 (Phone)

**From:** BRENT MURPHY  
Davis Partnership Architects  
2301 Blake St.  
STE 100  
Denver, CO 80208-2108  
US  
303-861-8555x2592 (Phone)  
303-861-3027 (Fax)

**Subject:** 233600-01 - Air Terminals  
**Sent Via:** Info Exchange  
**Submittal ID:**  
**Return By:** 10/23/2012  
**Specification Section:**  
**Purpose:** For Review  
**Remarks:** Brent,  
For your review and approval.  
Rebecca

See Consultant Review Action

This submittal has been reviewed by Davis Partnership, P.C., where applicable, for conformance to architectural requirements, and has been reviewed by consultant(s) to Davis Partnership, P.C. for conformance with the design concept of the Project and compliance with the information given in the Contract Documents. Contractor is responsible for dimensions to be confirmed and correlated at the job site; for information that pertains solely to the fabrication processes or to techniques of construction; and for coordination of the work of all trades. Refer to comments noted on the Consultant(s) review stamp(s) for further action.

**DAVIS PARTNERSHIP, P.C., ARCHITECTS**

Date 10/22/2012 By BJM

**CC:**

**Contents**

Quantity: 1 Dated: 10/16/2012 Number:  
Description:  
EPMC Air terminals 233600 2.2.pdf  
Action:  
Remarks:

<b>RECEIVED</b> Cator, Ruma Assoc. 10/17/12	
<b>Tracking #</b>	<b>12.2442</b>
<b>CRA Project #</b>	<b>2011-233</b>



5995 Greenwood Plaza Blvd.  
 Suite 100  
 Greenwood Village, CO 80111-4710  
 303-571-5377  
 303-629-7467 (fax)

**TRANSMITTAL**  
**No. 12D1137-0061**

**PROJECT:** EPMC-Imaging Addition MRI and CT

**DATE:** 10/16/2012

**TO:** Davis Partnership PC Arch  
 2301 Blake St #100  
 Denver CO 80205-2108

**RE:** Air terminals

**ATTN:** Brent Murphy

**JOB:** 12D1137

**Ph/Fax:** 303-861-8555

WE ARE SENDING:	SUBMITTED FOR:	ACTION TAKEN:
<input type="checkbox"/> Shop Drawings	<input type="checkbox"/> Approval	<input type="checkbox"/> Approved as Submitted
<input type="checkbox"/> Letter	<input type="checkbox"/> Your Use	<input type="checkbox"/> Approved as Noted
<input type="checkbox"/> Prints	<input type="checkbox"/> As Requested	<input type="checkbox"/> Returned After Loan
<input type="checkbox"/> Change Order	<input type="checkbox"/> Review and Comment	<input type="checkbox"/> Resubmit
<input type="checkbox"/> Plans		<input type="checkbox"/> Submit
<input type="checkbox"/> Samples	<b>SENT VIA:</b>	<input type="checkbox"/> Returned
<input type="checkbox"/> Specifications / Product Data	<input type="checkbox"/> Attached	<input type="checkbox"/> Returned for Corrections
<input type="checkbox"/> Other:	<input type="checkbox"/> Separate Cover Via:	<input checked="" type="checkbox"/> Due Date: 10/16/2012

**NOTES:**

<i>Item</i>	<i>Package</i>	<i>Code</i>	<i>Rev.</i>	<i>Copies</i>	<i>Date</i>	<i>Description</i>	<i>Status</i>
Submittal	15110	233600.01	1	1	10/16/2012	Air terminals	New Item

**CC:**

**Signed:** \_\_\_\_\_  
 Rebecca Terrazas



# Submittal Stamp Sheet

**Project:** EPMC  
**Phipps' Job #:** 12D1137  
**Submittal #:** 233600 **Date:** 10-16-12

<p>GH Phipps.:</p> <p style="text-align: center;"><b>SUBMITTED</b>  <b>GH Phipps</b>  <i>Construction Companies</i></p> <p>GH Phipps has reviewed, approved, and hereby submits the attached in accordance with the contract documents.</p> <p>Note to Subcontractor/Material Supplier:          Subcontractor/Material Supplier remains responsible for the confirmation and correlation of dimensions at the jobsite; fabrication processes and construction techniques; coordination of the work with the work of other trades; and satisfactory performance of the work.</p>	<p>Architect:</p>
<p>Engineer:</p> <p>           No Exception Taken <input checked="" type="checkbox"/>    Make Corrections Noted <input type="checkbox"/>            Rejected <input type="checkbox"/>    Revise and Resubmit <input type="checkbox"/>            Submit Specified Item <input type="checkbox"/> </p> <p style="font-size: small; color: red;">CHECKING IS ONLY FOR GENERAL CONFORMANCE WITH THE DESIGN CONCEPT OF THE PROJECT AND GENERAL COMPLIANCE WITH THE INFORMATION GIVEN IN THE CONTRACT DOCUMENTS. ANY ACTION SHOWN IS SUBJECT TO THE REQUIREMENTS OF THE PLANS AND SPECIFICATIONS. CONTRACTOR IS RESPONSIBLE FOR: DIMENSIONS WHICH SHALL BE CONFIRMED AND CORRELATED AT THE JOB SITE; FABRICATION PROCESSES AND TECHNIQUES OF CONSTRUCTION; COORDINATION OF HIS WORK WITH THAT OF ALL OTHER TRADES; AND THE SATISFACTORY PERFORMANCE OF HIS WORK.</p> <p style="text-align: center; font-size: x-small;">CATOR, RUMA &amp; ASSOCIATES, CO.          Consulting Mechanical/Electrical Engineers          Lakewood, Colorado 80401 (303) 232-6200</p> <p><b>Date:</b> 10/19/12    <b>By:</b> Bob Lazzaro</p> <hr style="width: 50%; margin-left: 0;"/> <p style="font-size: x-small; color: red;">REVIEW DOES NOT INCLUDE SIZES OR QUANTITIES</p>	<p>Other:</p>

**NOTES:** HVAC Air Terminal

Signed: Rebecca T Terrazas  
 GH Phipps Representative



2669 E. Hwy 224•Denver, CO 80229•303-288-4546•FAX: 303-289-5756

## SUBMITTAL

DATE: August 21, 2012

---

<b>JOB NO:</b>	12-100
<b>PROJECT:</b>	Estes Park Medical Center MRI / CT Addition
<b>GENERAL CONTRACTOR:</b>	GH Phipps
<b>ARCHITECT:</b>	Davis Partnership Architects
<b>MECH. ENGINEER:</b>	Cator Ruma & Associates
<b>SUPPLIER:</b>	Parker Sheet Metal
<b>SUBMITTAL NO:</b>	03
<b>SPECIFICATION:</b>	233600 – Air Terminal Units
<b>PARAGRAPH:</b>	2.2



BUILDING ENVIRONMENTS

*Technology for  
Better Buildings*

## EQUIPMENT SUBMITTAL

<b>PROJECT</b>	<b>Estes Park Medical Center MRI/CT Addition</b>
<b>ARCHITECT</b>	
<b>ENGINEER</b>	<b>Cator Ruma &amp; Associates, Inc.</b>
<b>CONTRACTOR</b>	<b>Parker Sheet Metal</b>
<b>ITEM</b>	<b>VAV's</b>
<b>MANUFACTURER</b>	<b>Krueger</b>
<b>SUBMITTED BY</b>	<b>LONG Building Environments – Jonathan Bliss</b>

Equipment will not be released for production until formal approval is received.

**DATE: August 13, 2012**

**Tag:** \*Priced at 5,280 Feet with 30% Glycol

**VAV-2-1**

**VAV-2-2**

**VAV-2-3**

**VAV-2-4**

**VAV-2-5**

### Single Duct Terminal Unit Schedule

Tag	Model	Size		CFM		Static Pressure			NC Levels		Hot Water Heat Coil									
		Unit	Outlet	Max	Min	Inlet	Down	Min	Rad.	Disch.	CFM	MBH	EAT	LAT	APd	GPM	EWT	LWT	WPd	Rows
VAV-2-01	LMHS	09	14x12	1,050	300	1.00	0.25	0.29	20	14	300	10.9	55	96	0.20	0.8	180.0	149.1	0.10	1
VAV-2-02	LMHS	08	12x10	800	150	1.00	0.25	0.33	21	15	150	6.8	55	106	0.24	0.5	180.0	149.1	0.20	1
VAV-2-03	LMHS	08	12x10	800	150	1.00	0.25	0.33	21	15	150	6.8	55	106	0.24	0.5	180.0	149.1	0.20	1
VAV-2-04	LMHS	14	20x17	3,000	660	1.00	0.25	0.51	22	20	660	20.3	55	90	0.37	1.0	180.0	133.8	0.10	1
VAV-2-05	LMHS	12	16x15	2,000	500	1.00	0.25	0.46	22	16	500	16.9	55	93	0.36	1.2	180.0	147.9	0.40	1

- Notes:
1. Room NC level shown includes attenuation transfer functions obtained from tables in AHRI Standard 885.
  2. Sound data shall be obtained from tests conducted in accordance with AHRI Standard 880.
  3. Selections based upon Krueger as Manufacturer.
  4. Dimensions are for base product only. Check submittal drawings for exact dimensions.
  5. Size units are given in inches, flows units are cubic feet per minute, pressure units are inches of water, and temperature units are degrees fahrenheit.

<b>Project:</b>	<b>Tag: VAV-2-05</b>
-----------------	----------------------

Project Location:

Altitude: 5,280.0 Feet

File: Estes Park Medical Center MRI-CT.kec

User:

Room:

**Selection**

Quantity	Model	Size		CFM			Static			Max NC Levels	
		Unit	Outlet	Max.	Min.	Heating	Inlet	Down	Min.	Rad.	Disch.
1	LMHS	12	16x15	2,000	500	500	1.00	0.25	0.46	22	16

- Notes: 1. See below for PWL calculations used to obtain Max NC rating.  
 2. Outlet size is approximate and does not include coil dimensions. See submittal drawings for exact dimensions.

**Hot Water Heating Coil Performance**

MBH	Coil CFM	EAT / LAT	APd	GPM	EWT /LWT	WPd	Rows	Conn.	% Glycol
16.9	500	55 / 93	0.4	1.20	180.0 / 147.9	0.40	1	RH	30%

Coil Selection Method: 6-Solve for heat at desired water flow, rows (Straight Calculation)

**Other Information**

Maximum CFM:	2,263
Design CFM:	2,000
Safety Factor:	12%
Unit LxWxH:	40 x 16 x 15in.
Controls:	

**Accessories**

Outlet: Attenuator
Lining: 1-1" liner
Heating Coil: Hot Water
Attenuator: Yes

**Acoustic Summary**

Sound Description	Radiated Sound PWL						NC	Discharge Sound PWL						NC	Standard
	2	3	4	5	6	7		2	3	4	5	6	7		
Primary Sound	60	53	47	42	38	30		66	59	54	44	43	42		
Total Attenuation	18	19	20	26	31	36		29	30	41	51	52	39		885-08,E
Room Sound Level	42	34	27	16	-	-	22	37	29	13	-	-	-	16	

- Notes: 1. Room sound levels shown include attenuation transfer functions shown above.  
 2. Data were obtained from tests conducted in accordance with AHRI Standard 880.  
 3. Sound power levels are in decibels, re 10<sup>-12</sup> watts.  
 4. Dash (-) in space indicates sound and NC value is less than 10.

The results of this program are only an aid to the designer, and are not a substitute for professional design services.  
 Krueger accepts no liability for the adequacy of any resulting design or installation.  
 All data subject to change without notice.



Project: **Tag: VAV-2-04**

Project Location:

Altitude: 5,280.0 Feet  
 File: Estes Park Medical Center MRI-CT.kec  
 User:  
 Room:

**Selection**

Quantity	Model	Size		CFM			Static			Max NC Levels	
		Unit	Outlet	Max.	Min.	Heating	Inlet	Down	Min.	Rad.	Disch.
1	LMHS	14	20x17.5	3,000	660	660	1.00	0.25	0.51	22	20

- Notes: 1. See below for PWL calculations used to obtain Max NC rating.  
 2. Outlet size is approximate and does not include coil dimensions. See submittal drawings for exact dimensions.

**Hot Water Heating Coil Performance**

MBH	Coil CFM	EAT / LAT	APd	GPM	EWT /LWT	WPd	Rows	Conn.	% Glycol
20.3	660	55 / 90	0.4	1.00	180.0 / 133.8	0.10	1	RH	30%

Coil Selection Method: 6-Solve for heat at desired water flow, rows (Straight Calculation)

**Other Information**

Maximum CFM:	3,081
Design CFM:	3,000
Safety Factor:	3%
Unit LxWxH:	40 x 20 x 18in.
Controls:	

**Accessories**

Outlet: Attenuator
Lining: 1-1" liner
Heating Coil: Hot Water
Attenuator: Yes

**Acoustic Summary**

Sound Description	Radiated Sound PWL						NC	Discharge Sound PWL						NC	Standard
	2	3	4	5	6	7		2	3	4	5	6	7		
Primary Sound	58	52	48	43	40	33		69	62	59	49	46	45		
Total Attenuation	18	19	20	26	31	36		29	30	41	51	52	39		885-08,E
Room Sound Level	40	33	28	17	-	-	22	40	32	18	-	-	-	20	

- Notes: 1. Room sound levels shown include attenuation transfer functions shown above.  
 2. Data were obtained from tests conducted in accordance with AHRI Standard 880.  
 3. Sound power levels are in decibels, re 10<sup>-12</sup> watts.  
 4. Dash (-) in space indicates sound and NC value is less than 10.

The results of this program are only an aid to the designer, and are not a substitute for professional design services.  
 Krueger accepts no liability for the adequacy of any resulting design or installation.  
 All data subject to change without notice.

<b>Project:</b>	<b>Tag: VAV-2-03</b>
-----------------	----------------------

Project Location:

Altitude: 5,280.0 Feet  
 File: Estes Park Medical Center MRI-CT.kec  
 User:  
 Room:

**Selection**

Quantity	Model	Size		CFM			Static			Max NC Levels	
		Unit	Outlet	Max.	Min.	Heating	Inlet	Down	Min.	Rad.	Disch.
1	LMHS	08	12x10	800	150	150	1.00	0.25	0.33	21	15

- Notes: 1. See below for PWL calculations used to obtain Max NC rating.  
 2. Outlet size is approximate and does not include coil dimensions. See submittal drawings for exact dimensions.

**Hot Water Heating Coil Performance**

MBH	Coil CFM	EAT / LAT	APd	GPM	EWT /LWT	WPd	Rows	Conn.	% Glycol
6.8	150	55 / 106	0.2	0.50	180.0 / 149.1	0.20	1	RH	30%

Coil Selection Method: 6-Solve for heat at desired water flow, rows (Straight Calculation)

**Other Information**

Maximum CFM:	1,006
Design CFM:	800
Safety Factor:	20%
Unit LxWxH:	40 x 12 x 10in.
Controls:	

**Accessories**

Outlet: Attenuator
Lining: 1-1" liner
Heating Coil: Hot Water
Attenuator: Yes

**Acoustic Summary**

Sound Description	Radiated Sound PWL							NC	Discharge Sound PWL							NC	Standard
	2	3	4	5	6	7	2		3	4	5	6	7				
Primary Sound	59	52	41	37	31	29		62	59	47	38	33	32				
Total Attenuation	18	19	20	26	31	36		29	30	41	51	52	39		885-08,E		
Room Sound Level	41	33	21	11	-	-	21	33	29	-	-	-	-	15			

- Notes: 1. Room sound levels shown include attenuation transfer functions shown above.  
 2. Data were obtained from tests conducted in accordance with AHRI Standard 880.  
 3. Sound power levels are in decibels, re 10<sup>-12</sup> watts.  
 4. Dash (-) in space indicates sound and NC value is less than 10.

The results of this program are only an aid to the designer, and are not a substitute for professional design services.  
 Krueger accepts no liability for the adequacy of any resulting design or installation.  
 All data subject to change without notice.

<b>Project:</b>	<b>Tag: VAV-2-02</b>
-----------------	----------------------

Project Location:

Altitude: 5,280.0 Feet

File: Estes Park Medical Center MRI-CT.kec

User:

Room:

**Selection**

Quantity	Model	Size		CFM			Static			Max NC Levels	
		Unit	Outlet	Max.	Min.	Heating	Inlet	Down	Min.	Rad.	Disch.
1	LMHS	08	12x10	800	150	150	1.00	0.25	0.33	21	15

- Notes: 1. See below for PWL calculations used to obtain Max NC rating.  
 2. Outlet size is approximate and does not include coil dimensions. See submittal drawings for exact dimensions.

**Hot Water Heating Coil Performance**

MBH	Coil CFM	EAT / LAT	APd	GPM	EWT /LWT	WPd	Rows	Conn.	% Glycol
6.8	150	55 / 106	0.2	0.50	180.0 / 149.1	0.20	1	RH	30%

Coil Selection Method: 6-Solve for heat at desired water flow, rows (Straight Calculation)

**Other Information**

Maximum CFM:	1,006
Design CFM:	800
Safety Factor:	20%
Unit LxWxH:	40 x 12 x 10in.
Controls:	

**Accessories**

Outlet: Attenuator
Lining: 1-1" liner
Heating Coil: Hot Water
Attenuator: Yes

**Acoustic Summary**

Sound Description	Radiated Sound PWL							NC	Discharge Sound PWL							NC	Standard
	2	3	4	5	6	7	2		3	4	5	6	7				
Primary Sound	59	52	41	37	31	29		62	59	47	38	33	32				
Total Attenuation	18	19	20	26	31	36		29	30	41	51	52	39		885-08,E		
Room Sound Level	41	33	21	11	-	-	21	33	29	-	-	-	-	15			

- Notes: 1. Room sound levels shown include attenuation transfer functions shown above.  
 2. Data were obtained from tests conducted in accordance with AHRI Standard 880.  
 3. Sound power levels are in decibels, re 10<sup>-12</sup> watts.  
 4. Dash (-) in space indicates sound and NC value is less than 10.

The results of this program are only an aid to the designer, and are not a substitute for professional design services.  
 Krueger accepts no liability for the adequacy of any resulting design or installation.  
 All data subject to change without notice.

<b>Project:</b>	<b>Tag: VAV-2-01</b>
-----------------	----------------------

Project Location:  
 Altitude: 5,280.0 Feet  
 File: Estes Park Medical Center MRI-CT.kec  
 User:  
 Room:

**Selection**

Quantity	Model	Size		CFM			Static			Max NC Levels	
		Unit	Outlet	Max.	Min.	Heating	Inlet	Down	Min.	Rad.	Disch.
1	LMHS	09	14x12.5	1,050	300	300	1.00	0.25	0.29	20	14

- Notes: 1. See below for PWL calculations used to obtain Max NC rating.  
 2. Outlet size is approximate and does not include coil dimensions. See submittal drawings for exact dimensions.

**Hot Water Heating Coil Performance**

MBH	Coil CFM	EAT / LAT	APd	GPM	EWT /LWT	WPd	Rows	Conn.	% Glycol
10.9	300	55 / 96	0.2	0.80	180.0 / 149.1	0.10	1	RH	30%

Coil Selection Method: 6-Solve for heat at desired water flow, rows (Straight Calculation)

**Other Information**

Maximum CFM:	1,273
Design CFM:	1,050
Safety Factor:	18%
Unit LxWxH:	40 x 14 x 13in.
Controls:	

**Accessories**

Outlet: Attenuator
Lining: 1-1" liner
Heating Coil: Hot Water
Attenuator: Yes

**Acoustic Summary**

Sound Description	Radiated Sound PWL						NC	Discharge Sound PWL						NC	Standard
	2	3	4	5	6	7		2	3	4	5	6	7		
Primary Sound	56	49	46	38	34	26		62	58	50	40	36	36		
Total Attenuation	18	19	20	26	31	36		29	30	41	51	52	39		885-08,E
Room Sound Level	38	30	26	12	-	-	20	33	28	-	-	-	-	14	

- Notes: 1. Room sound levels shown include attenuation transfer functions shown above.  
 2. Data were obtained from tests conducted in accordance with AHRI Standard 880.  
 3. Sound power levels are in decibels, re 10<sup>-12</sup> watts.  
 4. Dash (-) in space indicates sound and NC value is less than 10.


The results of this program are only an aid to the designer, and are not a substitute for professional design services.  
 Krueger accepts no liability for the adequacy of any resulting design or installation.  
 All data subject to change without notice.

JOB NAME \_\_\_\_\_  
 ARCHITECT \_\_\_\_\_  
 ENGINEER \_\_\_\_\_  
 CONTRACTOR \_\_\_\_\_  
 LOCATION \_\_\_\_\_

**SUBMITTAL SHEET**  
 Form Number TS0021.2 Effective Date 7/04  
 Replaces FORM TS0021.1



**LMHS**  
**ATTENUATOR UNIT WITH HOT WATER HEAT – NO CONTROLS**



**STANDARD FEATURES:**

- 22 Ga. Zinc coated steel construction.
- 1/2" dia shaft extending from the unit casing .
- 1/2" thick dual density fiberglass insulation meeting **NFPA 90A** and **UL 184** safety requirements.
- Linear averaging sensor.
- Hot water coils. See form TS0005 for dimensions and specifications
- Field installation of controls

**NOTE:** Right hand configuration shown, left hand available.

**OPTIONAL FEATURES:**

- 20 Ga. Zinc coated steel construction
- Liners:
  - Cellular insulation
  - Steriliner
  - Sterilwall
  - Perf double wall
  - 1" dual density fiberglass insulation
- Four quadrant averaging cross flow sensor
- Left hand control.
- Right hand control.
- Left hand water coil connection
- Right hand water coil connection.
- Bottom access panel
- Hanger brackets.
- Cam lock bottom access panel

**DIMENSIONS ARE GIVEN AS INCHES (MM)**

**LMHS ATTENUATOR UNIT WITH HOT WATER REHEAT**

INLET SIZE	NOM MAX CFM (L/S)	W	H	A	B	D	Lc
<del>4</del>	<del>230 (109)</del>	<del>12 (305)</del>	<del>8 (203)</del>	<del>5 3/8 (136)</del>	<del>1 1/2 (38)</del>	<del>3 7/8 (98)</del>	SEE FORM TS0005
<del>5</del>	<del>360 (170)</del>	<del>12 (305)</del>	<del>8 (203)</del>	<del>5 3/8 (136)</del>	<del>1 1/2 (38)</del>	<del>4 7/8 (124)</del>	
<del>6</del>	<del>520 (245)</del>	<del>12 (305)</del>	<del>8 (203)</del>	<del>3 3/8 (86)</del>	<del>1 1/2 (38)</del>	<del>5 7/8 (149)</del>	
<del>7</del>	<del>710 (335)</del>	<del>12 (305)</del>	<del>10 (254)</del>	<del>3 3/8 (86)</del>	<del>1 1/2 (38)</del>	<del>6 7/8 (175)</del>	
8	925 (437)	12 (305)	10 (254)	3 3/8 (86)	1 1/2 (38)	7 7/8 (200)	
9	1200 (566)	14 (356)	12 1/2 (318)	3 3/8 (86)	2 1/2 (64)	8 7/8 (225)	
10	1450 (685)	14 (356)	12 1/2 (318)	3 3/8 (86)	2 1/2 (64)	9 7/8 (251)	
12	2100 (991)	16 (406)	15 (381)	3 3/8 (86)	3 1/2 (89)	11 7/8 (302)	
14	2900 (1369)	20 (508)	17 1/2 (445)	3 3/8 (86)	5 1/2 (140)	13 7/8 (352)	
<del>16</del>	<del>3700 (1746)</del>	<del>24 (610)</del>	<del>18 (457)</del>	<del>3 3/8 (86)</del>	<del>7 1/2 (191)</del>	<del>15 7/8 (403)</del>	
22	7100 (3351)	38 (965)	18 (457)	4 1/4 (108)	14 1/2 (368)	SEE ABOVE	


JOB NAME \_\_\_\_\_  
 ARCHITECT \_\_\_\_\_  
 ENGINEER \_\_\_\_\_  
 CONTRACTOR \_\_\_\_\_  
 LOCATION \_\_\_\_\_

**SUBMITTAL SHEET**  
 Form Number TS0005.5 Effective Date 11/03  
 Replaces FORM TS0005.4



## LMHS HOT WATER COILS

### With Hot Water Reheat



LMHS coils are shipped from the factory attached to the unit discharge. Coil discharge is configured for slip and drive field ductwork installation. Coil section is uninsulated.

CONNECTION TUBING – 0.032" thick copper. Refer to connection diameter shown in table below.  
 COIL CASING – 20 Ga. Galvanized steel.  
 COIL TUBING – 1/2" diameter x 0.016" thick copper.  
 COIL FINS – 0.0045" thick aluminum, 10 per inch, mechanically bonded to tubing.  
 COIL ACCESSORIES:

- Optional air vent and water drain

LMHS SIZE		H	W	Lc	A	B	C	WATER CONNECTION
4,5,6	1 ROW	8(203)	12(304)	5(127)	3(76)	6 1/4(159)	-	1/2(13)
	2 ROW	8(203)	12(304)	5(127)	4 1/4(108)	6 7/8(175)	1 1/8(29)	7/8(22)
	3 ROW	8(203)	12(304)	7 1/4(184)	4 1/4(108)	6 7/8(175)	2 1/8(54)	7/8(22)
	4 ROW	8(203)	12(304)	7 1/4(184)	4 1/4(108)	6 7/8(175)	3 1/4(83)	7/8(22)
7,8	1 ROW	10(254)	12(304)	5(127)	3(76)	8 3/4(222)	-	1/2(13)
	2 ROW	10(254)	12(304)	5(127)	4 1/4(108)	9(229)	1 1/8(29)	7/8(22)
	3 ROW	10(254)	12(304)	7 1/4(184)	4 1/4(108)	9(229)	2 1/8(54)	7/8(22)
	4 ROW	10(254)	12(304)	7 1/4(184)	4 1/4(108)	9(229)	3 1/4(83)	7/8(22)
9,10	1 ROW	12 1/2(317)	14(356)	5(127)	4 1/4(108)	10 7/8(276)	1 1/4(32)	7/8(22)
	2 ROW	12 1/2(317)	14(356)	5(127)	4 1/4(108)	11 1/2(292)	1 1/8(29)	7/8(22)
	3 ROW	12 1/2(317)	14(356)	7 1/4(184)	4 1/4(108)	10 1/4(260)	2 1/8(54)	7/8(22)
	4 ROW	12 1/2(317)	14(356)	7 1/4(184)	4 1/4(108)	10 1/4(260)	3 1/4(83)	7/8(22)
12	1 ROW	15(381)	16(406)	5(127)	4 1/4(108)	13 3/4(349)	1 1/4(32)	7/8(22)
	2 ROW	15(381)	16(406)	5(127)	4 1/4(108)	13 3/4(349)	1 1/8(29)	7/8(22)
	3 ROW	15(381)	16(406)	7 1/4(184)	4 1/4(108)	14(356)	2 5/8(67)	7/8(22)
	4 ROW	15(381)	16(406)	7 1/4(184)	4 1/4(108)	14(356)	3 1/4(83)	7/8(22)
14	1 ROW	17 1/2(445)	20(508)	7 1/2(191)	4 1/4(108)	15 7/8(403)	1 1/4(32)	7/8(22)
	2 ROW	17 1/2(445)	20(508)	7 1/2(191)	4 1/4(108)	16 1/2(419)	1 1/8(29)	7/8(22)
	3 ROW	17 1/2(445)	20(508)	9 3/4(248)	4 1/4(108)	14(356)	2 1/8(54)	7/8(22)
	4 ROW	17 1/2(445)	20(508)	9 3/4(248)	4 1/4(108)	14(356)	3 1/4(83)	7/8(22)
16	1 ROW	18(457)	24(609)	7 1/2(191)	4 1/4(108)	15 7/8(403)	1 1/4(32)	7/8(22)
	2 ROW	18(457)	24(609)	7 1/2(191)	4 1/4(108)	16 1/2(419)	1 1/8(29)	7/8(22)
	3 ROW	18(457)	24(609)	9 3/4(248)	4 1/4(108)	14(356)	2 1/8(54)	7/8(22)
	4 ROW	18(457)	24(609)	9 3/4(248)	4 1/4(108)	14(356)	3 1/4(83)	7/8(22)
22	1 ROW	18(457)	38(965)	5(127)	3 5/8(92)	15 7/8(403)	1 5/16(33)	7/8(22)
	2 ROW	18(457)	38(965)	5(127)	3 5/8(92)	16 1/2(419)	1 3/32(27)	7/8(22)
	3 ROW	18(457)	38(965)	7 1/4(184)	3 5/8(92)	14(356)	2 5/32(54)	7/8(22)
	4 ROW	18(457)	38(965)	7 1/4(184)	3 5/8(92)	14(356)	3 1/4(82)	7/8(22)