

**DISTRICT BOARD**

Megan Clark  
Rabi Elias  
Russ Greenfield  
Craig K. Murray  
Judy Schriebman

**DISTRICT ADMINISTRATION**

Mark R. Williams,  
General Manager  
Michael Cortez,  
District Engineer  
Mel Liebmann,  
Plant Manager  
Susan McGuire,  
Administrative Services Manager  
Greg Pease,  
Collection System/Safety Manager

**ADDENDUM NO. 5**

Date: February 27, 2015  
Project: **Plant Improvements 2015 Phase 1**  
Job No.: 12600-02

To: All Planholders and Prospective Bidders

The following changes and/or clarifications are hereby made to the Contract Documents, and shall become a part of the Contract Documents dated January 2015.

1. Add the following material to **Vol. 2, Section 09900-2, PAINTING, Item 2.02 SCHEDULE OF COATING MATERIALS.**

Coating C-2 Immersion-Non Immersion Service:

Surface Preparation: Steel – Immersion Service

SSPC-SP10 Near White Metal Blast Cleaning

Steel – Non-Immersion Service

SSPC-SP6 Commercial Blast Cleaning

New Concrete – 28-day cure, brush off blast

Old Concrete – Hydroblast w/hot water and detergent, abrasive blast

System: High Solids, chemical and corrosion resistant Polyamidoamine Epoxy

Paint Types: Tnemec Series 69 High Build Epoxoline II Series V69 (low VOC)  
or Koppers Super Hi-Gard 892  
or Equal

Primer: Self-Priming

Coats: Steel or Concrete – Two coats

Total 12-16 mils dry film thickness

Color: To be selected

2. Add the following areas to **Vol. 2, Section 09900-7, PAINTING, Item 3.06.B. SCHEDULE OF PAINTING.**

B. SCHEDULE OF PAINTING – New concrete and piping and new equipment only:

LOCATION	COATING SYSTEM NUMBER				
	CONCRETE			PIPES, METALWORK <sup>(1)</sup> INCLUDING PLASTIC PIPE	
	EXTERIOR		INTERIOR	SUBMERGED	EXPOSED
	BELOW GRADE	ABOVE GRADE			
GRIT WASHER PLATFORM					
Concrete	--	--	--	--	C-4
Piping, Metalwork	--	--	--	--	C -3
Wrapped concrete	--	--	--	--	C -4
MARINWOOD PUMP STATION VALVE PIT					
Piping, Metalwork	--	--	--	--	C - 3
MARINWOOD PUMP STATION PUMP PIT					
Piping, Metalwork	--	--	--	C - 2	C - 2
DIGESTER MIXING PUMP					
Piping, Metalwork	--	--	--	--	C - 3

(1) Excludes aluminum and stainless steel only.

This addendum consists of 3 pages (including these pages). Acknowledge receipt of this addendum in the space provided on page 2-5, Proposal Cover Page and Bid Schedule, of the Bid Forms, and by signing in the space provided below. Submit original copy of this addendum cover page along with the bid. Failure to do so may disqualify the bidder.

Las Gallinas Valley Sanitary District:



Michael P. Cortez, PE, District Engineer  
Tel. No. (415) 472-1033, ext. 18

Bidder: \_\_\_\_\_

\_\_\_\_\_  
(Authorized Signature)

(Date)