



**CITY OF PORT COLBORNE
REQUEST FOR PROPOSAL**

**DESIGN, SUPPLY, INSTALL STAND-BY GENERATOR
LOCATED AT CITY HALL, 66 CHARLOTTE STREET**

ADDENDUM #2

This addendum shall form an integral part of the specifications and plans for the above project and shall be read in conjunction therewith. This addendum shall, however, take precedence over all requirements of the previously issued specifications and plans with which it may prove to be at variance, unless otherwise clarified by the Contract Administrator.

This addendum must be signed by the tenderer in the appropriate space and must be attached to the RFP Summary for submission at the time of bidding. Bidders not including this addendum, signed as required, may be rejected as informal.

Additional Information:

Manufacturer and Model of UPS – APS Smart Ups 1000XL (all units)

Size and voltage of service at Guild Hall – 200 Amp 120/208 Volt 3 phase

Date issued: Wednesday October 20th, 2010

Jim Huppunen
Manager of Engineering Services

Tenderer's Signature: _____

Company Name: _____

Date: _____